



บรรณานุกรม

1. ไกรสร อุดมรัตน์ "การกำจัดน้ำทิ้งจากโรงงานผลิตเต้าหู้ด้วยเครื่องกรองแอนแอโรบิค" วิทยานิพนธ์ปริญาามหาบัณฑิต ภาควิชาวิศวกรรมสุขาภิบาล ปรัชิตวิทยาลัย จุฬาลงกรณ์มหาวิทยาลัย, 2521
2. กรรณิกา สิริสิงห์ "เคมีของน้ำ น้ำไล่โครก และการวิเคราะห์" กรุงเทพฯ : พิมพ์ที่ บริษัทสารมวลชนจำกัด, 2522
3. เฉษฐา ค่ำศึก "ผลของความลึกและตำแหน่งของชั้นตัวกลางต่อสมรรถนะเครื่องกรองไร้ออกซิเจน" วิทยานิพนธ์ปริญาามหาบัณฑิต ภาควิชาวิศวกรรมสุขาภิบาล ปรัชิตวิทยาลัย จุฬาลงกรณ์มหาวิทยาลัย, 2527
4. ธงชัย พรรณสวัสดิ์ "คู่มือวิเคราะห์น้ำทิ้ง" สถาบันวิจัยสภาวะแวดล้อม จุฬาลงกรณ์มหาวิทยาลัย, 2525
5. บัญญัติ ล้อยศรีงาม "จุลชีววิทยาทั่วไป" กรุงเทพฯ : สำนักพิมพ์โอเดียนสโตร์, 2525
6. พรพจน์ วรรณสุต "การกำจัดน้ำทิ้งที่มีสารอินทรีย์สูงมากด้วยเครื่องกรองแอนแอโรบิคที่มีชั้นตัวกรองสูง" วิทยานิพนธ์ปริญาามหาบัณฑิต ภาควิชาวิศวกรรมสุขาภิบาล ปรัชิตวิทยาลัย จุฬาลงกรณ์มหาวิทยาลัย, 2526
7. ไทพรรณ พรประภา และมันสิน ตัณฑุลเวคัม "การกำจัดน้ำไล่โครกจากโรงงานน้ำตาลโดยใช้เครื่องกรองแอนแอโรบิค" งานวิจัยหมายเลข 17.SA-2519 คณะวิศวกรรมศาสตร์ จุฬาลงกรณ์มหาวิทยาลัย, 2519
8. มันสิน ตัณฑุลเวคัม "การออกแบบชั้นขบวนการของระบบกำจัดน้ำเสียโดยวิธีชีววิทยา" เล่ม 1 ความรู้พื้นฐาน ภาควิชาวิศวกรรมสิ่งแวดล้อม คณะวิศวกรรมศาสตร์ จุฬาลงกรณ์มหาวิทยาลัย, 2525
9. "การออกแบบชั้นขบวนการของระบบกำจัดน้ำเสียที่อาศัยหลักชีววิทยา" เล่ม 3-การออกแบบ ภาควิชาวิศวกรรมสุขาภิบาล คณะวิศวกรรมศาสตร์ จุฬาลงกรณ์มหาวิทยาลัย, 2523.
10. โรมรัน ศรัสมฤทธิ "การศึกษาเบื้องต้นในการผลิตก๊าซชีวภาพจากเครื่องกรองไร้ออกซิเจนที่ใช้อินทรีย์วัสดุเป็นตัวกลาง" วิทยานิพนธ์ปริญาามหาบัณฑิต ภาควิชาวิศวกรรมสุขาภิบาล ปรัชิตวิทยาลัย จุฬาลงกรณ์มหาวิทยาลัย, 2525

11. วิทยา เพียรวิจิตร "เทคโนโลยีการกำจัดน้ำเสีย" กรุงเทพฯ : สำนักพิมพ์โอเดียนส์โตร์, 2525
12. เสริมพล รัตนสุ้ย และ ชัยยุทธ์ กลิ่นสุคนธ์ "การกำจัดน้ำทิ้งจากโรงงานอุตสาหกรรม และแหล่งชุมชน" พิมพ์ครั้งที่ 2 โรงพิมพ์สถาบันวิจัยวิทยาศาสตร์แห่งประเทศไทย, 2525
13. สุจินต์ พนาวิฑูกุล "การแก้ปัญหาตะกอนฮีดในระบบ Activated Sludge" วารสารวิศวกรรมสาร, ปีที่ 37 เล่มที่ 46 (ธันวาคม 2527)
14. Andrew, J.F. "A Dynamic Model of the Anaerobic Digestion Process" Proc of the 23rd Ind. Waste Conf Purdue University 1968
15. Basu A.K. and E. Leclerc "Comparative Study on Treatment of Beet Molasses Waste by Thermophilic and Mesophilic Digestion" University of Lieque Belgiun 1973
16. Bjorn Fronstell "Anaerobic treatment in a sludge bed system compared with a filter system" J.WPCF, Vol.53, No.2, 216-222
17. Blane & Molof "Electrode Potential and Electrolytic Control of the Anaerobic Digestion Process" Proc: 24th Industrial Waste Conference, Purdue University, 1040-1056, 1969
18. Chongrak Polprasert, Le H. Hoang "Kinetic of Bacteria and bacteriophages in anaerobic filter" J.WPCF, Vol.55, No.4, 385-391
19. D.C.M. Hines and D.W. Weeter "Production of Ammonia in a Pack-Bed Anaerobic Upflow (ANFLOW) Bioreactor" Water Research, Vol.77, No.209, 1980
20. Dilallo. R. and Alberston, D.E. "Volatile Acid Direct Trtitration" J.WPCF, Vol.33, No.4, 1969, 356-365
21. Dirasian, H.A., et. al "Electrode potentials developed during sludge digestion" J.WPCF, Vol.35, No.4, 1963, 423-439

22. Donovan, et. al "Treatment of High Strength Waste By An Anaerobic Filter" Proc of the Seminar/Work Shop Anaerobic Filter : An Energy Plus for Wastewater Treatment, Jan.9-10, 1980, Howey-In-The-Hills, Fla, ANL/CNSV-TM-50, 179 (1980)
23. EL-SHAFIE, A.T. and BLOODGOOD, D.E. (1973) "Anaerobic Treatment in a Multiple Upflow Filter System" J.WPCF , Vol.54, No.11, 2345-2357
24. Kroeker E.J. and D.D. Schulte, A.B. Sparling, H.M. Lapp "Anaerobic treatment process stability" (1979) J.WPCF., Vol.51, No.4, 718-726
25. Friedman, et. al "New Observation With Anaerobic Fixed Film Reactors" Proc. of the Saminar/Work Shop, Anaerobic Filter : An Energy Plus for Wastewater Treatment, Jan 9-10, 1980, Howey-In-The-Hills, Fla., ANL/CNSV-TM-50, 95, (1981)
26. George V. Crawford, Tom Alkema, Michael Yue, Michael Thorne "Anaerobic treatment of thermal conditioning liquors" (1982) J.WPCF., Vol.54, No.11, 1458-1464.
27. Rippon G.M. "The Bioenergy Process-An Overview" Water Pollution Control 1983
28. Hartz, K.E. and Kountz, R.R. "Effect of CO₂ and N₂ on anaerobic digestion" Journal of the Sanitary Engg. Dn, April 1966, pp.83-95
29. Jenett & Dennis, "Anaerobic Filter Treatment of Phamaceutial Waste" J.WPCF, Vol.47, No.1, pp.104-121
30. Khalique A. Khan, Makram T. Suidan, and Wendall H. Cross "Role of Surface Active Media in Anaerobic Filter" Joural of Environmental Engineering Division, Proceeding of the

American Society of Civil Engineering, ASCE, Vol.108,
No.EE2, April 1982

31. Kugelman, I.J., and McCarty P.L. "Cation Toxicity and Stimulation in Anaerobic Waste Treatment" J.WPCF, Vol.37, No.1, 1965, 97-115
32. Lawrence, A.W. and McCarty P.L. "Kinetic of Methane Fermentation in Anaerobic Treatment" J.WPCF, Vol.41, No.2, 1968
33. Landine, et. al "Potato Processing Wastewater Treatment Using Horizontal Anaerobic Filter" Can.Tnst.Food Sci Techonol. J., 14, 144 (1981)
34. Longworth & Macinnes "Apparent Oxidation-Reduction Potentials, Acid, and, Population Studies of L. Acidophilus under Anaerobic Conditions" J.Bacteriol, 32, 567, 1963
35. Lettinga., et al "Feasibility of Upflow Anaerobic Sludge Blanket (UASB) Process for the Treatment of Low Strength Wastes" In Proc 35th Ind. Waste Conf. (1980) Purdue University, 625 (1981)
36. Mueller, J.A., and Mancini, J.G. "Anaerobic Filter Kinetics and Application" 20th PIWC., ANN ARBOR SCIENCE, 2520
37. Vander Meer R.R., de Vletter "Anaerobic treatment of Wastewater : the gas-liquid sludge seperator" (1982) J.WPCF, Vol.54, No.1, 103-110
38. Landine R.C., T. Viraraghavan, a.a. Cocci and G.J. Brown "Anaerobic fermentation-filtration of potato processing wastewater" (1982) J.WPCF, Vol.55, No.5, 448-453
39. Jenkins SR, J.M. Morgan, C.L. Sawyer "Measuring anaerobic sludge digestion and growth by a simple alkalimetric titration" (1983) J.WPCF, Vol.55, No.5, 448-453

40. Schwartz, et.al "Anaerobic Digestion of A Waste Water Treatment Side Stream : Potential for Energy Conservation" Proc. U.S. Dept of Energy, Energy Optimization of Water and Waste Water Management for Municipal and Industrial Applications Conf, Dec 10-13, 1979, New Orleans La ANL/EES-TM-96, 1, 235 (1980)
41. Tesch W.,K. Schneider and R. Bachofen "Performance of an Anaerobic Filter for Purification and Methane Production from Waste Water of a Sugar Refinery" Process Biochemistry, January/February 1983
42. Young, J.C., and McCarty, P.L. "The Anaerobic Filter For Waste Treatment" (1967) J.WPCF, Vol.41, No.5, 160-174
43. Young, J.C., and McCarty P.L. "Anaerobic Waste Treatment Fundamental" Public Work, 1964

ศูนย์วิทยทรัพยากร
จุฬาลงกรณ์มหาวิทยาลัย



ภาคผนวก

ศูนย์วิทยทรัพยากร
จุฬาลงกรณ์มหาวิทยาลัย

ตารางที่ 1.4 ค่า pH จากเครื่องกรองใร้ออกซิเจนที่มีชั้นตัวกลางเติมแต่ง ภายใต้การทำงานที่ระดับออกซิเจนไหลคดถึง 1 ก.ก.ซีไอดี/ม³ - วัน

PH 100% MEDIA L= 3 KG/CUM-DAY

DATE	.15	.30	.45	.75	1.05	1.20	DATE	.15M	.30	.45	.75	1.05	1.20
7/20	6.50	6.90	6.80	6.85	7.00	6.90	9/01	6.80	6.95	6.95	6.80	6.85	6.90
7/21	6.80	6.95	6.90	6.90	6.90	7.00	9/02	6.75	6.85	6.80	6.80	6.90	6.90
7/22	6.80	6.90	6.90	6.80	6.90	6.90	9/03						
7/23	6.80	6.90	6.80	6.90	6.90	7.00	9/04						
7/24	6.95	6.90	7.00	7.00	7.00	7.20	9/05	6.85	6.90	6.90	6.90	6.85	7.00
7/25							9/06	6.65	7.00	6.90	6.90	6.90	7.05
7/26	6.95	7.00	6.90	6.90	6.80	7.00	9/07	6.90	6.95	6.90	6.90	6.90	6.95
7/27	6.70	6.90	6.90	6.90	6.90	7.00	9/08	6.90	6.90	6.90	6.95	6.90	7.00
7/28	6.70	6.80	6.90	6.90	6.80	7.20	9/09	6.90	6.85	6.95	6.90	6.90	7.00
7/29	6.80	6.80	6.90	6.90	6.80	6.90	9/10						
7/30							9/11						
7/31							9/12	7.00	7.00	7.00	7.00	7.00	7.20
8/01	6.50	6.70	6.70	6.70	6.70	6.70	9/13	6.90	6.90	7.00	7.00	7.00	7.10
8/02	6.75	6.80	6.75	6.75	6.75	6.75	9/14	6.70	6.90	7.00	7.00	7.00	7.00
8/03	6.60	6.60	6.60	6.60	6.70	6.70	9/15	6.70	6.70	7.00	6.85	6.90	6.95
8/04	6.60	6.60	6.60	6.75	6.80	6.90	9/16	6.75	6.75	6.90	7.00	6.90	6.90
8/05	6.70	6.70	6.70	6.70	6.70	6.80	9/17						
8/06							9/18						
8/07							9/19	7.00	7.00	7.00	7.00	7.00	7.00
8/08	6.60	7.00	7.00	7.00	7.00	7.10	9/20	6.95	7.00	6.95	6.90	6.90	7.05
8/09	6.80	6.85	6.85	6.85	6.85	7.20	9/21	7.00	7.00	7.00	6.90	6.90	6.95
8/10	6.65	6.65	6.75	6.75	6.75	6.80	9/22	7.00	7.00	7.00	6.90	6.90	7.05
8/11	6.80	6.80	6.90	6.80	6.85	7.00	9/23	6.80	6.90	6.90	7.00	6.95	7.00
8/12	6.90	6.80	6.90	6.80	6.80	7.00	9/24						
8/13							9/25						
8/14							9/26		6.90		6.90		7.00
8/15	6.80	6.80	6.80	6.80	6.80	7.00	9/27		6.90		6.90		7.00
8/16	6.70	6.75	6.75	6.80	6.90	6.80	9/28		6.90		6.90		6.95
8/17	6.70	6.80	6.80	6.80	6.80	7.20	9/29		6.95		6.85		6.95
8/18	6.90	6.95	6.90	6.90	7.10	7.00	9/30		6.80		6.80		6.90
8/19	7.00	7.00	7.10	7.00	7.00	7.00	10/01						
8/20							10/02						
8/21							10/03	6.80	6.80	6.80	6.80	6.90	6.90
8/22	6.25	6.90	6.80	6.80	6.90	7.00	10/04	6.70	6.80	6.80	6.80	6.90	6.95
8/23	6.95	7.00	6.90	6.85	6.80	7.00	10/05	6.70	6.80	6.90	6.90	7.00	6.90
8/24	6.90	6.90	6.90	6.90	6.90	7.15	10/06	6.70	6.80	6.95	6.95	6.90	6.95
8/25	7.00	7.00	7.00	6.90	6.95	7.00	10/07	6.70	6.95	6.90	6.90	6.90	7.00
8/26	6.85	6.90	6.90	6.85	6.80	7.20							
8/27													
8/28													
8/29	6.25	6.95	6.95	6.85	6.90	7.15							
8/30	6.88	6.95	6.95	6.85	6.90	7.10							
8/31	6.90	6.90	6.95	6.90	6.90	7.25							



ตารางที่ 3 ค่า pH จากเครื่องกรองร็อกซ์หินยิปซัมตัวกลางเต็มถัง ภายใต้การ
ทำงานที่ระดับออกซิเจนละลายน้ำ 3 ก.ก.ซีโอดี/ม³ - วัน

PH 100% L= 3 KG/CUM-DAY

DATE	.15M	.30M	.45M	.75M	1.05M	1.20M	DATE	.15M	.30M	.45M	.75M	1.05M	1.20M
11/14		6.60		7.10		6.90	01/01						
11/15		7.00		7.20		7.10	01/02		6.80		6.80		7.00
11/16		6.60		6.80		6.90	01/03		6.75		6.90		7.00
11/17		6.70		7.00		7.00	01/04		6.65		6.80		7.10
11/18		6.70		6.90		6.90	01/05		6.65		6.85		7.00
11/19		6.70		6.90		6.90	01/06		6.65		6.80		6.90
11/20							01/07						
11/21		6.65		6.70		7.10	01/08						
11/22		6.65		6.70		6.90	01/09		6.80		6.80		6.90
11/23		6.65		6.80		6.90	01/10		6.70		6.70		6.80
11/24		6.80		6.90		7.15	01/11		6.90		6.90		7.10
11/25		6.70		6.90		7.00	01/12		6.70		6.75		6.90
11/26							01/13		6.50		6.60		6.85
11/27							01/14						
11/28		6.70		6.70		6.80	01/15						
11/29		6.80		6.85		6.90	01/16		6.80		6.90		7.00
11/30		6.50		6.70		6.85	01/17		6.50		6.70		6.85
12/01		6.50		6.70		6.90	01/18		6.60		6.80		6.95
12/02							01/19		6.65		6.85		6.95
12/03							01/20		6.50		6.70		6.85
12/04							01/21						
12/05		6.80		6.90		7.10	01/22						
12/06		6.80		6.85		7.00	01/23		6.65		6.90		7.20
12/07		6.80		6.80		7.00	01/24		6.65		6.70		6.90
12/08		6.70		6.70		6.90	01/25		6.75		6.75		6.80
12/09		6.60		6.80		6.95	01/26		6.60		6.65		6.80
12/10							01/27	6.65	6.70	6.80	6.80	6.90	6.85
12/11							01/28						
12/12		6.50		6.60		6.80	01/29						
12/13		6.60		6.70		6.80	01/30	6.70	6.75	6.85	6.90	6.90	6.80
12/14		6.70		6.70		6.90	01/31	6.70	6.70	6.80	6.85	6.90	6.90
12/15		6.40		6.75		6.90	02/01	6.65	6.65	6.85	6.90	7.00	7.00
12/16		6.60		6.80		7.00	02/02	6.75	6.75	6.90	6.95	7.00	7.00
12/17							02/03	6.70	6.75	6.90	6.95	7.05	7.00
12/18							02/04						
12/19		6.80		6.90		7.20	02/05						
12/20		6.70		6.80		7.00	02/06	6.65	6.70	6.90	6.90	7.00	7.00
12/21		6.60		6.80		7.05	02/07	6.60	6.65	6.85	6.85	6.95	7.00
12/22		6.65		6.95		7.20	02/08	6.60	6.70	6.80	6.90	7.05	6.90
12/23		6.70		6.80		7.10	02/09	6.65	6.75	6.90	7.00	7.10	6.90
12/24							02/10	6.70	6.80	6.85	7.00	7.05	7.00
12/25													
12/26		6.40		6.70		7.10							
12/27		6.45		6.70		6.90							
12/28		6.50		6.70		7.10							
12/29		6.60		6.65		6.95							
12/30		6.60		6.80		7.10							
12/31		6.60		6.80		7.10							

ตารางที่ 8 น ค่าสภาพความเป็นด่างทั้งหมดจากเครื่องกรองไร้ออกซิเจนที่มีชั้นตัวกลางครึ่ง
ถังลอย ภายใต้การทำงานที่ระดับออร์แกนิคโหลดคั่ง 1 ก.ก.ซีโอดี/ม³-วัน

TOTAL ALKALINITY 50% MEDIA L= 1 KG/CUM-DAY

DATE	.15M	.30M	.45M	.75M	1.05M	1.20M	DATE	.15M	.30M	.45M	.75M	1.05M	1.20M
7/20	1450	1475	1425	1575	1525	1325	9/01	1518	1499	1487	1487	1487	1494
7/21	1500	1525	1525	1500	1500	1325	9/02	1446	1518	1506	1566	1570	1558
7/22	1475	1525	1525	1500	1525	1500	9/03						
7/23	1525	1525	1500	1550	1550	1450	9/04						
7/24							9/05	1590	1578	1590	1602	1590	1554
7/25	1600	1637	1625	1625	1625	1637	9/06	1631	1655	1629	1643	1643	1607
7/26	1537	1575	1575	1562	1575	1487	9/07	1614	1614	1614	1614	1590	1602
7/27	1375	1450	1450	1437	1450	1450	9/08	1600	1590	1610	1610	1620	1600
7/28	1396	1439	1410	1425	1453	1439	9/09	1590	1590	1627	1627	1602	1528
7/29	1390	1453	1410	1420	1450	1467	9/10						
7/30							9/11						
7/31							9/12	1440	1490	1470	1520	1580	1560
8/01	1339	1637	1396	1439	1396	1425	9/13	1460	1451	1487	1560	1580	1560
8/02	1595	1575	1567	1567	1482	1496	9/14	1450	1420	1600	1610	1620	1554
8/03	1510	1450	1510	1539	1539	1524	9/15	1450	1451	1570	1580	1600	1554
8/04	1467	1439	1467	1510	1482	1467	9/16	1450	1525	1525	1537	1550	1540
8/05	1453	1453	1439	1439	1410	1425	9/17						
8/06							9/18						
8/07							9/19	1446	1450	1580	1580	1620	1600
8/08	1439	1425	1439	1482	1496	1467	9/20	1450	1450	1625	1662	1650	1600
8/09	1596	1596	1596	1596	1610	1567	9/21	1446	1625	1590	1614	1600	1625
8/10	1581	1596	1581	1581	1610	1453	9/22	1450	1600	1637	1637	1637	1612
8/11	1553	1581	1581	1610	1596	1581	9/23	1446	1670	1620	1662	1640	1671
8/12	1520	1520	1520	1590	1590	1581	9/24						
8/13							9/25						
8/14							9/26		1587		1600		1650
8/15	1653	1653	1681	1653	1638	1710	9/27		1521		1550		1610
8/16	1539	1539	1567	1596	1624	1624	9/28		1537		1537		1540
8/17	1553	1553	1581	1610	1624	1610	9/29		1512		1550		1562
8/18	1551	1522	1551	1566	1566	1421	9/30		1562		1575		1575
8/19	1522	1552	1567	1611	1682	1682	10/01						
8/20							10/02						
8/21							10/03	1460	1550	1560	1580	1570	1530
8/22	1522	1580	1508	1580	1624	1522	10/04	1460	1550	1560	1562	1570	1550
8/23	1551	1551	1539	1638	1551	1493	10/05	1540	1575	1560	1550	1566	1600
8/24	1566	1551	1537	1551	1551	1508	10/06	1480	1550	1580	1575	1580	1575
8/25	1420	1520	1525	1560	1560	1563	10/07	1495	1500	1525	1550	1550	1575
8/26	1305	1497	1522	1551	1551	1439	10/08						
8/27							10/09						
8/28							10/10	1520	1541	1518	1562	1566	1575
8/29	1378	1487	1487	1499	1463	1571							
8/30	1504	1482	1470	1518	1494	1446							
8/31	1506	1506	1518	1506	1518	1434							

ตารางที่ 11 ผ ค่าสภาพความเป็นด่างทั้งหมดจากเครื่องกรองไร้ออกซิเจน ที่มีอินตัวกลาง
เต็มถัง ภายใต้การทำงานที่ระดับออร์แกนิกโหลดคั่ง 5 กก.ซีโอดี/ม³-วัน
TOTAL ALKALINITY 100% MEDIA L= 5 KG/CUM-DAY

DATE	.15M	.30M	.45M	.75M	1.05M	1.20M	WASTE	DATE	.15M	.30M	.45M	.75M	1.05M	1.20M	WASTE
02/14						3321	3452	03/17							
02/15						3553	3321	03/18							
02/16						3553	3321	03/19		3577		4230		4240	3948
02/17						3836	3452	03/20		3510		4027		4558	3922
02/18								03/21		3690		4027		4160	3987
02/19								03/22		3555		3940		4372	3852
02/20						4635	3321	03/23		3610		4027		4160	3922
02/21						4635	3321	03/24							
02/22						4609	3452	03/25							
02/23						4240	3452	03/26		3892		4230		4240	3895
02/24						4506	3321	03/27		3577		4055		4297	3735
02/25								03/28		3510		4387		4365	3802
02/26								03/29		3315		3892		3825	3502
02/27								03/30		3352		3892		4297	3645
02/28						4841	3321	03/31							
02/29						4134	3452	04/01							
03/01						4240	3392	04/02	3275	3375	3780	3960	3960	3915	3600
03/02						4331	3321	04/03							
03/03								04/04	3195	3577	3780	3712	3712	3825	3645
03/04								04/05	3275	3555	3757	3960	3960	3915	3645
03/05						4266	3321	04/06	3352	3577	3780	4185	4185	3825	3645
03/06						4213	3321	04/07							
03/07						4160	3452	04/08	3367	3825	4005	4005	4005	4140	3600
03/08						4331	3452	04/09	3352	3690	3870	4297	4297	4140	3802
03/09						4505	3452	04/10	3420	3780	3915	3982	3982	4005	3855
03/10								04/11	3345	3780	4230	4275	4275	4050	3825
03/11								04/12	3345	3892	4005	4230	4230	3957	3855
03/12						4478	3690								
03/13						4531	3690								
03/14						4664	3736								
03/15						4531	3736								
03/16						4319	3852								

ศูนย์สัตวแพทย์
จุฬาลงกรณ์มหาวิทยาลัย

ตารางที่ 12 ม ค่าสภาพความเป็นต่างทั้งหมดจากเครื่องกรองไร้ออกซิเจน ที่มีชั้นตัวกลาง
ครึ่งถังลอย ภายใต้การทำงานที่ระดับออร์แกนิกโหลดถึง 5 ก.ก.ซีโอดี/
ม³ - วัน

TOTAL ALKALINITY 50% MEDIA L= 5 KG/CUM-DAY

DATE	.15M	.30M	.45M	.75M	1.05M	1.20M	WASTE	DATE	.15M	.30M	.45M	.75M	1.05M	1.20M	WASTE
02/14		3520					3452 3452	03/17							
02/15		3340					3321 3321	03/18							
02/16		3296					3321 3321	03/19		3652		4107		4107	3948
02/17		3392					3939 3939	03/20		3621		4054		4240	3922
02/18								03/21		3692		4293		4160	3987
02/19								03/22		3710		4160		4240	3852
02/20		3252		3975		4107	3948	03/23		3789		4234		4240	3922
02/21		3583		4054		4240	3922	03/24							
02/22		3405		4095		4235	3852	03/25							
02/23		3583		4160		4160	4085	03/26		3299		4160		3948	3895
02/24		3662		4035		4257	4085	03/27		3289		3937		3915	3735
02/25								03/28		3600		4095		4027	3802
02/26								03/29		3421		4275		4140	3520
02/27								03/30		3396		4230		4297	3645
02/28		3789		4319		4379	4510	03/31							
02/29		4215		4372		4346	4660	04/01							
03/01		4558		4531		4452	4531	04/02	3200	3230	3870	3825	3870	3780	3600
03/02		4358		4200		4240	4160	04/03							
03/03								04/04	3237	3210	3712	4162	4117	4027	3645
03/04								04/05	3200	3310	3757	3825	4117	4027	3645
03/05		4372		4452		4425	4379	04/06	3235	3285	3948	4230	4230	4117	3645
03/06		3789		4558		4505	4081	04/07							
03/07		3922		4534		4531	3922	04/08	3100	3230	3555	3735	3780	3870	3600
03/08		4358		4372		4531	4081	04/09	3210	3240	3757	3780	4117	4027	3802
03/09		4372		4452		4478	4134	04/10	3210	3240	3622	3757	3948	3937	3855
03/10								04/11	3100	3210	3757	3825	3839	3735	3825
03/11								04/12	3210	3200	3600	3690	3780	3735	3855
03/12		3941		5387		5387	3922								
03/13		3899		4478		4425	3736								
03/14		4213		4452		4452	4160								
03/15		3789		4372		4372	3852								
03/16		3710		4234		4240	3852								



ตารางที่ 13 ม ค่า VFA จากเครื่องกรองไร้ออกซิเจนที่มีชั้นตัวกลางเต็มถัง ภายใต้การ
ทำงานที่ระดับออร์แกนิกโหลดคั่ง 1 ก.ก.ซีโอดี/ม³-วัน

VFA 100% MEEIA L= 1 KE/CUK-DAY

DATE	.15M	.30M	.45M	.75M	1.05M	1.20M	DATE	.15M	.30M	.45M	.75M	1.05M	1.20M
7/20	160	100	90	90	90	90	9/01	313	144	144	162	148	171
7/21	150	90	90	90	90	80	9/02	313	313	313	313	175	180
7/22	327	277	171	171	171	171	9/03						
7/23	209	114	114	104	123	123	9/04						
7/24							9/05	168	173	117	140	150	145
7/25	153	139	84	89	79	144	9/06	104	127	136	136	163	136
7/26	285	120	115	115	125	125	9/07	180	162	139	139	139	167
7/27	397	170	125	145	160	135	9/08	318	318	342	334	179	180
7/28	277	120	135	120	135	145	9/09	347	349	342	355	180	180
7/29	277	120	135	120	135	145	9/10						
7/30							9/11						
7/31							9/12	347	347	304	340	340	180
8/01	300	135	130	140	160	175	9/13	313	313	313	313	313	180
8/02	337	330	150	115	120	130	9/14	180	180	180	175	175	167
8/03	322	277	155	285	160	175	9/15	168	180	160	160	161	167
8/04	315	170	160	170	160	180	9/16	142	160	113	128	142	119
8/05	330	285	285	160	180	180	9/17						
8/06							9/18						
8/07							9/19	277	277	160	150	140	130
8/08	465	427	337	330	300	180	9/20	285	277	180	160	140	135
8/09	487	307	160	175	180	277	9/21	285	311	277	180	142	120
8/10	315	277	285	322	315	315	9/22	277	296	277	180	161	135
8/11	170	120	125	130	135	135	9/23	277	277	277	180	161	140
8/12	170	170	160	140	130	130	9/24						
8/13							9/25						
8/14							9/26		180		160		160
8/15	130	125	155	140	130	130	9/27		180		160		140
8/16	190	175	160	165	135	135	9/28		277		160		127
8/17	170	160	150	160	145	135	9/29		277		165		127
8/18	180	162	162	180	160	167	9/30		277		180		119
8/19	160	157	133	123	138	108	10/01						
8/20							10/02						
8/21							10/03	277	171	171	167	140	167
8/22	172	157	167	148	143	89	10/04	277	171	160	160	140	166
8/23	153	133	113	153	138	108	10/05	285	176	165	161	145	156
8/24	162	108	113	157	120	103	10/06	285	166	165	141	145	145
8/25	160	160	155	153	140	160	10/07	285	166	166	141	145	140
8/26	155	190	155	175	177	91							
8/27													
8/28													
8/29	177	187	180	216	211	89							
8/30	325	295	180	347	325	123							
8/31	273	280	180	177	273	273							

ตารางที่ 19 ผ ค่า HCO_3^- จากเครื่องกรองไร้ออกซิเจนที่มีชั้นตัวกลางเติมผง ภายใต้งาน
การทํางานที่ระดับออกซิเจนละลายถึง 1 ก.ก.ซิโอดี/ม³-วัน

BICARBONATE 100% MEDIA L= 1 KG/CUN-DAY

DATE	.15M	.30M	.45M	.75M	1.05M	1.20M	DATE	.15M	.30M	.45M	.75M	1.05M	1.20M
7/20	1165	1225	1250	1260	1260	1320	9/01	1102	1307	1318	1344	1334	1335
7/21	1225	1235	1285	1285	1285	1420	9/02	1193	1193	1128	1152	1319	1318
7/22	1073	1171	1204	1229	1229	1204	9/03						
7/23	1166	1286	1286	1271	1277	1262	9/04						
7/24							9/05	1434	1417	1401	1414	1356	1433
7/25	1409	1398	1428	1436	1471	1356	9/06	1515	1432	1423	1423	1360	1442
7/26	1215	1305	1372	1385	1375	1350	9/07	1422	1392	1451	1415	1415	1417
7/27	978	1255	1287	1292	1290	1265	9/08	1272	1162	1208	1206	1361	1395
7/28	1190	1305	1361	1376	1347	1379	9/09	1243	1132	1159	1185	1222	1282
7/29	1143	1340	1370	1370	1345	1333	9/10						
7/30							9/11						
7/31							9/12	1193	1124	1236	1210	1220	1340
8/01	1139	1290	1309	1285	1293	1250	9/13	1247	1177	1277	1237	1247	1330
8/02	1145	1180	1326	1495	1518	1409	9/14	1326	1340	1360	1375	1365	1363
8/03	1117	1162	1384	1292	1199	1349	9/15	1338	1350	1399	1380	1399	1353
8/04	1195	1354	1284	1340	1350	1330	9/16	1383	1374	1424	1382	1406	1393
8/05	1023	1140	1168	1293	1259	1259	9/17						
8/06							9/18						
8/07							9/19	1203	1253	1380	1390	1420	1411
8/08	931	1012	1073	1123	1153	1273	9/20	1169	1191	1221	1197	1247	1254
8/09	923	1175	1322	1292	1197	1176	9/21	1236	1176	1233	1246	1242	1403
8/10	1081	1176	1154	1103	1165	1165	9/22	1208	1236	1221	1233	1241	1411
8/11	1383	1433	1414	1422	1399	1475	9/23	1243	1310	1293	1400	1399	1450
8/12	1360	1372	1380	1413	1384	1450	9/24						
8/13							9/25						
8/14							9/26		1370		1377		1420
8/15	1523	1499	1526	1513	1518	1523	9/27		1360		1377		1380
8/16	1373	1392	1450	1459	1445	1518	9/28		1365		1315		1360
8/17	1440	1507	1531	1508	1550	1533	9/29		1310		1310		1363
8/18	1328	1375	1389	1386	1377	1370	9/30		1312		1307		1368
8/19	1319	1336	1360	1428	1412	1442	10/01						
8/20							10/02						
8/21							10/03	1235	1396	1380	1238	1299	1293
8/22	1321	1365	1326	1302	1350	1433	10/04	1183	1354	1391	1290	1360	1294
8/23	1337	1387	1496	1500	1427	1433	10/05	1227	1336	1386	1351	1367	1356
8/24	1421	1464	1427	1588	1620	1535	10/06	1182	1346	1388	1371	1394	1366
8/25	1464	1485	1465	1487	1520	1520	10/07	1202	1314	1387	1412	1435	1440
8/26	1469	1419	1487	1437	1418	1489							
8/27													
8/28													
8/29	1394	1384	1348	1307	1349	1471							
8/30	1205	1199	1195	1195	1229	1407							
8/31	1221	1190	1329	1329	1269	1221							



ตารางที่ 20 ค่า HCO_3^{-1} จากเครื่องกรองไร้ออกซิเจนที่มีชั้นตัวกลางครึ่งถังลอย ภายใต้
 การทำงานที่ระดับออกแอกซิเจนถึง 1 ก.ก.ซิโอดี/ม³-วัน

BICABOMATE 50% MEDIA L= 1 KG/CUM-DAY

DATE	.15M	.30M	.45M	.75M	1.05M	1.20M	DATE	.15M	.30M	.45M	.75M	1.05M	1.20M
7/20	1390	1433	1373	1545	1485	1265	9/01	1218	1199	1210	1187	1307	1314
7/21	1410	1445	1445	1420	1420	1235	9/02	1131	1203	1229	1191	1390	1378
7/22	1323	1364	1364	1367	1402	1377	9/03						
7/23	1393	1407	1396	1450	1451	1336	9/04						
7/24							9/05	1313	1301	1305	1317	1425	1384
7/25	1534	1573	1551	1580	1580	1553	9/06	1346	1378	1344	1366	1478	1434
7/26	1367	1410	1410	1402	1445	1367	9/07	1329	1337	1329	1329	1420	1422
7/27	1225	1300	1270	1332	1310	1340	9/08	1323	1313	1333	1325	1445	1420
7/28	1216	1259	1230	1265	1303	1294	9/09	1305	1305	1350	1350	1427	1353
7/29	1210	1273	1245	1265	1310	1337	9/10						
7/30							9/11						
7/31							9/12	1163	1213	1185	1235	1420	1460
8/01	1189	1174	1221	1294	1271	1295	9/13	1280	1271	1210	1275	1415	1400
8/02	1296	1273	1260	1402	1302	1326	9/14	1270	1240	1323	1325	1480	1384
8/03	1340	1364	1345	1394	1369	1354	9/15	1290	1274	1293	1303	1455	1394
8/04	1347	1347	1342	1370	1372	1332	9/16	1290	1348	1248	1260	1410	1380
8/05	1298	1289	1279	1309	1260	1300	9/17						
8/06							9/18						
8/07							9/19	1281	1330	1435	1460	1510	1500
8/08	1054	1125	1079	1190	1316	1287	9/20	1290	1330	1514	1542	1515	1512
8/09	1421	1436	1441	1436	1500	1452	9/21	1286	1500	1470	1489	1518	1519
8/10	1411	1446	1401	1426	1450	1298	9/22	1280	1460	1497	1517	1536	1506
8/11	1413	1441	1456	1515	1516	1521	9/23	1286	1550	1480	1542	1530	1571
8/12	1380	1380	1395	1470	1490	1466	9/24						
8/13							9/25						
8/14							9/26		1457		1480		1540
8/15	1553	1573	1581	1563	1558	1610	9/27		1386		1420		1490
8/16	1399	1419	1457	1486	1524	1534	9/28		1372		1426		1433
8/17	1443	1453	1481	1510	1549	1530	9/29		1385		1443		1445
8/18	1448	1409	1448	1487	1478	1346	9/30		1435		1458		1467
8/19	1402	1432	1459	1523	1598	1594	10/01						
8/20							10/02						
8/21							10/03	1300	1430	1450	1468	1470	1418
8/22	1382	1460	1405	1490	1536	1414	10/04	1310	1412	1382	1434	1450	1423
8/23	1411	1428	1444	1530	1448	1393	10/05	1285	1463	1440	1434	1466	1488
8/24	1416	1453	1439	1461	1467	1426	10/06	1325	1424	1460	1458	1470	1458
8/25	1270	1400	1422	1470	1488	1483	10/07	1345	1370	1395	1423	1440	1463
8/26	1145	1377	1419	1459	1479	1362							
8/27													
8/28													
8/29	1201	1276	1310	1386	1350	1448							
8/30	1135	1113	1153	1386	1361	1323							
8/31	1137	1137	1201	1326	1405	1277							

ตารางที่ 24 ม. ค่า HCO_3^{-1} จากเครื่องกรองโรออกซิเจนที่มีชั้นตัวกลางครึ่งถังลอย ภายใต้

ปฏิบัติการงานที่ระดับออร์แกนิกโหลดถึง 5 ก.ก.ซิโอดี/ม³-วัน

.....

BICARBONATE 50% MEDIA L= 5 KG/CUM-DAY

DATE	.15M	.30M	.45M	.75M	1.05M	1.20M	WASTE	DATE	.15M	.30M	.45M	.75M	1.05M	1.20M	WASTE
02/14		2200				2010	3362	03/17							
02/15		1995				2079	3231	03/18							
02/16		1975				2108	3209	03/19		2277		2787		3065	3836
02/17		2009				2657	3827	03/20		2146		2893		2902	3810
02/18								03/21		2346		2977		3010	3875
02/19								03/22		2364		2844		2789	3740
02/20		1801		2435		2825	3836	03/23		2431		2986		3090	3832
02/21		2132		2569		2958	3810	03/24							
02/22		2185		2705		3022	3740	03/25							
02/23		2173		2945		2913	3973	03/26		1942		2912		2708	3805
02/24		2279		2550		3000	3950	03/27		1912		2691		2705	3645
02/25								03/28		2241		2847		2782	3712
02/26								03/29		2301		3005		2920	3430
02/27								03/30		2050		2960		3052	3555
02/28		2351		3406		3542	4246	03/31							
02/29		2768		3024		3066	4584	04/01							
03/01		3108		3216		3177	4419	04/02	1762	1849	2432	2577	2540	2520	3510
03/02		2908		2885		2965	4048	04/03							
03/03								04/04	1795	1870	2372	3017	2817	2760	3555
03/04								04/05	1758	1930	2472	2625	2817	2907	3555
03/05		2685		3102		3150	4287	04/06	1795	1905	2638	2985	2872	2907	3555
03/06		2239		3008		3155	3946	04/07							
03/07		2539		3201		3181	3787	04/08	1680	1890	2215	2493	2628	2628	3510
03/08		2975		2989		3256	3969	04/09	1800	1830	2472	2493	2689	2889	3712
03/09		3022		3137		3364	4022	04/10	1795	1975	2337	2607	2728	2787	3465
03/10								04/11	1685	1820	2477	2575	2798	2585	3735
03/11								04/12	1760	1825	2320	2440	2485	2535	3465
03/12		2558		3837		4237	3832								
03/13		2516		3162		3075	3624								
03/14		2796		3047		2967	4048								
03/15		2372		2786		2820	3717								
03/16		2235		2851		3025	3740								



ตารางที่ 25 น ค่า HCO_3^- จากเครื่องกรองไร้ออกซิเจนที่มีชั้นตัวกรองเต็มถัง ภายใต้
การทำงานที่ระดับออร์แกนิกโหลดถึง 1 ก.ก.ซีโอดี/ม³-วัน (วิเคราะห์
โดย titrate ด้วยกรดจนถึง pH 5.75)

HCO_3 AT 5.75 100% MEDIA L=1 KG/CUM-DAY

DATE	.15M	.30M	.45M	.75M	1.05M	1.20M	DATE	.15M	.30M	.45M	.75M	1.05M	1.20
7/20	975	1000	1025	1025	975	1075	9/01	904	936	952	952	891	904
7/21	925	900	925	950	1000	1050	9/02	964	936	976	940	928	910
7/22	900	975	950	1000	975	950	9/03						
7/23	875	950	1000	1000	975	975	9/04						
7/24							9/05	1048	976	1072	1096	952	1072
7/25	1150	1162	1212	1212	1275	1200	9/06	1025	1072	1144	1096	1012	1132
7/26	1137	1062	1137	1137	1150	1000	9/07	1120	1144	1072	1084	1084	1060
7/27	950	950	925	925	1012	950	9/08	1131	1072	1260	1110	1100	1100
7/28	912	883	897	897	983	940	9/09	1217	1267	1267	1110	1093	1192
7/29							9/10						
7/30							9/11						
7/31							9/12	1110	1116	1087	1137	1029	1010
8/01	869	826	855	855	826	798	9/13	1174	1200	1210	1220	1087	1087
8/02	940	954	954	940	954	912	9/14	1026	1247	1247	1250	1200	1180
8/03	940	983	954	883	855	855	9/15	1117	1160	1200	1210	1210	1200
8/04	926	997	954	926	912	926	9/16	1087	1160	1220	1250	1200	1120
8/05	840	940	940	926	883	954	9/17						
8/06							9/18						
8/07							9/19	1020	1075	962	1110	1000	1100
8/08	741	883	912	855	840	883	9/20	1025	1050	1012	1210	875	938
8/09	855	940	969	897	940	869	9/21	1025	1075	1120	1075	975	938
8/10	926	969	954	940	954	969	9/22	1112	1075	1075	987	987	987
8/11	1026	1026	1040	1011	1040	1154	9/23	1020	1050	1120	1062	1062	1000
8/12							9/24						
8/13							9/25						
8/14							9/26		1087		1020		900
8/15	1110	1097	1168	111	1068	1083	9/27		1080		1100		910
8/16	969	969	997	1026	1083	1083	9/28		1112		1025		980
8/17	926	1011	983	1011	1068	1068	9/29		1062		925		980
8/18							9/30		1006		962		1000
8/19							10/01						
8/20	986	1000	1026	986	1029	1073	10/02						
8/21	1110	1116	1131	1044	1087	1000	10/03	962	1025	1037	950	1008	950
8/22	1015	1073	989	913	1000	1058	10/04	925	962	962	925	875	1020
8/23	1174	1166	1189	1073	986	1058	10/05	1025	1025	1012	975	975	975
8/24	1305	1247	1131	1189	1131	1189	10/06	1025	1125	1012	925	1093	980
8/25	1131	1160	1110	1116	1116	1261	10/07	980	1006	1020	980	1110	980
8/26	1044	1044	1058	1029	957	1000							
8/27													
8/28													
8/29	1050	1060	952	952	940	964							
8/30	1036	1036	976	976	988	976							
8/31	1000	1072	964	1012	1048	964							

ตารางที่ 31 ม ค่า VFA/HCO_3^{-1} จากเครื่องกรองไร้ออกซิเจนที่มีชั้นตัวกลางเต็มถัง
ภายใต้การทำงานที่ระดับออร์แกนิกโหลดถึง 1 ก.ก.ชีโอดี/ม³-วัน

VFA/HCO₃ 100% MEDIA L= 1 KG/CUM-DAY

DATE	.15M	.30M	.45M	.75M	1.05M	1.20M	DATE	.15M	.30M	.45M	.75M	1.05M	1.20M
7/20	0.49	0.08	0.07	0.07	0.07	0.06	9/01	0.28	0.11	0.11	0.12	0.11	0.13
7/21	0.12	0.07	0.07	0.07	0.07	0.05	9/02	0.25	0.26	0.30	0.29	0.13	0.14
7/22	0.30	0.24	0.14	0.14	0.13	0.14	9/03						
7/23	0.18	0.09	0.09	0.09	0.09	0.10	9/04						
7/24							9/05	0.12	0.12	0.08	0.10	0.11	0.10
7/25	0.11	0.10	0.05	0.06	0.05	0.11	9/06	0.07	0.09	0.09	0.09	0.12	0.09
7/26	0.23	0.09	0.08	0.08	0.09	0.09	9/07	0.13	0.12	0.09	0.10	0.10	0.12
7/27	0.40	0.14	0.10	0.11	0.12	0.11	9/08	0.25	0.27	0.28	0.28	0.13	0.12
7/28	0.23	0.09	0.10	0.09	0.10	0.11	9/09	0.28	0.30	0.34	0.30	0.15	0.14
7/29	0.24	0.09	0.10	0.09	0.10	0.11	9/10						
7/30							9/11						
7/31							9/12	0.29	0.31	0.24	0.28	0.28	0.13
8/01	0.26	0.10	0.10	0.10	0.12	0.14	9/13	0.25	0.26	0.24	0.25	0.25	0.13
8/02	0.29	0.28	0.11	0.08	0.08	0.09	9/14	0.13	0.13	0.13	0.13	0.13	0.12
8/03	0.29	0.23	0.11	0.22	0.13	0.13	9/15	0.12	0.12	0.11	0.11	0.11	0.12
8/04	0.26	0.13	0.12	0.12	0.12	0.13	9/16	0.10	0.08	0.08	0.09	0.10	0.09
8/05	0.32	0.25	0.24	0.12	0.14	0.14	9/17						
8/06							9/18						
8/07							9/19	0.23	0.22	0.11	0.11	0.10	0.09
8/08	0.49	0.42	0.31	0.29	0.26	0.14	9/20	0.24	0.23	0.15	0.13	0.11	0.11
8/09	0.53	0.26	0.12	0.14	0.24	0.23	9/21	0.23	0.26	0.22	0.14	0.11	0.09
8/10	0.29	0.24	0.25	0.29	0.27	0.27	9/22	0.23	0.24	0.22	0.14	0.13	0.09
8/11	0.12	0.08	0.09	0.09	0.09	0.09	9/23	0.22	0.21	0.21	0.13	0.11	0.10
8/12	0.13	0.12	0.12	0.10	0.10	0.09	9/24						
8/13							9/25						
8/14							9/26		0.13		0.12		0.11
8/15	0.09	0.08	0.10	0.09	0.09	0.08	9/27		0.13		0.12		0.10
8/16	0.13	0.12	0.11	0.11	0.10	0.09	9/28		0.20		0.12		0.09
8/17	0.12	0.11	0.10	0.10	0.10	0.09	9/29		0.21		0.12		0.10
8/18	0.13	0.12	0.12	0.13	0.11	0.12	9/30		0.21		0.14		0.10
8/19	0.12	0.12	0.10	0.09	0.10	0.07	10/01						
8/20							10/02						
8/21							10/03	0.22	0.12	0.12	0.13	0.11	0.13
8/22	0.13	0.12	0.13	0.11	0.10	0.06	10/04	0.23	0.13	0.11	0.12	0.10	0.13
8/23	0.11	0.10	0.08	0.10	0.09	0.07	10/05	0.23	0.13	0.12	0.12	0.11	0.11
8/24	0.10	0.07	0.06	0.10	0.07	0.07	10/06	0.24	0.12	0.12	0.10	0.10	0.11
8/25	0.11	0.11	0.10	0.10	0.09	0.10	10/07	0.24	0.13	0.12	0.10	0.10	0.10
8/26	0.11	0.13	0.10	0.12	0.12	0.06							
8/27													
8/28													
8/29	0.13	0.13	0.13	0.16	0.16	0.06							
8/30	0.27	0.25	0.23	0.29	0.25	0.09							
8/31	0.22	0.24	0.31	0.13	0.21	0.22							

ตารางที่ 32 ม ค่า VFA/HCO_3^{-1} จากเครื่องกรองไร้ออกซิเจนที่มีชั้นตัวกลางครึ่งถังลอย
ภายใต้การทำงานที่ระดับออร์แกนิกโหลดถึง 1 ก.ก.ซีโอดี/ม³-วัน

VFA/HCO₃ 50% MEDIA L= 1 KG/CUM-DAY

DATE	.15M	.30M	.45M	.75M	1.05M	1.20M	DATE	.15M	.30M	.45M	.75M	1.05M	1.20M
7/20	0.04	0.03	0.03	0.02	0.02	0.05	9/01	0.25	0.25	0.23	0.25	0.12	0.14
7/21	0.06	0.06	0.06	0.06	0.05	0.07	9/02	0.28	0.26	0.22	0.26	0.12	0.13
7/22	0.11	0.12	0.12	0.12	0.09	0.09	9/03						
7/23	0.10	0.08	0.08	0.06	0.07	0.09	9/04						
7/24							9/05	0.21	0.21	0.22	0.22	0.11	0.12
7/25	0.10	0.10	0.10	0.08	0.07	0.07	9/06	0.21	0.20	0.21	0.20	0.12	0.12
7/26	0.12	0.12	0.12	0.11	0.09	0.07	9/07	0.21	0.21	0.21	0.21	0.09	0.13
7/27	0.12	0.12	0.14	0.08	0.10	0.08	9/08	0.21	0.21	0.21	0.21	0.10	0.13
7/28	0.15	0.14	0.15	0.12	0.11	0.11	9/09	0.22	0.22	0.20	0.20	0.10	0.13
7/29	0.15	0.14	0.13	0.12	0.10	0.10	9/10						
7/30							9/11						
7/31							9/12	0.24	0.23	0.24	0.23	0.07	0.11
8/01	0.13	0.14	0.14	0.11	0.14	0.10	9/13	0.14	0.14	0.23	0.22	0.09	0.11
8/02	0.23	0.23	0.24	0.12	0.07	0.13	9/14	0.14	0.14	0.21	0.21	0.05	0.12
8/03	0.13	0.12	0.12	0.10	0.11	0.13	9/15	0.12	0.13	0.21	0.21	0.07	0.11
8/04	0.09	0.10	0.09	0.10	0.05	0.10	9/16	0.12	0.13	0.22	0.22	0.07	0.11
8/05	0.12	0.12	0.13	0.10	0.07	0.10	9/17						
8/06							9/18						
8/07							9/19	0.13	0.09	0.10	0.08	0.07	0.07
8/08	0.35	0.27	0.33	0.25	0.05	0.14	9/20	0.12	0.09	0.07	0.08	0.09	0.06
8/09	0.12	0.11	0.11	0.11	0.06	0.08	9/21	0.12	0.08	0.08	0.08	0.05	0.07
8/10	0.12	0.10	0.13	0.11	0.05	0.12	9/22	0.13	0.10	0.09	0.08	0.07	0.07
8/11	0.10	0.10	0.09	0.06	0.06	0.04	9/23	0.12	0.08	0.09	0.08	0.07	0.06
8/12	0.10	0.10	0.09	0.07	0.04	0.08	9/24						
8/13							9/25						
8/14							9/26		0.09		0.08		0.07
8/15	0.06	0.05	0.06	0.06	0.06	0.06	9/27		0.10		0.09		0.08
8/16	0.10	0.08	0.08	0.07	0.07	0.06	9/28		0.12		0.08		0.07
8/17	0.08	0.07	0.07	0.06	0.06	0.06	9/29		0.09		0.07		0.08
8/18	0.07	0.08	0.07	0.05	0.05	0.06	9/30		0.09		0.08		0.07
8/19	0.09	0.08	0.07	0.06	0.05	0.06	10/01						
8/20							10/02						
8/21							10/03	0.12	0.08	0.08	0.08	0.07	0.08
8/22	0.10	0.08	0.07	0.06	0.08	0.07	10/04	0.11	0.10	0.09	0.09	0.08	0.09
8/23	0.10	0.09	0.06	0.07	0.10	0.07	10/05	0.13	0.08	0.08	0.08	0.07	0.07
8/24	0.11	0.07	0.07	0.60	0.08	0.07	10/06	0.12	0.09	0.08	0.08	0.07	0.08
8/25	0.12	0.09	0.07	0.06	0.14	0.06	10/07	0.11	0.09	0.09	0.09	0.08	0.08
8/26	0.14	0.09	0.07	0.06	0.13	0.06							
8/27													
8/28													
8/29	0.15	0.14	0.13	0.08	0.12	0.08							
8/30	0.32	0.33	0.27	0.10	0.11	0.09							
8/31	0.32	0.32	0.26	0.13	0.12	0.12							

ตารางที่ 35 ม ค่า VFA/HCO_3^{-1} จากเครื่องกรองไร้ออกซิเจนที่มีชั้นตัวกลางเติมถัง
ภายใต้การทำงานที่ระดับออร์แกนิกโหลดถึง 5 ก.ก.ชีโอดี/ม³-วัน

VFA/HCO₃ 100% MEDIA L= 5 KG/CUM-DAY

DATE	.15M	.30M	.45M	.75M	1.05M	1.20M	DATE	.15M	.30M	.45M	.75M	1.05M	1.20M
02/14						0.91	03/17						
02/15						0.74	03/18						
02/16						0.87	03/19		2.02		1.30		1.17
02/17						0.84	03/20		2.27		1.11		1.07
02/18							03/21		1.95		1.17		1.37
02/19							03/22		2.06		1.17		1.03
02/20						0.55	03/23		2.08		1.47		1.15
02/21						0.60	03/24						
02/22						0.54	03/25						
02/23						0.70	03/26		1.93		1.30		0.92
02/24						0.74	03/27		2.02		1.72		1.07
02/25							03/28		2.05		1.20		0.86
02/26							03/29		2.25		1.29		1.04
02/27							03/30		2.50		1.33		0.89
02/28						0.52	03/31						
02/29						0.60	04/01						
03/01						0.57	04/02	1.94	2.12	1.33	1.24	1.16	1.07
03/02						0.61	04/03						
03/03							04/04	1.86	2.14	1.43	1.20	1.34	1.12
03/04							04/05	1.94	1.98	1.35	1.21	1.15	0.99
03/05						0.77	04/06	1.81	2.14	1.33	1.29	1.03	1.04
03/06						1.08	04/07						
03/07						0.65	04/08	1.78	1.88	1.43	1.26	1.13	0.98
03/08						0.75	04/09	1.81	1.81	1.35	1.15	0.98	0.96
03/09						0.86	04/10	1.45	1.54	1.23	0.99	1.10	1.02
03/10							04/11	1.67	1.80	1.04	1.01	0.96	1.03
03/11							04/12	1.82	1.66	1.25	1.01	0.97	1.04
03/12						1.11							
03/13						1.12							
03/14						0.91							
03/15						1.16							
03/16						0.96							

ตารางที่ 36 ม ค่า VFA/HCO_3^{-1} จากเครื่องกรองไร้ออกซิเจนที่มีชั้นตัวกลางครึ่งถังลอย
ภายใต้การทำงานที่ระดับออร์แกนิกโหลดถึง 5 ก.ก.ซีโอดี/ม³-วัน

VFA/HCO₃ 50% MEDIA L= 5 KG/CUM-DAY

DATE	.15M	.30M	.45M	.75M	1.05M	1.20M	DATE	.15M	.30M	.45M	.75M	1.05M	1.20M
02/14		0.62				0.59	03/17						
02/15		0.66				0.59	03/18						
02/16		0.68				0.57	03/19		0.60		0.43		0.37
02/17		0.69				0.48	03/20		0.68		0.43		0.46
02/18							03/21		0.56		0.44		0.38
02/19							03/22		0.56		0.46		0.44
02/20		0.80		0.55		0.45	03/23		0.55		0.41		0.37
02/21		0.68		0.58		0.43	03/24						
02/22		0.64		0.51		0.40	03/25						
02/23		0.64		0.44		0.42	03/26		0.69		0.43		0.45
02/24		0.60		0.58		0.41	03/27		0.70		0.46		0.44
02/25							03/28		0.60		0.43		0.44
02/26							03/29		0.57		0.42		0.41
02/27							03/30		0.65		0.42		0.40
02/28		0.61		0.35		0.35	03/31						
02/29		0.52		0.44		0.42	04/01						
03/01		0.46		0.40		0.40	04/02	0.81	0.74	0.52	0.49	0.48	0.50
03/02		0.49		0.45		0.43	04/03						
03/03							04/04	0.81	0.71	0.54	0.41	0.42	0.43
03/04							04/05	0.82	0.71	0.52	0.45	0.42	0.38
03/05		0.63		0.43		0.40	04/06	0.80	0.72	0.49	0.41	0.41	0.41
03/06		0.69		0.51		0.42	04/07						
03/07		0.54		0.43		0.42	04/08	0.84	0.70	0.60	0.49	0.43	0.47
03/08		0.46		0.46		0.39	04/09	0.78	0.77	0.52	0.53	0.44	0.39
03/09		0.44		0.42		0.37	04/10	0.78	0.74	0.55	0.44	0.44	0.44
03/10							04/11	0.84	0.74	0.51	0.48	0.41	0.45
03/11							04/12	0.82	0.75	0.55	0.51	0.47	0.47
03/12		0.54		0.40		0.29							
03/13		0.55		0.41		0.44							
03/14		0.51		0.46		0.43							
03/15		0.57		0.57		0.44							
03/16		0.50		0.48		0.40							

จุฬาลงกรณ์มหาวิทยาลัย

ตารางที่ 37 ผ ค่า ORP. จากเครื่องกรองไร้ออกซิเจนที่มีชั้นตัวกลางเต็มถัง ภายใต้
การทำงานที่ระดับออกซิเจนไหลคงที่ 1 ก.ก. ออกซิเจน/ม³-วัน

ORP 100% MEDIA L= 1 KG/CUM-DAY

DATE	.15M	.30M	.45M	.75M	1.05M	1.20M	DATE	.15M	.30M	.45M	.75M	1.05M	1.20M
7/20	-320	-300	-300	-320	-310	-390	9/01	-340	-350	-340	-330	-330	-280
7/21	-320	-300	-310	-310	-300	-300	9/02	-360	-350	-340	-330	-340	-300
7/22	-310	-300	-310	-300	-310	-260	9/03						
7/23	-330	-330	-320	-300	-300	-280	9/04						
7/24	-340	-340	-340	-300	-300	-300	9/05	-360	-360	-340	-350	-330	-300
7/25							9/06	-380	-360	-330	-350	-340	-310
7/26	-350	-340	-320	-330	-330	-300	9/07	-350	-350	-330	-340	-340	-300
7/27	-340	-340	-340	-320	-320	-320	9/08	-360	-350	-320	-340	-340	-300
7/28	-320	-320	-320	-310	-310	-300	9/09	-360	-340	-320	-340	-340	-310
7/29	-320	-320	-320	-310	-310	-300	9/10						
7/30							9/11						
7/31							9/12	-340	-340	-320	-320	-320	-285
8/01	-400	-380	-380	-320	-340	-320	9/13	-350	-30	-320	-330	-320	-300
8/02	-400	-350	-360	-380	-320	-320	9/14	-350	-340	-325	-320	-320	-300
8/03	-340	-330	-320	-340	-338	-320	9/15	-350	-310	-325	-310	-300	-300
8/04	-350	-340	-330	-330	-330	-310	9/16	-360	-320	-320	-310	-300	-280
8/05	-340	-330	-330	-340	-338	-320	9/17						
8/06							9/18						
8/07							9/19	-350	-330	-320	-320	-310	-300
8/08	-320	-320	-340	-300	-318	-312	9/20	-330	-320	-320	-320	-320	-280
8/09	-350	-320	-340	-320	-322	-320	9/21	-330	-325	-320	-320	-320	-300
8/10	-340	-340	-330	-320	-300	-300	9/22	-330	-325	-330	-330	-320	-300
8/11	-330	-330	-330	-330	-330	-360	9/23	-350	-325	-320	-320	-300	-300
8/12	-340	-340	-310	-320	-300	-300	9/24						
8/13							9/25						
8/14							9/26		-320		-300		-300
8/15	-350	-350	-320	-340	-340	-300	9/27		-330		-310		-290
8/16	-350	-350	-340	-340	-320	-300	9/28		-330		-300		-290
8/17	-320	-330	-340	-320	-300	-280	9/29		-340		-320		-290
8/18	-330	-330	-320	-320	-290	-280	9/30		-350		-318		-300
8/19	-330	-320	-320	-320	-300	-280	10/01						
8/20							10/02						
8/21							10/03	-350	-310	-320	-300	-300	-280
8/22	-340	-340	-330	-320	-310	-280	10/04	-340	-320	-320	-310	-300	-280
8/23	-360	-350	-320	-340	-320	-300	10/05	-340	-330	-320	-310	-300	-300
8/24	-330	-340	-322	-340	-340	-290	10/06	-340	-330	-330	-310	-300	-270
8/25	-320	-320	-320	-320	-330	-390	10/07	-340	-330	-330	-310	-290	-290
8/26	-340	-330	-340	-320	-320	-320							
8/27													
8/28													
9/29	-320	-320	-347	-320	-330	-310							
8/30	-340	-325	-350	-320	-320	-230							
8/31	-340	-330	-340	-320	-320	-300							

ตารางที่ 38 ณ ค่า ORP. จากเครื่องกรองไร้ออกซิเจนที่มีชั้นตัวกลางครึ่งถังล้อย ภาย-
ใต้การทำงานที่ระดับออกซิเจนไหลคงที่ 1 ก.ก.ซีโอดี/ม³-วัน

ORP 50% MEDIA L= 1K6/CUM-DAY

DATE	.15M	.30M	.45M	.75M	1.05M	1.20M	DATE	.15M	.30M	.45M	.75M	1.05M	1.20M
7/20	-310	-320	-300	-320	-320	-300	9/01	-340	-335	-320	-330	-300	-280
7/21	-340	-320	-320	-340	-320	-300	9/02	-360	-320	-338	-330	-295	-295
7/22	-320	-310	-300	-300	-290	-300	9/03						
7/23	-300	-320	-320	-320	-300	-300	9/04						
7/24	-320	-310	-310	-300	-300	-300	9/05	-350	-338	-330	-320	-318	-318
7/25							9/06	-350	-338	-325	-320	-310	-310
7/26	-340	-340	-320	-300	-310	-320	9/07	-340	-320	-305	-300	-280	-295
7/27	-320	-320	-310	-300	-300	-320	9/08	-340	-330	-310	-300	-280	-290
7/28	-320	-320	-300	-300	-300	-310	9/09	-340	-322	-322	-300	-300	-310
7/29	-320	-320	-300	-300	-300	-300	9/10						
7/30							9/11						
7/31							9/12	-325	-325	-320	-315	-300	-300
8/01	-378	-360	-360	-320	-320	-310	9/13	-340	-320	-320	-315	-300	-300
8/02	-420	-360	-340	-360	-340	-320	9/14	-330	-325	-310	-310	-300	-290
8/03	-330	-340	-338	-340	-330	-320	9/15	-330	-300	-310	-300	-295	-280
8/04	-350	-340	-330	-330	-320	-310	9/16	-330	-310	-300	-300	-300	-270
8/05	-330	-340	-338	-340	-330	-320	9/17						
8/06							9/18						
8/07							9/19	-340	-330	-310	-310	-280	-280
8/08	-320	-320	-318	-318	-300	-280	9/20	-320	-310	-300	-300	-280	-280
8/09	-320	-340	-340	-320	-300	-300	9/21	-330	-320	-310	-305	-300	-270
8/10	-340	-340	-330	-320	-310	-300	9/22	-330	-318	-310	-302	-300	-300
8/11	-340	-330	-320	-280	-290	-300	9/23	-340	-330	-320	-300	-300	-290
8/12	-340	-330	-320	-290	-290	-280	9/24						
8/13							9/25						
8/14							9/26		-330		-310		-260
8/15	-350	-340	-340	-340	-320	-300	9/27		-330		-300		-280
8/16	-350	-350	-340	-320	-310	-280	9/28		-330		-300		-290
8/17	-330	-320	-320	-320	-320	-280	9/29		-330		-300		-300
8/18	-320	-30	-300	-300	-270	-270	9/30		-360		-330		-310
8/19	-340	-320	-320	-320	-310	-300	10/01						
8/20							10/02						
8/21							10/03	-340	-310	-320	-300	-300	-270
8/22	-320	-310	-300	-300	-290	-270	10/04	-330	-310	-310	-300	-280	-260
8/23	-320	-320	-310	-300	-300	-300	10/05	-340	-330	-320	-300	-280	-300
8/24	-342	-340	-325	-330	-320	-300	10/06	-340	-330	-320	-320	-290	-290
8/25	-340	-310	-300	-300	-300	-270	10/07	-340	-330	-320	-300	-290	-280
8/26	-340	-340	-310	-320	-310	-280							
8/27													
8/28													
8/29	-310	-300	-320	-320	-320	-300							
8/30	-340	-320	-318	-310	-300	-270							
8/31	-330	-320	-320	-320	-310	-280							

ตารางที่ 42 ม ค่า ORP. จากเครื่องกรองร้ออกซิเจนที่มีชั้นตัวกลางครึ่งถังลอย
ภายใต้การทำงานที่ระดับออกซิเจนไหลคั่ง 5 ก.ก.ซีโอค/ม³-วัน

ORP 50% MEDIA L= 5 K6/CUM-DAY

DATE	.15K	.30K	.45K	.75K	1.05K	1.20K	DATE	.15K	.30K	.45K	.75K	1.05K	1.20K	
02/14		-320		-310		-270	03/17							
02/15		-340		-300		-270	03/18							
02/16		-320		-310		-300	03/19		-330		-320		-320	
02/17		-350		-340		-320	03/20		-350		-330		-320	
02/18							03/21		-370		-360		-350	
02/19							03/22		-350		-340		-330	
02/20		-350		-330		-310	03/23		-350		-340		-330	
02/21		-340		-330		-300	03/24							
02/22		-360		-330		-300	03/25							
02/23		-360		-340		-320	03/26		-360		-340		-350	
02/24		-370		-340		-320	03/27		-370		-340		-330	
02/25							03/28		-360		-350		-320	
02/26							03/29		-350		-340		-330	
02/27		-350		-350		-300	03/30		-360		-340		-330	
02/28		-370		-300		-340	03/31							
02/29		-320		-350		-280	04/01							
03/01		-330		-340		-310	04/02		-370	-380	-380	-380	-350	-330
03/02							04/03							
03/03							04/04		-350	-340	-350	-350	-340	-320
03/04							04/05		-350	-340	-340	-340	-340	-320
03/05		-340		-350		-280	04/06		-350	-350	-340	-340	-330	-300
03/06		-340		-300		-320	04/07							
03/07		-370		-330		-340	04/08		-340	-350	-360	-360	-320	-280
03/08		-360		-310		-330	04/09							
03/09		-350		-340		-330	04/10		-360	-360	-350	-340	-320	-290
03/10							04/11		-350	-350	-340	-330	-320	-300
03/11							04/12		-340	-360	-360	-350	-330	-300
03/12		-360		-350		-340	04/13		-340	-350	-340	-330	-320	-310
03/13		-310		-330		-290	04/14		-340	-340	-350	-350	-340	-320
03/14		-340		-330		-320								
03/15		-330		-310		-290								
03/16		-340		-340		-320								



ตารางที่ 43 ม ค่า ซีโอดี จากเครื่องกรองไร้ออกซิเจนที่มีชั้นตัวกลางเติมถึง ภาบไต
 การทำงานที่ระดับออร์แกนิกโหลดคั่ง 1 ก.ก.ซีโอดี/ม³-วัน

COD 100% MEDIA L- # KG/CUM-DAY

DATE	.15M	.30M	.45M	.75M	1.05M	1.20M	DATE	.15M	.30M	.45M	.75M	1.05M	1.20M
7/20	454	322	248	231	223	211	9/01						
7/21							9/02						
7/22	602	346	290	282	273	265	9/03	338	302	356	345	394	374
7/23							9/04						
7/24	506	306	280	280	250	260	9/05	248	179	163	191	199	228
7/25							9/06						
7/26							9/07	406	308	236	280	272	280
7/27	563	315	311	264	248	235	9/08						
7/28							9/09	310	300	294	180	208	220
7/29	467	300	280	276	260	256	9/10						
7/30							9/11						
7/31							9/12	330	300	220	210	200	222
8/01	613	398	374	357	345	341	9/13						
8/02							9/14	334	240	240	228	224	226
8/03	538	526	518	365	325	321	9/15						
8/04							9/16	360	260	240	214	218	220
8/05	503	369	357	345	333	325	9/17						
8/06							9/18	259	198	201	190	191	180
8/07							9/19						
8/08	538	369	345	337	329	325	9/20	300	244	220	220	190	210
8/09							9/21						
8/10	674	435	356	490	462	410	9/22		240		210		212
8/11							9/23						
8/12	502	412	284	292	229	229	9/24		275		230		180
8/13							9/25						
8/14							9/26		265		240		230
8/15	481	350	242	226	203	187	9/27						
8/16							9/28		257		210		214
8/17	356	325	302	255	217	193	9/29						
8/18							9/30		281		242		222
8/19	304	321	286	177	233	166	10/01						
8/20	280	256	209	219	249	210	10/02		220		210		203
8/21							10/03		214		215		207
8/22	288	284	322	288	224	222	10/04						
8/23							10/05		286		188		183
8/24	241	271	214	238	228	201	10/06						
8/25							10/07	275	275	260	210	211	175
8/26	288	264	260	240	228	240	10/08						
8/27							10/09	281	276	261	220	210	176
8/28							10/10	277	270	267	220	210	180
8/29	260	280	285	322	301	152							
8/30													
8/31	282	221	192	250	239	242							

ตารางที่ 49 ม ปริมาณก๊าซทั้งหมด ก๊าซมีเทน จากเครื่องกรองทั้งสอง ภายใต้การทำ-

งานที่ระดับออร์แกนิกโหลดดิ่ง 1 ก.ก.ซีโอดี/ม³-วัน

ORGANICLOADING = 1 KGCU-M-DAY

DATE	GAS 50	%CH ₄ 50	GAS 100	%CH ₄	DATE	GAS 50%	%CH ₄	GAS 100	%CH ₄	CH ₄			
7/20	40.00	74	29.60	25.90	78	20.20	9/01	37.20	72.00	26.70	33.16	70.00	23.21
7/21	39.00	74	28.86	25.20	78	19.60	9/02						
7/22	40.00	74	29.60	29.90	77	23.00	9/03	43.20	72.00	31.10	37.90	72.00	27.00
7/23	38.00	74	28.12	26.70	76	20.29	9/04						
7/24	40.00	74	29.60	24.30	77	18.70	9/05	42.70	74.00	31.60	37.50	72.00	27.00
7/25	44.00	75	33.00	26.20	78	20.43	9/06	42.40	74.00	31.40	37.50	74.00	27.70
7/26	45.00	74	33.30	26.90	79	21.25	9/07	41.76	74.00	30.90	36.60	74.00	27.10
7/27	45.00	75	33.75	27.30	80	21.94	9/08						
7/28	40.00	72	28.80	23.10	80	18.45	9/09	39.96	75.00	30.20	34.98	74.00	25.88
7/29	40.00	74	29.60	27.20	75	20.40	9/10						
7/30							9/11						
7/31							9/12	43.20	75.00	32.40	37.84	77.00	29.13
8/01	41.00	75	30.75	28.90	77	22.25	9/13	43.30	75.00	32.40	37.51	77.00	28.80
8/02	40.00	75	30.00	35.80	79	28.28	9/14	42.36	75.00	31.70	37.62	78.00	29.01
8/03	42.00	74	31.08	28.40	77	21.86	9/15	43.36	75.00	31.70	39.60	77.00	30.49
8/04	35.00	76	25.60	33.00	77	22.20	9/16	43.80	75.00	32.80	38.50	80.00	30.80
8/05	34.90	77	26.80	31.90	76	24.20	9/17						
8/06	37.20	75	27.90	28.50	77	21.90	9/18	42.48	76.00	32.28	37.40	80.00	29.92
8/07	33.80	76	25.68	29.20	78	22.77	9/19						
8/08	35.16	74	26.01	29.20	77	22.48	9/20	42.70	75.00	32.04	37.50	76.00	28.50
8/09	32.50	77	25.02	26.90	76	20.44	9/21	43.20	73.00	31.50	37.60	78.00	29.30
8/10	33.40	77	25.70	32.70	72	23.54	9/22	43.20	75.00	32.40	37.80	78.00	29.40
8/11	35.04	77	26.98	25.70	78	20.04	9/23	42.00	73.00	30.60	37.40	76.00	28.42
8/12	31.20	77	24.02	29.90	77	23.00	9/24	42.10	75.00	31.60	37.50	78.00	29.25
8/13	31.20	77	24.02	32.60	78	25.40	9/25						
8/14	37.20	80	29.70	35.50	80	28.40	9/26	42.10	75.00	31.50	37.40	76.00	28.40
8/15	35.70	77	27.48	38.01	79	30.02	9/27	42.40	73.00	31.00	37.80	76.00	29.70
8/16	38.40	76	29.18	34.20	79	27.01	9/28	42.40	76.00	32.10	37.50	76.00	29.20
8/17	39.60	77	30.48	35.10	79	27.72	9/29	43.20	74.00	31.90	38.60	76.00	29.33
8/18	40.80	75	30.60	36.20	79	28.60	9/30	42.60	75.00	31.95	37.50	76.00	29.20
8/19	41.40	77	31.80				10/01						
8/20	42.10	76	31.99	35.90	81	29.07	10/02						
8/21	42.60	77	32.80	36.10	78	28.16	10/03	43.20	74.00	31.90	38.06	76.00	29.30
8/22	35.80	75	26.85	36.20	78	28.23	10/04	42.96	75.00	32.20	38.50	76.00	29.20
8/23	42.20	77	32.49	32.70	77	25.17	10/05	42.20	74.00	31.20	38.10	75.00	28.60
8/24	41.70	75	31.27	35.20	77	25.56	10/06	42.60	74.00	31.50	37.51	76.00	28.50
8/25	40.90	74	31.90	35.10	76	26.67	10/07	42.80	73.00	31.20	37.51	76.00	28.50
8/26	38.88	75	29.16	33.70	75	25.27							
8/27	39.00	75	30.18										
8/28	37.50	75	27.86	35.10	74	25.97							
8/29	38.80	72	27.90	33.20	73	24.28							
8/30	39.00	73	28.47	31.07	72	22.34							
8/31	38.64	72	27.82	33.02	73	24.10							

ตารางที่ 51 ผ ปริมาณก๊าซทั้งหมด ก๊าซมีเทน จากเครื่องกรองทั้งสอง ภายใต้การทำงาน
ที่ระดับออร์แกนิคโหลดถึง 5 ก.ก.ซีไอดี/ม³-วัน

LOADING = 5KG/CUM-DAY

ITE	GAS 50%	%CH4	CH4	GAS100%	%CH4	CH4	DATE	GAS 50%	%CH4	CH4	GAS100%	%CH4	CH4
2/14	118.69	60.00	71.00	110.76	50.00	55.00	03/17						
2/15	136.95	55.00	75.00	114.48	51.00	58.00	03/18						
2/16	148.94	54.00	80.00	127.20	50.00	64.00	03/19	164.00	55.00	91.84	145.20	52.00	75.50
2/17	144.00	55.00	79.00	120.12	52.00	62.40	03/20	161.00	56.00	90.00	145.80	52.00	75.85
2/18	146.30	54.00	80.00	128.28	52.00	66.70	03/21	161.70	56.00	90.55	146.40	52.00	76.13
2/19							03/22	153.12	56.00	85.74	147.12	50.00	73.65
2/20	146.30	55.00	80.40	124.20	55.00	68.30	03/23	156.20	55.00	85.91	147.60	51.00	75.27
2/21	143.77	55.00	78.50	117.00	53.00	65.50	03/24						
2/22	142.45	55.00	78.30	114.36	55.00	62.80	03/25						
2/23	141.90	53.00	76.00	116.04	50.00	61.50	03/26	166.70	59.00	98.38	140.00	57.00	79.82
2/24	145.20	56.00	81.00	117.24	56.00	65.60	03/27	147.70	64.00	94.55	151.56	59.00	89.42
2/25	146.74	55.00	81.70	114.00	56.00	63.80	03/28	154.00	66.00	101.64	141.96	61.00	86.59
2/26	144.10	55.00	79.20	113.76	55.00	62.00	03/29	157.85	65.00	102.60	144.00	61.00	87.84
2/27	151.80	56.00	85.00	118.44	52.00	61.00	03/30	166.00	64.00	107.00	145.40	60.00	87.26
2/28	134.00	60.00	80.40	128.00	53.00	74.00	03/31						
2/29	132.00	62.00	81.80	124.00	53.00	72.00	04/01	190.00	57.00	108.00	148.20	61.00	89.00
03/01	128.00	64.00	82.00	112.00	62.00	69.00	04/02	190.00	57.00	108.00	148.20	61.00	89.00
03/02	151.47	55.00	83.00	132.00	55.00	72.60	04/03						
03/03	142.36	60.00	85.40	116.80	53.00	67.70	04/04	167.00	57.00	95.00	145.00	59.00	85.00
03/04	149.90	57.00	85.40	110.70	60.00	66.40	04/05	171.00	58.00	99.00	147.00	60.00	88.00
03/05	153.00	56.00	86.10	112.40	60.00	67.40	04/06	181.00	58.00	104.00	148.00	60.00	88.80
03/06	133.87	59.00	79.00	117.00	60.00	70.20	04/07	187.00	58.00	108.00	148.80	60.00	89.30
03/07	150.48	59.00	87.20	117.00	63.00	74.00	04/08						
03/08	144.10	57.00	82.13	121.20	55.00	67.00	04/09	177.00	60.00	106.20	148.20	61.00	90.40
03/09	149.00	55.00	82.88	129.00	54.00	69.55	04/10	181.00	61.00	110.40	146.00	62.00	90.50
03/10							04/11	184.00	61.00	112.00	147.00	62.00	92.60
03/11							04/12	181.00	61.00	110.40	146.00	62.00	91.90
03/12	163.00	54.00	88.50	140.00	49.00	68.60							
03/13	166.00	55.00	91.30	145.68	47.00	69.20							
03/14	164.45	56.00	92.09	145.20	49.00	69.69							
03/15	166.65	56.00	93.32	145.20	53.00	76.20							
03/16	167.97	55.00	92.38	152.40	49.00	74.40							

ตารางที่ 52 ผ ตะกอนแขวนลอย จากเครื่องกรองไร้ออกซิเจนที่มีชั้นตัวกลางเต็มถัง
ภายใต้การทำงานที่ระดับออร์แกนิกโหลดถึง 1 ก.ก.ซีโอดี/ม³-วัน

SOLID 100% MEDIA L= 1 KG/CUM-DAY

DATE	.15K	.30K	.45K	.75K	1.05K	1.20K	DATE	.15K	.30K	.45K	.75K	1.05K	1.20K
7/20	2950	1490	480	264	120	110	9/01	2890	1620	600	335	140	120
7/21	3110	1510	452	279	110	90	9/02	2910	1640	610	350	150	124
7/22	3160	1490	462	256	125	95	9/03						
7/23							9/04						
7/24							9/05	3110	1650	620	368	170	120
7/25	3120	1560	510	262	110	80	9/06	3370	1600	610	344	185	116
7/26	3210	1540	470	255	115	85	9/07	3100	1640	590	364	185	120
7/27	3390	1530	450	242	120	95	9/08	3100	1620	620	351	190	100
7/28	3110	1525	460	270	120	90	9/09	3190	1680	680	348	210	120
7/29	2980	1545	420	278	125	95	9/10						
7/30							9/11						
7/31							9/12	2930	1720	651	420	220	100
8/01	2950	1545	490	260	150	70	9/13	2830	1690	672	440	220	95
8/02	2800	1540	490	283	136	80	9/14	2910	1710	675	441	210	95
8/03	2860	1532	520	260	123	90	9/15	2940	1685	686	451	180	105
8/04	2930	1525	540	280	122	90	9/16	2980	1680	690	462	180	100
8/05	3360	1500	542	285	120	110	9/17						
8/06							9/18						
8/07							9/19	2820	1740	720	428	175	110
8/08	3760	1540	560	320	160	114	9/20	2820	1740	710	444	195	100
8/09	3530	1450	560	348	136	100	9/21						
8/10	3100	1500	581	310	120	89	9/22	2800	1750	680	408	195	100
8/11	3200	1500	491	352	160	89	9/23						
8/12	3010	1520	570	310	160	88	9/24	3250	1760	640	404	185	120
8/13							9/25						
8/14							9/26	3550	1754		450		108
8/15	3100	1580	610	325	180	109	9/27						
8/16	3200	1575	610	352	175	88	9/28	3800	1750		440		105
8/17	3225	1585	625	373	180	87	9/29						
8/18	3220	1610	610	373	165	91	9/30	3820	1780		410		106
8/19	3410	1620	640	380	166	94	10/01	4100	1800		420		110
8/20							10/02						
8/21							10/03	4210	1810		441		120
8/22	3440	1640	590	300	168	104	10/04						
8/23	3410	1660	575	345	170	106	10/05	4110	1820		422		102
8/24	3444	1660	610	315	175	110	10/06						
8/25	3250	1675	610	310	175	124	10/07						
8/26	3160	1640	620	380	180	110	10/08	4315	1810	675	415	180	110
8/27							10/09						
8/28							10/10	4210	1815	680	441	175	113
8/29	3050	1710	610	310	180	121							
8/30	3251	1650	620	310	185	124							
8/31	3300	1640	620	320	180	131							

ตารางที่ 53 ผ ตะกอนแขวนลอยจากเครื่องกรองไร้ออกซิเจนที่มียื่นตัวกลางครึ่งถังลอย
ภายใต้การทำงานที่ระดับออร์แกนิคโหลดตั้ง 1 ก.ก.ซีโอซี/ม³-วัน

SOLID 50% MEDIA L= 1 KG/CUM-DAY

DATE	.15K	.30K	.45K	.75K	1.05K	1.20K	DATE	.15K	.30K	.45K	.75K	1.05K	1.20K
7/20	4070	1320	600	505	157	124	9/01	3920	1480	568	552	220	180
7/21	3620	1350	615	545	155	110	9/02	3810	1350	580	472	210	180
7/22	3580	1320	644	502	155	157	9/03						
7/23							9/04						
7/24							9/05	4100	1276	568	456	216	210
7/25	3120	1310	641	541	161	170	9/06	4210	1336	616	515	252	190
7/26	3340	1310	652	525	163	171	9/07	4400	1336	616	476	212	190
7/27	3340	1350	600	512	160	188	9/08	4200	1354	620	490	242	185
7/28	3220	1350	640	532	156	164	9/09	4100	1380	652	520	252	165
7/29	3650	1350	668	540	186	164	9/10						
7/30							9/11						
7/31							9/12	4124	1312	611	511	228	180
8/01	3544	1484	684	520	180	145	9/13	4221	1350	622	522	235	190
8/02	3510	1492	692	510	172	127	9/14	4410	1330	615	515	241	175
8/03	3564	1536	696	488	172	135	9/15	4330	1386	630	530	241	170
8/04	3570	1340	624	468	185	150	9/16	4210	1370	650	550	220	150
8/05	3524	1470	670	440	180	150	9/17						
8/06							9/18						
8/07							9/19	4320	1404	700	600	210	160
8/08	3610	1310	650	500	172	160	9/20	4456	1464	632	460	210	156
8/09	3350	1296	692	456	180	165	9/21						
8/10	3510	1361	615	458	185	165	9/22	4610	1510	696	460	220	151
8/11	3710	1341	605	465	188	170	9/23						
8/12	3810	1352	587	478	185	175	9/24	4810	1510	620	468	210	160
8/13							9/25						
8/14							9/26	4920	1620		451		144
8/15	3810	1345	615	510	210	170	9/27						
8/16	3610	1351	590	500	215	180	9/28	4710	1650		452		145
8/17	3640	1352	584	487	221	165	9/29						
8/18	3540	1340	575	485	221	170	9/30	4700	1660		435		160
8/19	3410	1370	585	485	261	180	10/01	4800	1560		430		120
8/20							10/02						
8/21							10/03	5000	1550		445		136
8/22	3720	1390	610	500	245	200	10/04						
8/23	3610	1391	620	495	241	190	10/05	5212	1540		481		156
8/24	3515	1384	633	485	252	195	10/06						
8/25	3611	1395	645	485	254	185	10/07						
8/26	3410	1384	637	541	261	185	10/08	5410	1520	610	435	210	165
8/27							10/09						
8/28							10/10	5210	1530	642	445	225	151
8/29	3810	1399	650	520	258	185							
8/30	3880	1412	641	580	253	185							
8/31	3900	1422	620	575	253	170							

ตารางที่ 56 ม ตะกอนแขวนลอยจากเครื่องกรองไร้ออกซิเจนที่มีชั้นตัวกลางเติมถัง
ภายใต้การทำงานที่ระดับออกซิเจนไหลตลอดถึง 5 ก.ก.ซีโอที/ม³-วัน

SOLID 100% MEDIA L= 5 KG/CUM-DAY

DATE	.15K	.30K	.45K	.75K	1.05K	1.20K	DATE	.15K	.30K	.45K	.75K	1.05K	1.20K
02/13	20400	10320		1830		950	03/16	20400	10400		2570		1130
02/14							03/17						
02/15	26000	11200		1970		1010	03/18						
02/16							03/19	19700	12100	2940	2520	1010	910
02/17	24500	12470		2100		1080	03/20						
02/18							03/21	18700	11900	2990	2330	1410	930
02/19							03/22						
02/20	25100	12100		2170		980	03/23	18250	12000	2740	2190	1560	1050
02/21							03/24						
02/22	24100	12000		2080		990	03/25						
02/23							03/26	18100	11000	3170	2670	1720	1080
02/24	22100	11500		2150		1100	03/27						
02/25							03/28	21300	12020	3850	2350	1510	1150
02/26							03/29						
02/27	23100	12100		2630		1270	03/30	18600	12000	3950	2860	1460	1080
02/28							03/31						
02/29							04/01						
03/01	24100	12500		3410		900	04/02	18800	11500	3840	2320	1430	860
03/02							04/03						
03/03	24100	12200		3020		890	04/04	18000	11560	4570	2320	1580	900
03/04							04/05						
03/05	23800	12100		3690		900	04/06	20100	12000	4870	2150	1170	860
03/06							04/07						
03/07	24100	10400		3460		870	04/08	21200	13280	4860	2700	1060	900
03/08							04/09						
03/09	18550	10250		3080		820	04/10	24100	12020	4700	2700	1305	860
03/10							04/11						
03/11	19500	10820		2760		1120	04/12	25500	12720	3960	2470	985	750
03/12							04/13						
03/13							04/14	26500	12360	5050	2380	970	724
03/14	21250	10620		2560		970							
03/15													



ตารางที่ 58 ผ ตะกอนเวลาไหล จากเครื่องกรองไร้ออกซิเจนที่มีปั่นตัวกลาง เริ่มที่
ภายใต้การทำงานที่ระดับออกซิเจนไหลลงถึง 1 ก.ก.ซิโอดี/ม³-วัน

VSS 100% MEDIA L= 1 KG/CUM-DAY

DATE	.15K	.30K	.45K	.75K	1.05K	1.20K	DATE	.15K	.30K	.45K	.75K	1.05K	1.20K
7/20	1898	1010	346	205	105	92	9/01						
7/21							9/02	1920	1180	468	280	130	109
7/22	2054	1012	355	215	106	85	9/03						
7/23							9/04						
7/24							9/05	2052	1155	483	309	148	110
7/25	2028	1060	380	220	90	72	9/06						
7/26							9/07	2077	1120	460	314	160	105
7/27	2204	1040	390	210	106	85	9/08						
7/28							9/09	2137	1176	520	296	183	90
7/29	2000	1050	350	236	110	88	9/10						
7/30							9/11						
7/31							9/12	2120	1170	507	357	190	102
8/01	1980	1050	378	218	132	60	9/13						
8/02							9/14	1978	1190	526	372	184	88
8/03	1859	1040	400	220	110	60	9/15						
8/04							9/16	1966	1176	538	388	160	84
8/05	2184	1020	418	240	106	65	9/17						
8/06							9/18						
8/07							9/19	1980	1218	554	359	152	84
8/08	2240	1054	432	265	142	68	9/20						
8/09							9/21						
8/10	2146	1028	450	257	106	70	9/22	1954	1225	530	346	167	93
8/11							9/23						
8/12	2016	1040	440	260	142	65	9/24	2112	1232	550	348	160	98
8/13							9/25						
8/14							9/26	2272	1228		396		95
8/15	2042	1087	472	274	160	85	9/27						
8/16							9/28	2356	1200		378		90
8/17	2128	1090	483	280	150	75	9/29						
8/18							9/30	2450	1240		360		93
8/19	2150	1105	495	310	146	80	10/01	2665	1260		352		97
8/20							10/02						
8/21							10/03	2735	1268		370		105
8/22	2236	1128	457	255	142	88	10/04						
8/23							10/05	2710	1275		350		88
8/24	2240	1130	474	268	150	93	10/06						
8/25							10/07						
8/26							10/08	2800	1290	526	350	152	97
8/27	2220	1124	482	311	155	95	10/09						
8/28							10/10	2820	1272	540	360	154	101
8/29	2150	1154	475	263	160	103							
8/30													
8/31	2200	1123	420	272	152	110							

ตารางที่ 59 ผ ตะกอนโวลูไทล์ จากเครื่องกรองไร้ออกซิเจนที่มีชั้นตัวกลางครึ่งถัง
ภายใต้การทำงานที่ระดับออร์แกนิกโหลดตั้ง 1 ก.ก.ซีโอดี/ม³-วัน

VSS 50% MEDIA L= 1KG/CUM-DAY

DATE	.15M	.30M	.45M	.75M	1.05M	1.20M	DATE	.15M	.30M	.45M	.75M	1.05M	1.20M
7/20	2950	924	455	320	94	111	9/01						
7/21							9/02	2744	1006	437	400	187	158
7/22	2300	938	483	386	131	140	9/03						
7/23							9/04						
7/24							9/05	2706	990	450	378	184	185
7/25	2515	930	480	416	135	153	9/06						
7/26							9/07	2948	940	474	380	180	160
7/27	2338	972	450	400	135	160	9/08						
7/28							9/09	2870	966	480	416	200	145
7/29	2505	978	494	421	158	147	9/10						
7/30							9/11						
7/31							9/12	2500	944	460	410	194	158
8/01	2410	1030	513	416	153	130	9/13						
8/02							9/14	2728	960	473	412	205	154
8/03	2508	1070	522	390	147	120	9/15						
8/04							9/16	2720	940	494	420	187	132
8/05	2456	1030	496	352	150	120	9/17						
8/06							9/18						
8/07							9/19	2937	1010	525	480	180	140
8/08	2410	943	481	405	142	140	9/20						
8/09							9/21						
8/10	2133	980	461	366	150	148	9/22	2950	1087	528	368	190	134
8/11							9/23						
8/12	2410	946	440	380	157	150	9/24	2980	1112 ^x	520	384	195	140 ^x
8/13							9/25						
8/14							9/26	3126	1130		400		125
8/15	2422	968	461	408	178	150	9/27						
8/16							9/28	3325	1155		410		130
8/17	2414	970	436	390	188	140	9/29						
8/18							9/30	3100	1160		410		136
8/19	2810	970	440	390	219	162	10/01	3264	1092		344		105
8/20							10/02						
8/21							10/03	3400	1085		356		119
8/22	2710	1000	460	400	206	170	10/04						
8/23							10/05	3587	1088	457	385	178	135
8/24	2771	996	480	388	212	172	10/06						
8/25							10/07						
8/26	2810	950	490	432	216	160	10/08	3671	1064	480	348	180	140
8/27							10/09						
8/28							10/10	3542	1160	470	360	182	130
8/29	2680	979	487	416	211	162							
8/30													
8/31	2710	1100	480	460	210	150							

ตารางที่ 63 ผ ตะกอนเวลาไหลจากเครื่องกรองไร้ออกซิเจนที่มีชั้นตัวกลางครึ่งถังลอย
ภายใต้การทำงานที่ระดับออกซิเจนไหลคงที่ 5 ก.ก.ซีไอดี/ม³-วัน

VSS 50% MEDIA L= 5KG/CUK-DAY

DATE	.15K	.30K	.45K	.75K	1.05K	1.20K	DATE	.15K	.30K	.45K	.75K	1.05K	1.20K
02/13	23700	19600		610		550	03/16	31880	25600		650		310
02/14							03/17						
02/15	25360	20800		800		670	03/18						
02/16							03/19	31520	24650	2220	750	450	310
02/17	24000	19800		730		530	03/20						
02/18							03/21	28800	21200	2090	720	800	320
02/19							03/22						
02/20	28000	22170		950		450	03/23	27100	21400	1950	490	400	300
02/21							03/24						
02/22	29500	22700		910		700	03/25						
02/23							03/26	32100	22800	1900	780	590	360
02/24	27000	21140		910		615	03/27						
02/25							03/28	31200	21400	1100	660	350	310
02/26							03/29						
02/27	28400	22400		870		790	03/30	34500	22400	1436	620	590	420
02/28							03/31						
02/29							04/01						
03/01	31000	21500		1010		650	04/02	32470	23400	1520	970	500	270
03/02							04/03						
03/03	31500	23680		1000		670	04/04	35100	23450	1920	1000	640	450
03/04							04/05						
03/05	32360	23830		1050		670	04/06	34400	21650	1920	800	640	320
03/06							04/07						
03/07	34560	26000		960		540	04/08	32900	21800	1704	750	510	230
03/08							04/09						
03/09	35000	25200		870		610	04/10	32500	21950	2735	720	540	280
03/10							04/11						
03/11							04/12	33100	23150	2710	890	520	370
03/12	34100	25120		830		550	04/13						
03/13							04/14	32610	22100	2925	1000	550	450
03/14	35600	25200		1050		420							
03/15													

ศูนย์วิทยทรัพยากร
จุฬาลงกรณ์มหาวิทยาลัย

ประวัติผู้เขียน

ชื่อ นาย เรืองชัย เลิศกภาพร
เกิด 7 เมษายน 2500 กรุงเทพมหานคร
การศึกษา วิศวกรรมศาสตรบัณฑิต (โยธา) มหาวิทยาลัยขอนแก่น
ที่ทำงาน ศาลาว่าการกรุงเทพมหานคร
ที่อยู่ 200/39 เมืองทองนิเวศ 2 ถนนพัฒนาการ เขตพระโขนง กทม.



ศูนย์วิทยทรัพยากร
จุฬาลงกรณ์มหาวิทยาลัย