



## REFERENCES

1. Hovanessian, S.A., and Stout, T.M., "Optimum Fuel Allocation in Power Plants", Trans. Inst. Electron. Electl Engrs Pwr. Apparatus. System 82.,pp.329-335, 1963.
2. Himmelblau, D.M., "Process Optimization by Search Techniques", I & EC Process Design and Development, vol.2, no.4, October, pp. 296-300, 1963.
3. Sauer, R.N., "Computer Point the Way to More profit", Hydrocarbon Processing & Petroleum Refiner", vol.43, no.2, February, pp. 84-92, 1964.
4. Payne, R.E., "Alkylation - What You Should Know About This Process.", Petroleum Refiner (now Hydrocarbon Processing & Petroleum Refiner), vol 37, no.9, September, pp.316-329, 1958.
5. Dibella, C.W., and Steven, W.F., "Process Optimization by Non-linear Programming", I & EC Process Design and Development, vol.4, no.1, January, pp.16-20, 1965.
6. Umeda, T., "Optimal Design of An Adsorber-Stripper System", I & EC Process Design and Development, vol.8, no.3, July, pp.308-317, 1969.
7. Gottfried, B.S., Bruggink, P.R., and Harwood, E.R., "Chemical Process Optimization Using Penalty Functions", Ind. Eng. Chem. Process Des. Develop., vol.9, no.4, pp.581-587, 1970.
8. Umeda, T., "A Modified Complex Method for Optimization", Ind. Eng. Chem. Process Des Develop., vol.10, no.2, pp.229-236, 1971.
9. Adelman, A., and Stevens, W.F., "Process Optimization by 'the "Complex" Method" AIChE Journal, vol. 18, no.1, January, pp.20-24, 1972.
10. Friedman, P., and Pinder, K.L., "Optimization of a Simulation Model of a Chemical Plant", Ind. Eng. Chem. Process Des. Develop., vol.11, no.4, 1972.

11. Luss, R., and Jaakola, T.H., "Optimization of Nonlinear Functions Subject to Equality Constraints. Judicious Use of Elementary Calculus and Random Numbers", *Ind. Eng. Chem. Process Des. Develop.*, vol.12, no.3, pp.380-383, 1973.
12. Heukroth, M.W., Gaddy, J.L., and Gaines, L.D., "An examination of the Adaptive Random Search Technique", *AIChE Journal*, vol.22, no.4, pp.744-750, 1976.
13. Goulcher, R. and Casares Long, J.J., "The Solution of Steady-State Chemical Engineering Optimization Problems Using a Random-Search Algorithm", *Com. and Chem. Eng.*, vol.2, pp.33-36, 1978.
14. Biegler, L.T., and Hughes, R.R., "Process Optimization : A Comparative Case Study", *Com. and Chem. Eng.*, vol.7, no.5, pp. 645-661, 1983.
15. Hoerner, D.R., and Crosser, O.K., "Application of Generalized Geometric Programming in Preliminary Plant Design", *Ind. Eng. Chem. Process Des. Dev.*, vol.20, no.2, pp.210-219, 1981.
16. Rangaiah, G.P., "Studies in Constrained Optimization of Chemical Process Problems", *Com. and Chem. Eng.*, vol.9, no.4, pp.395-404, 1985.
17. Vinante, C., and Valladares, E., "Application of the Method of Multipliers to the Optimization of Chemical Process", *Com. and Chem. Eng.*, vol.9, no.1, pp.83-87, 1985.
18. Papoulias, S.A., and Grossmann, I.E., "A Structural Optimization Approach in Process Synthesis - I,II,III", *Com. and Chem. Eng.*, vol.7, no.6, pp.695-734, 1983.
19. Stadtherr, M.A., Cera, G.D., and Alkire, R.C., "Optimization of and Electrolytic Cell With Use of a GRG Algorithm", *Com. and chem. Eng.*, vol.7, no.1, pp.27-34, 1983.
20. Grauer, M., Gruhn, G., and Pollmer, L., "Optimization of a Complex by a GRG Algorithm", vol.3, pp.597-602. 1979.
21. Lasdon, L.S. and Waren, A.D., "Large Scale Nonlinear Programming", *Com, and Chem. Eng.*, vol.7, no.5. pp.595-604, 1983.

22. Shreve, R.N., and Brink, J.A., Chemical Process Industries, McGraw-Hill Kogakusha, LTD., 1977.
23. Himmelblau, D.M., Applied Nonlinear Programming, McGraw-Hill, New York, 1972.
24. Keyes, M.A., and Kaya, A., "Plant energy Management by Multilevel Coordination", Proc. of IFAC PRP/S Conference, Antwerp, Belgium, 1983.
25. Westerberg, A., and Debrose, C., "An Optimization algorithm for structured design systems", AICHE, 19(2), pp.335-343, 1973.
26. Westerberg, A., and Berna, J.J., "A new Approach to Optimization of Chemical Process", AICHE, 20, no.1, pp.37-43, 1980.
27. Luss. R., and Jaakola, T.H., "Optimization by Direct Search and Systematic Reduction of the Sizes of Search Region", AICHE, vol.19, no.4, pp.760-766, 1973.

APPENDICES

## APPENDIX A

## DETAILS OF SYNTHETIC FIBRE PLANT COGENERATION MODEL

## 1. objective function

The objective function to be minimized represents the total net cost required to cogenerate process steam and electricity, as follows.

$$\begin{aligned}
 (\text{Total net cost}) &= (\text{cost of make - up boiler feed water}) \\
 &+ (\text{cost of fuel oil consumption}) \\
 &+ (\text{cost of purchased electricity}) \\
 &+ (\text{cost of blow steam}) \\
 &+ (\text{income from steam sale})
 \end{aligned}$$

In mathematical symbols, the objective function becomes

$$PHI = CW * x(7) + CF * x(6) + CE * x(4) + CB * x(3) - CS * FS$$

1.1 cost of fuel oil consumption

Cost of fuel oil consumption mainly depends on the amount of superheated steam produced in the boiler.

$$\text{Cost of fuel oil consumption} = CF * x(6)$$

when CF is the unit price of fuel oil 2500 RW 1 which is 2.62 Baht/litre (May, 1987) and x(6) is the rate of fuel oil consumption by mains boiler (1/h)

### 1.2 cost of purchased electricity

The electricity cost consists of the following components

- a) Demand \* 170 Bath/KW
- b) Energy \* 1.22 Bath/KWH
- c) Discount 4%
- d) Bonus = Demand \* 90 Bath/KW (1- 0.85/PO)

when - Demand here is the maximum value of purchased electricity in that month

$$\text{Demand} = x(4)/0.85$$

- 0.85 is the desired power factor ,

- PO is the actual power factor

- Bonus is a discount given by the Provincial Electric Authority. However, it will be negligible here.

Therefore, the cost of purchased electricity

$$\begin{aligned} &= (\text{demand} * 170 + \text{energy} * 1.22) * 0.96 \\ &= [x(4)/0.85] * 170 + x(4) * 30 * 24 * 1.22 * 0.96 \\ &= 1035.26 * x(4) \end{aligned}$$

Since the above is electricity purchase cost per month.

$$\begin{aligned} \text{So, electricity purchase cost per hour} &= 1035.26 * x(4) / (30 * 24) \\ &= 1.438 * x(4) \end{aligned}$$

### 1.3 costs of steam

Steam of a different pressure is assigned a different associated cost because its energy content (enthalpy) and the work content (exergy) are not the same.

### 1.3.1 cost of 100K superheated steam

From the steam-oil ratio relation based on actual boiler operation, 3590 l/h of fuel oil is consumed to generate 50 T/H of steam, whereas 5330 l/h of fuel oil generates 75 T/h of steam. So on the average, 4460 l/h of fuel oil is required to produce 62.5T/h of steam. And the average steam oil ratio is 0.014 T/l fuel oil.

Since the fuel cost, CF, is 2.62 Baht/l, the cost of 100K superheated steam =  $2.62/0.014 = 186.97$  Baht/T

### 1.3.2 Cost of 17K steam

The definition of exergy is

$$e = (h - h_o) - T_o (s - s_o) \quad \text{---(A-1)}$$

$e$  - exergy of steam (kcal/kg)

$h$  - enthalpy of steam (kcal/Kg)

$h_o$  - enthalpy of steam at dead state

$t_o$  - dead state temperature  $25^{\circ}\text{C}$  or  $298^{\circ}\text{K}$

$s$  - entropy of steam ( $\text{kcal}/\text{kg}^{\circ}\text{K}$ )

$s_o$  - entropy of steam at dead state

The properties of steam are taken from the steam table

$$h (17\text{K}, 240^{\circ}\text{C}) = 692.46 \text{ (kcal/kg)}$$

$$h (3\text{K}, 180^{\circ}\text{C}) = 656.52 \text{ (kcal/kg)}$$

$$h (100\text{K}, 500^{\circ}\text{C}) = 806.2 \text{ (kcal/kg)}$$

$$h_o = 25.07 \text{ (kcal/kg)}$$

$$s_o = 0.087 \text{ (kcal/kg)}$$

$$s (17\text{K}, 240^{\circ}\text{C}) = 1.59 \text{ (kcal}/\text{kg}^{\circ}\text{K)}$$

$$s (3\text{K}, 180^{\circ}\text{C}) = 1.72 \text{ (kcal}/\text{kg}^{\circ}\text{K)}$$

$$s (100\text{K}, 500^{\circ}\text{C}) = 1.586 \text{ (kcal}/\text{kg}^{\circ}\text{K)}$$

Next the above values are substituted into equation (A-1) to obtain the exergy of steam at each condition.

$$\begin{aligned} e(100\text{K}, 500^{\circ}\text{C}) &= (806.2 - 25.07) - 298(1.586 - 0.087) \\ &= 781.13 - 446.46 \\ &= 334.67 \text{ kcal/kg} \end{aligned}$$

$$\begin{aligned} e(17\text{K}, 240^{\circ}\text{C}) &= (692.46 - 25.07) - 298(1.59 - 0.087) \\ &= 667.79 - 447.6 \\ &= 219.79 \text{ kcal/kg} \end{aligned}$$

$$\begin{aligned} e(3\text{K}, 180^{\circ}\text{C}) &= (656.52 - 25.07) - 298(1.72 - 0.087) \\ &= 631.45 - 488.42 \\ &= 143.03 \text{ kcal/kg} \end{aligned}$$

$$\begin{aligned} \text{Cost of 17K steam} &= [e(17\text{K}, 240^{\circ}\text{C})/e(100\text{K}, 500^{\circ}\text{C})] \\ &\quad \times (\text{Cost of 100K steam}) \\ &= (219.79/334.67) (\text{CF}/0.014) \\ &= 46.90 \text{ CF or 122.90 Baht/T} \end{aligned}$$

### 1.3.3 Cost of 3K steam

$$\begin{aligned} \text{Similarly, cost of 3K steam} &= [e(3\text{K}, 180^{\circ}\text{C})/e(100\text{K}, 500^{\circ}\text{C})] \\ &\quad \times (\text{Cost of 100K steam}) \\ &= 143.03/334.67 (\text{CF}/0.014) \\ &= 30.52 \text{ CF or 79.98 Baht/T} \end{aligned}$$

### 1.4 Cost of make - up boiler feed water

By experience, the cost of make - up boiler feed water is taken as 10 Baht/T

### 1.5 Sale price of 17K steam

The steam for sale was 17K steam. Here its sale price was taken to be the same as the production cost of 17K steam.



## 2. Inequality constraints

In this section the physical meaning of each inequality constraint is explained and the equation form is shown.

2.1 Bustie electricity must be less than purchased electricity

$$x(5) < x(4)$$

$$g(1) = x(5) - x(4) < 0$$

2.2 100K by - passed steam must be greater than or equal to 0.5 T/h

$$g(2) = x(8) + 0.5 - ((EN1 - EN2) / (EN1 - EN5)) * (X(9) + RC * x(1)) < 0$$

2.3 The 17K steam to the boiler burners must be less than  $0.04 * RC * x(1)$  by experience

$$g(3) = 0.96 * RC * x(1) - x(11) < 0$$

2.4 The 17K steam to the burners must be greater than 0.010 T/h

$$g(4) = 0.10 + x(11) - RC * x(1) < 0$$

2.5 Temperature of the outlet steam from the high pressure heater must be higher than  $140^{\circ}\text{C}$

$$g(5) = 140 - (((CON + x(7) + X(11) + TODT * EN5) - ((CON + x(7)) * x(12) * 1000 + TODT * EN4)) / x(11)) * 1.0E-3 < 0$$

The second term of constraint  $g(5)$  was the temperature of the outlet steam from the high pressure heater. Details of the relation has been shown in the example of calculation in Appindex C.

2.6 Temperature of the outler steam from the high pressure heater must be less than  $170^{\circ}\text{C}$ .

$$g(6) = -170 + (((CON + x(7) + x(11) + TODT * EN5) - ((CON + x(7)) * x(12) * 1000 + TODT * EN4)) / x(11)) * 1.0E-3 < 0$$

### 3. Equality constraints

First the nomenclature used in the derivation of the model will be shown here.

#### Abbreviation of Words

HPH - High Pressure Heater

BFP - Boiler Feed Pump

DT - Deaeration Tank

DFP - Deaerator Feed Pump

PWT - Purified Water Tank (This tank contained with the make-up boiler feed water)

FOH - Fuel oil Heater

APH - Air Preheater

#### Parameters

TOAT - 17K atomizing steam to boiler (for atomizing fuel oil)  
(T/h)

TODT - 3K steam to deaeration tank (T/h)

TOAPH - 3K steam to air preheater (T/h)

TOFOH - 3K steam to fuel oil heater (T/h)

BP1 - 100K steam by - passed from boiler to 17K steam line  
(T/h)

BP2 - 100K steam by - passed from boiler to 3K steam line  
(T/h)

D1 - Desuperheating water for mixing with by-passed steam  
to 17K steam line (T/h)

D2 - Desuperheating water for mixing with by-passed  
steam to 3K steam line (T/h)

- FDE1 - Desuperheating water for 17K extracted steam  
 $(FDE1=BP1+D1)(T/h)$
- FDE2 - Desuperheating water fo 3K extracted steam  
 $(FDE2=BP2+D2)(T/h)$
- BB - blow down from boiler bottom (T/h)

### Constants

- TSUP - Temperature of superheated steam produced from boiler. In this work TSUP is  $500^{\circ}\text{C}$
- EN1 - Enthalpy of 17K steam extracted from turbogenerator  
 $EN1 = 437.714 * TSUP + 513866$   
 $= 732723 \text{ kcal/T}$
- EN2 - Enthalpy of 17K saturated steam (after desuperheating)  
 $EN2 = 691000 \text{ kcal/T}$
- EN3 - Enthalpy of 13K steam exhausted from turbogenerator  
 $EN3 = 727.5 * TSUP + 326323$   
 $= 690073 \text{ kcal/T}$
- EN4 - Enthalpy of 3K saturated steam (after desuperheating)  
 $EN4 = 675000 \text{ kcal/T}$
- EN5 - Enthalpy of desuperheating water  
 $EN5 = 142,000 \text{ kcal/T}$
- EN6 - Enthalpy of superheated 100K steam ( $500^{\circ}\text{C}$ ) from boiler  
 $EN6 = 700 * TSUP + 456643$   
 $= 806643 \text{ kcal/T}$
- RC - Fixed fraction of 17K steam sent back to boiler as house service. By experiment RC is 0.092

- RD - Fixed fraction of 3K steam sent back to boiler as house service. By experiment RD was 0.12.
- RE - Correction factor of 3K house service steam. By experiment RE is 1.0.
- CPOIL - Specific heat of fuel oil.  
CPOIL = 0.538 kcal/kg<sup>°C</sup>
- CPAIR - Specific of air.  
CPAIR = 0.237 kcal/kg<sup>°C</sup>
- DENAIR - Density of air  
DENAIR = 1.29 kg/m<sup>3</sup>
- DENOIL - Density of fuel oil  
DENOIL = 0.9465 kg/l

### 3.1 Energy balance around the turbogenerator

$$\begin{aligned} \text{Define } A1 &= 1 - RC (EN2-EN5)/(EN1-EN5) \\ &\quad - RD (EN4-EN5)/(EN3-EN5) \\ A2 &= [EN6-RC.EN1(EN2-EN5)/(EN1-EN5) \\ &\quad - RD.EN3(EN2-EN5)/(EN3-EN5)]/A1 \end{aligned}$$

From the law of energy conservation.

(heat input of steam from boiler)-(heat output of 17K extracted steam)-(heat output of 3K exhaust steam)-(heat output of blow steam)-(work or electricity generated) = 0

$$\begin{aligned} h(1) \cdot &= (x(2)*860)*(1(.1699*(x(2)**.195)))*(1/A2-EN3)) \\ &\quad -((A2-EN1)/(A2-EN3))*((EN2-EN5)/(EN1-EN5))*x(9) \\ &\quad -((EN4-EN5)/(EN3-EN5))*(x(10)+2.3*RE)-X(3) = 0 \end{aligned}$$

The derivation of the equation is made by the factory.

### 3.2 Electricity balance

(Purchased electricity) + (generated electricity) =  
(Total electricity required by process)

$$x(4) + x(2) = AB$$

$$h(2) = x(4) + x(2) - AB = 0$$

### 3.3 Fuel oil consumption and steam produced

Fuel oil consumption depends on steam production according to the following empirical equation

$$x(6) = (x(1) * 1000) / (13.9198 + (x(1) - 45) * 5E-03)$$

$$h(3) = x(6) - (x(1) * 1000 / (13.9198 + (x(1) - 45) * 5E-03)) = 0$$

### 3.4 Overall steam mass balance around big loop

(100K steam generated by boiler) + (desuperheating water)  
= (17K steam sent to process plus 17K steam for  
sale) + (3K steam sent to process) + (3K steam blow off) + (17K steam  
house service) + (3K steam house service)

$$h(4) = x(9) + x(10) + x(3) + RC * x(1) + (RD * x(1) + 2.3 * RE) \\ - x(1) - x(8) = 0$$

### 3.5 Mass balance (Steam and Water) around HPH and DT

(Steam to HPH) + (3K steam house service) + (make-up feed  
water) + (Recovered condensate) = (boiler feed water) + (desuperheating  
water) + (TOFOH) + (TOAPH)

TOFOH and TOAPH are calculated simply from heat balances,  
as follows.

## Calculation of TOFOH

3K steam is used to heat fuel oil from 60°C to 90°C and it becomes condensate at 100°C.

$$\text{TOFOH} * (\text{EN4} - 0.1 * 10^6) = \text{CPOIL} * (\Delta T)_{\text{oil}} (Q_{\text{oil}})$$

$$\text{TOFOH} * (\text{EN4} - 0.1 * 10^6) = \text{CPOIL} * (90-60) * x(6) * \text{DENOIL}$$

$$\text{TOFOH} = \text{CPOIL} * (90-60) * x(6) * \text{DENOIL} / (\text{EN4} - 100,000)$$

## Calculation of TOAPH

3K steam is used to preheat combustion air from 35°C to 122°C and it becomes condensate at 100°C

$$\text{TOAPH} * \text{EN4} = \text{CPAIR} (\Delta T)_{\text{air}} (Q_{\text{air}})$$

$$Q_{\text{air}} = m \cdot Q_{\text{air theory}}$$

In this case assume that m is 1.3.

$$\begin{aligned} Q_{\text{air theory}} &= \text{function (heating value of oil) (see Boie's formula)} \\ &= 12.38(\text{HL} - 1,100) / 1,000 \quad \text{m}^3/\text{kg}_{\text{oil}} \end{aligned}$$

In this case HL was 9,300(kcal/kg)

$$\begin{aligned} Q_{\text{air theory}} &= 12.38(9300 - 1100) / 1,000 \\ &= 10.15 \quad \text{m}^3/\text{kg}_{\text{oil}} \end{aligned}$$

$$\begin{aligned} Q_{\text{air}} &= 1.3 Q_{\text{air theory}} \\ &= 1.3 * 10.15 \\ &= 13.19 \quad \text{m}^3/\text{kg}_{\text{oil}} \end{aligned}$$

$$\begin{aligned} \text{TOAPH} * \text{EN4} &= \text{CPAIR} (\Delta T)_{\text{air}} Q_{\text{air}} \\ &= \text{CPAIR} * (122-35) * 13.19 * \text{DENAIR} * x(6) * \text{DENOIL} \end{aligned}$$

$$\text{TOAPH} = \text{CPAIR} * (122-35) * 13.19 * \text{DENAIR} * x(6) * \text{DENOIL} / \text{EN4}$$

$$\begin{aligned}
 h(5) &= x(11) + (RD * x(1) + 2.3 * RE) + x(7) + CON \\
 &- 1.01 * x(1) - x(8) - (CPOIL * (90-60) * x(6) * DENOIL) / \\
 &(EN4-100,000) - CPAIR * (122-35) * 13.19 * DENAIR * \\
 &x(6) * DENOIL/EN4 = 0
 \end{aligned}$$

### 3.6 Overall water balance

(Make-up feed water)+(Condensate water)=(boiler feed water)  
 =(steam to air preheater) + (steam to fuel oil heater)  
 +(steam fo atomizing fuel oil + Bottom blow down from  
 boiler)+(17K steam sent to process plus steam for sale) + (3K steam  
 sent to process) + (3K steam blow off to atmosphere)

$$\begin{aligned}
 h(6) &= CPAIR * (122-35) * 13.19 * DENAIR * x(6) * \\
 &DENOIL/EN4 + (CPOIL * (90-60) * x(6) DENOIL)/(EN4-100,000) + RC * \\
 &x(1) - x(11) + 0.01 * x(1) + x(9) + x(10) + x(3) - x(7) - CON = 0
 \end{aligned}$$

### 3.7 Process Steam Requirement

(17K steam sent to process plus steam for sale) + (3K steam  
 sent to process)

=(Total repuirement of steam by proces plus steam for sale)

$$h(7) = x(9) + x(10) - PTOTAL = 0$$

### 3.8 Heat balance around HPH, BFP and DT

(heat from TOHPH) + (heat from TODT) + (heat from PWT) =  
(heat of boiler feed water)

$$\begin{aligned}
 h(8) = & (x(11) * EN2 + (RD * x(1) + 2.3 * RE) * EN4 \\
 & - EN4 * (CPOIL * (90-60) * x(6) * DENOIL) / (EN4 - 100,000) \\
 & - CPAIR * (122-35) * 13.19 * DENAIR * x(6) * DENOIL \\
 & + (CON + x(7) * x(12) * 1000 - 1.01 * x(1) * 0.19E6 - x(8) * \\
 & EN5) * 1.0E - 07 = 0
 \end{aligned}$$

### 3.9 Heat balance around PWT and DFP

(heat of condensate) + (heat from pure water tank) = (heat out)

$$\begin{aligned}
 h(9) = & (CON * x(13) * 1000 + x(7) * 0.03 E6 - (CON + \\
 & x(7)) * x(12) * 1000) * 1.0E - 07 = 0
 \end{aligned}$$



## APPENDIX B

DETAIL OF UPPER AND LOWER BOUND OF VARIABLE FOR COGENERATION  
MODEL OF SYNTHETIC FIBRE PLANT

The upper bounds (UB) and lower bounds (LB) of the 13 variables in the present cogeneration model of the fibre synthetic plant are shown and explained here.

	Variable	Physical Meaning	Remark
x(1)	UB = 80.0	Maximum boiler load is 80 T/h	
	LB = 50.0	The minimum boiler load is set at 50.0 T/h in order to maintain good boiler efficiency.	
x(2)	UB = 9,000.0	Maximum electricity generation capacity of turbogenerator is 9000.0 KW.	
	LB = 6,500	Minimum electricity generation capacity of turbogenerator is 6500.0 KW.	

	Variable	Physical Meaning	Remark
x(3)	UB = 20	The maximum allowable blow of 3K steam is 20.0 T/h.	
	LB = 0.0	3 K blow steam cannot be negative.	
x(4)	UB = 12000.0	Maximum electricity purchase is 12000.0 KW.	
	LB = 2010.0	Purchase electricity is set by contrat at 2010.0 KW.	
x(5)	UB = 12000.0	Maximum bus-tie electricity is 12000.0 KW.	
	LB = 0.0	Bus-tie electricity cannot be negative.	
x(6)	UB = 5675.0	Maximum fuel oil consumption is 5675.0 l/h (based on 80 T/h steam).	
	LB = 3580.0	Minimum fuel oil consumption is 3580.0 l/h (based on 50 T/h steam).	

	Variable	Physical Meaning	Remark
x(7)	UB = 80	Maximum make-up boiler feed water is 80 T/h. (no condensate recovery).	
	LB = 2.40	Minimum make-up boiler feed water is 3% of maximum boiler load (80 T/h), since it is necessary to carry out bottom blow.	
x(8)	UB = 3.45	Maximum desuperheating water is 3.45 T/h.	
	LB = 0.0	Desuperheating water must not be negative.	
x(9)	UB = 43.0	Maximum 17 K steam sent to process plus steam for sale must not exceed total requirement of process steam plus 17 K steam for sale (PTOTAL).	
	LB = 20.0	<p>Minimum 17 K steam sent to process plus steam for sale should not be less than P17K min (Minimum process requirement of 17 K steam plus steam for sale).</p> <p>This numerical value is for the standard case.</p>	

	Variable	Physical Meaning	Remark
x(10)	UB = 40.0	Maximum 3 K steam sent to process is 40.0 T/h. This is determined by the exhaust steam from the turbogenerator.	
	LB = 15.0	Minimum 3 K steam sent to process is 15.0 T/h. That is determined by the characteristics of turbogenerator.	
x(11)	UB = 7.36	Maximum 17 K steam to high pressure heater is 7.36 T/h.	
	LB = 5.24	Minimum 17 K steam to high pressure heater is 5.24 T/h.	
x(12)	UB = 90.0	Maximum temperature of mixing condensate and make-up water is 90°C	
	LB = 55.0	Minimum temperature of mixing condensate and make-up water is 55.0°C.	

Variable	Physical Meaning	Remark
x(13)	UB = 100.0 Maximum temperature of condensate in condensate tank at atmospheric pressure is 100°C.	
	LB = 60.0 Minimum temperature of condensate water in condensate tank is set at 60°C.	

## APPENDIX C

## DETAIL OF HEAT AND MASS BALANCES

To ensure the validity of the model, as well as the optimization results heat and mass balances were made each major piece of equipment or section in the fiber synthesis plant.

Appendix C indicates the pieces of equipment and sections where heat and mass balances were made, and show examples of calculation, including the computer print outs for both the starting point and optimal point.

The FORTRAN IV sub-program for carrying out these calculations is shown concluded in Appendix D as part of the listed subroutines.

#### 1. Location of heat and mass balances

Heat and mass balances were made around in following pieces of equipment and sections.

Balance 1. Around the section enclosed by loop P.1 in Fig.C.1

The input streams of the section enclosed by loop P.1 were steam from the boiler house and desuperheating water sent from the boiler feed water pump. The output streams were electricity generated, 3K blow steam, 17K steam supplied to the process plus 17K steam for sale, 3K steam supplied to the process, 17K steam for house service and 3K steam for house service.

Balance 2. Around the turbogenerator (enclosed by loop P.2)

The only input stream was super-heated steam from the boiler excluding the part which was by-passed for desuperheating. The output streams were 17K extract steam from the turbo generator, 3K exhaust steam, and 3K blow steam.

Balance 3. Around the desuperheater for 3K exhaust steam (enclosed by loop P.3)

Part of the exhaust steam from the turbogenerator was blown off to the atmosphere. Then it was desuperheated by mixing with hot water at  $142^{\circ}\text{C}$ , so that the temperature of the exhaust steam mixture was reduced from  $200^{\circ}\text{C}$  to be  $180^{\circ}\text{C}$ . After desuperheating the steam was sent to the process while a part of it was returned to the boiler as house service steam.

Balance 4. Around the desuperheater for 17K extract steam. (enclosed by loop P.4)

The extract steam from the turbogenerator was desuperheated by mixing with hot water at  $142^{\circ}\text{C}$ , so that the temperature of the extract steam was reduced from  $300^{\circ}\text{C}$  to be  $240^{\circ}\text{C}$ . After desuperheating the steam was sent to the process and also for sale, while a part of it was returned to the boiler as house service steam.

Balance 5. Around the section enclosed by loop P.5

The input streams to this section were steam from the boiler excluding the part which was by - passed for desuperheating, desuperheating water for the 17K extract steam and desuperheating water for the 3K exhaust steam. The output streams were electricity generated, 3K blow steam, 17K steam sent to the process plus steam for sale, 17K steam for house service, 3K steam sent to the process and 3K steam for house service.

Balance 6. Around the section enclosed by loop P.6

Part of the superheated steam from the boiler was by-passed and split. The pressures of the split streams were next reduced from  $100 \text{ kg/cm}^2$  to  $17 \text{ kg/cm}^2$  and  $3 \text{ kg/cm}^2$  while heat losses caused their temperatures to become  $190^\circ\text{C}$  and  $133^\circ\text{C}$ , respectively. Then the two streams were each mixed with a part of the mixture of condensate and make-up water to become desuperheating water for the 17K extract steam (FDE1) and for the 3K exhaust steam (FDE2), respectively.

Thus the input streams were 17K by-passed steam, 3K by-passed steam and a part of the mixture between condensate and make-up water.

The output streams were the two streams of desuperheating water for the 17K extract steam with enthalpy of about 142,000 kcal/T and for the 3K exhaust steam with enthalpy of about 142,000 kcal/T.

Balance 7. Around the section enclosed by loop P.7

As superheated steam from the boiler flowed to the turbogenerator, part of it was by-passed and its pressure was further reduced, as described in Balance 6 above.

Here the input stream was superheated steam from the boiler. The output streams were steam to the turbogenerator and by - passed steam.

Balance 8. Around the splitting point of 17K exhaust steam (enclosed by loop P.8)

At first the extract steam from the turbogenerator was desuperheated by mixing with 17K desuperheating water (FDE 1).



11

Then it was split into two streams, one flowing to house service and the other to the process.

Here the input stream was the desuperheated 17K steam. The output streams were 17K house service steam and 17K steam to the process plus steam for sale.

Balance 9. Around the splitting point of 3K steam (enclosed by loop P.9)

At first part of the 3K exhaust steam was blown off to the atmosphere. Then it was mixed with desuperheating water (FDE2) and split into two streams, one flowing to house service and the other to the process.

Here the input stream was the desuperheated 3K steam. The output streams were 3K house service steam and 3K steam to the process.

Balance 10. Around the blow-off point of 3K steam (enclosed by loop P.10)

A part of the 3K exhaust steam was blown off in order to adjust the rate of electricity generation at will even though the 3K process steam requirement was low.

Here the input stream was 3K exhaust steam from the turbogenerator and the output steams were 3K blow-off steam and 3K steam sent to the process.

Balance 11. Around the splitting point of 17K house service steam (enclosed by loop P.11)

Here the point the input stream was 17K house service steam. The output streams were 17K steam to the high pressure heater and 17K steam to boiler for atomizing fuel oil.

Balance 12. Around the splitting point of 3K house service (enclosed by loop P.12).

Here the input stream was 3K house service steam.

The output streams were 3K steam to the deaeration tank and 3K steam to the fuel oil heater and air preheater.

Balance 13. Around the splitting point of 3K heating steam (enclosed by loop P.13).

Here the input stream was 3K heating steam. The output streams were 3K steam to the fuel oil heater and 3K steam to the air preheater.

Balance 14. Around the section enclosed by loop P.14.

The section consisted of the high pressure feed water heater, boiler feed pump and deaeration tank. The input streams were 17K steam to the high pressure heater, 3K steam to the deaeration tank and boiler feed water from the deaeration feed pump. The output streams were boiler feed water and desuperheating water.

Balance 15. Around the boiler (enclosed by loop P.15)

Here the input streams were combustion air, fuel oil, 17K steam for atomizing fuel oil and boiler feed water. The output streams were 100K superheated steam from the boiler, hot flue gas exhausted air and bottom blow down from the boiler.

Balance 16. Around the deaeration tank (enclosed by loop P.16)

Here the input streams were 3K steam to the deaeration tank, incoming water from the deaeration feed pump and condensate from the high pressure heater. The output stream was deaerated water to the boiler feed pump.

Balance 17. Around the boiler feed pump (enclosed by loop P.17)

Here the input stream was deaerated water from the deaeration tank. The output streams were desuperheating water and boiler feed water.

Balance 18. Around the high pressure heater (enclosed by loop P.18)

Here the input streams were boiler feed water at about  $140^{\circ}\text{C}$  and 17K steam to the high pressure heater at about  $240^{\circ}\text{C}$ . The output streams were heated boiler feed water whose temperature was raised up to be about  $195^{\circ}\text{C}$  and condensate from the high pressure heater at about  $160^{\circ}\text{C}$ .

Balance 19. Around the fuel oil heater (enclosed by loop P.19)

Here the input streams were fuel oil and 3K heating steam to the fuel oil heater. The output streams were heated fuel oil and condensate.

Balance 20. Around the preheater (enclosed by loop P.20).

Here the input streams were cold combustion air and 3K heating steam to the air preheater.

The output streams were condensate and hot combustion air to the boiler.

Balance 21. Around the pure (boiler feed) water tank (enclosed by loop P.21).

Here the input streams were treated make-up water and returned condensate. The output stream was water to the deaeration tank.

At all the above balance points, the total amounts of mass in, mass out, heat in and heat out were calculated. Then relative errors of mass and heat balance were estimated as follows :

$$\text{Relative error} = \frac{[(\text{mass or heat in}) - (\text{mass or heat out})]}{(\text{mass or heat in})} \times 100 (\%)$$

Typical results of these heat and mass balances and their relative errors were shown in Appendix C.

## 2. Formulas and Examples of Calculation

The values of the variables at the starting point of the standard case were used here to demonstrate the calculations. This set of values represented the recent operating condition in the plant. When heat and mass balances were calculated, all the relative errors were found to be less than 1 percent.

### Balance 1. Around the section enclosed by loop P.1

mass in :

boiler load	7.13	T/h
desuperheating water	<u>2.04</u>	<u>T/h</u>
Total	<u>75.17</u>	<u>T/h</u>

mass out :

17K steam sent to the process plus steam for sale	20	T/h
3K steam sent to the process	23	T/h
3K house service steam	11.07	T/h
17K house service steam	6.72	T/h
3K blow-off steam	<u>14.38</u>	<u>T/h</u>
Total	<u>75.17</u>	<u>T/h</u>

heat in :

$$\text{heat of 100K steam from the boiler } 73.13 * 806,000 = 58.94 \times 10^6 \text{ kcal/h}$$

$$\text{heat of desuperheating water } 2.04 * 142,000 = \underline{0.29} \times \underline{10^6} \text{ kcal/h}$$

Total

$$\underline{59.23} \times \underline{10^6} \text{ kcal/h}$$

Let G be the amount of electricity

and RB be turbogenerator efficiency,

$$\text{then } RB = .1699 * (G^{**}.195)$$

In this case we have

$$G = 8536 \text{ KW and } RB = .993$$

$$\text{So heat of generated electricity} = (G \times 860) / RB$$

$$= 7.39 \text{ kcal/h}$$

heat out :

$$\text{heat of generated electricity} = 7.39 * 10^6 \text{ kcal/h}$$

$$\text{heat of 17K extract steam } 20 * 691,000 = 13.82 * 10^6 \text{ kcal/h}$$

$$\text{heat of 3K exhaust steam } 23 * 675,000 = 15.52 * 10^6 \text{ kcal/h}$$

$$\text{heat of 3K house service steam } 11.17 * 675,000 = 7.47 * 10^6 \text{ kcal/h}$$

$$\text{heat of 17K house service steam } 6.72 * 691,000 = 4.64 \text{ kcal/h}$$

$$\text{heat of 3K blow off steam, } 14.38 * 690,073 = \underline{9.92} \text{ kcal/h}$$

Total

$$\underline{58.76} \text{ kcal/h}$$

### Balance 2. Around the turbogenerator

Define TUR - inlet steam to the turbogenerator T/h

FEXT - extract steam from the turbogenerator T/h

FEXH - exhaust steam from the turbogenerator T/h

HS - 17K steam to the process plus steam for sale

T/h

LS - 3K steam to the process T/h

BS - 3K blow-off steam T/h

FDE1 - desuperheating steam for the extract steam T/h

FDE2 - desuperheating steam for the exhaust steam T/h

mass in :

$$\text{TUR} = \text{FEXT} + \text{FEXH}$$

$$\text{FEXT} = 17\text{k house service steam} + \text{HS} - \text{FDE1}$$

$$= 0.092 * 73.13 + 20 - 1.87$$

$$= 24.85 \text{ T/h}$$

$$\text{FEXH} = 3\text{K house service steam} + \text{LS} - \text{FDE2} + \text{BS}$$

$$= 11.07 + 23 - 0.92 + 14.38$$

$$= 47.53 \text{ T/h}$$

$$\text{TUR} = 24.85 + 47.53 \text{ T/h}$$

$$= 72.38 \text{ T/h}$$

$$\text{Total mass in} = 72.38 \text{ T/h}$$

mass out :

$$\text{Total mass out} = 72.38 \text{ T/h}$$

heat in :

$$\text{Total heat in} = \text{TUR} * \text{EN6}$$

$$= 72.38 * 806643$$

$$= 58.38 * 10^6 \text{ kcal/h}$$

heat out :

$$\text{Total heat out} = \text{FEXT} * \text{EN1} + \text{FEXH} * \text{EN3} + \text{heat of generated electricity}$$

$$= 24.85 * 732723 + 47.53 * 690773 + 7.41 * 10^6$$

$$= 18.2 * 10^6 + 32.8 * 10^6 + 7.41 * 10^6$$

$$= 58.41 * 10^6 \text{ kcal/h}$$

Balance 3. Around the desuperheater for 3K exhaust steam

mass in :

$$\begin{aligned}
 \text{FDE2} &= (\text{RD} * x(1) + 2.3 * \text{RE} + x(10) * (\text{EN3}-\text{EN4})/(\text{EN3}-\text{EN5})) \\
 &= (0.12 * 73.13 + 2.3 + 23) * (690073-675000)/ \\
 &\quad (690073-142000) \\
 &= 34.07 * 0.0275 \\
 &= 0.936 \text{ T/h}
 \end{aligned}$$

$$\begin{aligned}
 \text{Total mass in} &= \text{FEXH} - x(3) + \text{FDE2} \\
 &= 47.53 - 14.38 + 0.936 \\
 &= 34.086 \text{ T/h}
 \end{aligned}$$

mass out :

$$\begin{aligned}
 \text{Total mass out} &= x(10) + \text{RD} * x(1) + 2.3 * \text{RE} \\
 &= 23 + 0.12 * 73.13 + 2.3 \\
 &= 34.076 \text{ T/h}
 \end{aligned}$$

heat in :

$$\begin{aligned}
 \text{Total heat in} &= (\text{FEXH} - x(3)) * \text{EN3} + \text{FDE2} * \text{EN5} \\
 &= (47.53 - 14.38) * 690073 + 0.936 * 142000 \\
 &= 22.87 * 10^6 + 0.133 * 10^6 \text{ kcal/h} \\
 &= 23.0 * 10^6 \text{ kcal/h}
 \end{aligned}$$

heat out :

$$\begin{aligned}
 \text{Total heat out} &= \text{mass out} * \text{EN4} \\
 &= 34.076 * 675000 \text{ kcal/h} \\
 &= 23.0 * 10^6 \text{ kcal/h}
 \end{aligned}$$

Balance 4. Around the desuperheater for 17K extract steam.

mass in :

$$\begin{aligned} \text{FDE1} &= (\text{RC} * x(1) + x(9)) * (\text{EN1} - \text{EN2}) / (\text{EN1} - \text{EN5}) \\ &= (0.092 * 73.13 + 20) * (732723 - 691000) / \\ &\quad (732723 - 142000) \\ &= 26.72 * 0.07 \text{ T/h} \\ &= 1.88 \text{ T/h} \end{aligned}$$

$$\begin{aligned} \text{Total mass in} &= \text{FEXT} + \text{FDE1} \\ &= 24.85 + 1.88 \text{ T/h} \\ &= 26.73 \text{ T/h} \end{aligned}$$

mass out :

$$\begin{aligned} \text{Total mass out} &= \text{RC} * x(1) + x(9) \\ &= 0.092 * 73.13 + 20 \\ &= 6.728 + 20 \text{ T/h} \\ &= 26.728 \text{ T/h} \end{aligned}$$

heat in :

$$\begin{aligned} \text{Total heat in} &= \text{FEXT} * \text{EN1} + \text{FDE1} * \text{EN5} \\ &= 24.85 * 732723 + 1.88 * 142000 \\ &= 18.2 * 10^6 + 0.26 * 10^6 \text{ kcal/h} \\ &= 1.846 * 10^6 \text{ kcal/h} \end{aligned}$$

heat out :

$$\begin{aligned} \text{Total heat out} &= \text{mass out} * \text{EN2} \\ &= 26.728 * 691000 \\ &= 1.846 * 10^6 \text{ kcal/h} \end{aligned}$$



Balance 5. Around the section enclosed by loop P.5

mass in :

$$\begin{aligned}
 \text{Total mass in} &= \text{TUR} + \text{FDE1} + \text{FDE2} \\
 &= 72.38 + 1.88 + 0.936 \\
 &= 75.196 \text{ T/h}
 \end{aligned}$$

mass out :

$$\begin{aligned}
 \text{Total mass out} &= \text{RC} * x(1) + x(9) + \text{RD} * x(1) + 2.3 + x(3) \\
 &= 6.72 + 20 + 11.07 + 23 + 14.38 \\
 &= 75.17 \text{ T/h}
 \end{aligned}$$

heat in :

$$\begin{aligned}
 \text{Total heat in} &= \text{TUR} * \text{EN6} + \text{FDE1} * \text{ENR} + \text{FDE2} * \text{EN5} \\
 &= 72.38 * 806643 + 1.88 * 142000 + 0.936 * 142000 \\
 &= 58.38 * 10^6 + 0.266 * 10^6 + 0.133 * 10^6 \\
 &= 58.78 * 10^6 \text{ kcal/h}
 \end{aligned}$$

heat out :

$$\begin{aligned}
 \text{Total heat out} &= x(2) * 860/\text{RB} + x(3) * \text{EN3} + \text{RC} * x(1) * \text{EN2} \\
 &\quad + (\text{RD} * x(1) + 2.3 * \text{RE}) * \text{EN3} \\
 &= 7.41 * 10^6 + 14.38 * 690073 + 26.72 * 691000 \\
 &\quad + 34.07 * 675000 \\
 &= 7.41 * 10^6 + 9.92 * 10^6 + 18.46 * 10^6 \\
 &\quad + 22.99 * 10^6 \\
 &= 58.78 * 10^6 \text{ kcal/h}
 \end{aligned}$$

Balance 6. Around the section enclosed by loop P.6

Define EN7 - enthalpy of 17K steams at 198°C  
 EN7 = 19800 kcal/T

EN8 - enthalpy of 3K steam at 133°C  
 EN8 = 133000 kcal/T

BP1 - by - passed steam whose pressure was reduced to  
17K T/h

BP2 - by - passed steam whose pressure was reduced to  
3K T/h

D1 - Desuperheating water for BP1 T/h

D2 - Desuperheating water for BP2 T/h

BP - 100K by - passed steam

$$BP = x(1) - TUR$$

BP1 and D1 can be calculated from the heat balance.

$$FEE1 * EN5 = BP1 * EN7 + D1 * EN5 \quad \dots(a)$$

$$FDE2 * EN5 = (BP - BP1) * EN8 + (x(8) - D1) * EN5 \quad \dots(b)$$

from (b)

$$FDE2 * EN5 = BP * EN8 - BP1 * EN8 + x(8) * EN5 \\ - D1 * EN5 \quad \dots(c)$$

(a) + (c)

$$(FDE1 + FDE2) * EN5 = BP1 * (EN7 - EN2) + BP * EN8 \\ + x(8) * EN5$$

$$BP1 = (FDE1 + FDE2) * EN5 - BP * EN8 - x(8) * EN5 \\ EN7 - EN8$$

$$BP2 = BP - BP1$$

$$D1 = FDE1 * EN5 - BP1 * EN7 \\ EN5$$

$$D2 = x(8) - D1$$

After substituting the known values, we get

$$BP1 = 0.03 \text{ T/h}$$

$$BP2 = 0.72 \text{ T/h}$$

$$D1 = 1.788 \text{ T/h}$$

$$D2 = 0.252 \text{ T/h}$$

mass in :

$$\begin{aligned} \text{Total mass in} &= \text{BP} + x(8) \\ &= 0.75 + 2.04 \text{ T/h} \\ &= 2.79 \text{ T/h} \end{aligned}$$

mass out :

$$\begin{aligned} \text{Total mass out} &= \text{FDE1} + \text{FDE2} \\ &= 1.88 + 0.936 \text{ T/h} \\ &= 2.81 \text{ T/h} \end{aligned}$$

heat in :

$$\begin{aligned} \text{Total heat in} &= \text{BP1} * \text{EN7} + \text{BP2} * \text{EN8} + x(8) * \text{EN5} \\ &= 0.030 * 19800 + 0.72 * 133000 + 2.04 * 142000 \\ &= 5940 + 95760 + 289680 \\ &= 0.39 * 10^6 \text{ kcal/T} \end{aligned}$$

heat out :

$$\begin{aligned} \text{Total heat out} &= (\text{FDE1} + \text{FDE2}) * \text{EN5} \\ &= 2.81 * 142000 \\ &= 0.399 * 10^6 \text{ kcal/T} \end{aligned}$$

Balance 7. Around the section enclosed by loop P.7

mass in :

$$\begin{aligned} \text{Total mass in} &= x(1) \\ &= 73.13 \text{ T/h} \end{aligned}$$

mass out :

$$\begin{aligned} \text{Total mass out} &= \text{TUR} + \text{BP} \\ &= 72.38 + 0.75 \\ &= 73.13 \text{ T/h} \end{aligned}$$

heat in :

$$\begin{aligned} \text{Total heat in} &= x(1) * EN6 \\ &= 73.13 * 806643 \\ &= 58.98 * 10^6 \text{ kcal/T} \end{aligned}$$

heat out :

$$\begin{aligned} \text{Total heat out} &= TUR * EN6 + BP * EN6 \\ &= 72.38 * 806643 + 0.75 * 806643 \\ &= 58.38 * 10^6 + 0.6 * 10^6 \\ &= 58.98 * 10^6 \text{ kcal/T} \end{aligned}$$

Balance 8. Around the splitting point of 17K exhaust steam.

mass in :

$$\begin{aligned} \text{Total mass in} &= FEXT + FDE1 \\ &= 24.85 + 1.88 \\ &= 26.73 \text{ T/h} \end{aligned}$$

mass out :

$$\begin{aligned} \text{Total mass out} &= RC * x(1) + x(9) \\ &= 0.092 * 73.13 + 20 \\ &= 26.727 \text{ T/h} \end{aligned}$$

heat in :

$$\begin{aligned} \text{Total heat in} &= (FEXT + FDE1) * EN2 \\ &= 26.73 * 69100 \\ &= 18.47 * 10^6 \text{ kcal/T} \end{aligned}$$

heat out :

$$\begin{aligned} \text{Total heat out} &= (RC * x(1) + x(9)) * EN2 \\ &= 26.727 * 691000 \\ &= 18.47 * 10^6 \text{ kcal/T} \end{aligned}$$

Balance 9. Around the splitting point of 3K steam

mass in :

$$\begin{aligned}
 \text{Total mass in} &= \text{FEXH} - x(3) + \text{FDE2} \\
 &= 47.53 - 14.38 + 0.936 \\
 &= 34.086 \text{ T/h}
 \end{aligned}$$

mass out

$$\begin{aligned}
 \text{Total mass out} &= x(10) + x(1) * \text{RD} + 2.3 * \text{RE} \\
 &= 23 + 73.13 * 0.12 + 2.3 \\
 &= 34.07 \text{ T/h}
 \end{aligned}$$

heat in :

$$\begin{aligned}
 \text{Total heat in} &= [\text{FEXH} - x(3) + \text{FDE2}] * \text{EN4} \\
 &= 34.086 * 675000 \\
 &= 23.00 * 10^6 \text{ kcal/h}
 \end{aligned}$$

heat out :

$$\begin{aligned}
 \text{Total heat out} &= [x(10) + x(1) * \text{RD} + 2.3 * \text{RE}] * \text{EN4} \\
 &= 34.07 * 675000 \\
 &= 22.99 * 10^6 \text{ kcal/h}
 \end{aligned}$$

Balance 10. Around the blow-off point of 3K steam.

mass in :

$$\begin{aligned}
 \text{Total mass in} &= \text{FEXH} \\
 &= 47.53 \text{ T/h}
 \end{aligned}$$

mass out :

$$\begin{aligned}
 \text{Total mass out} &= \text{RD} * x(1) + 2.3 * \text{RE} + x(10) - \text{FDE2} + x(3) \\
 &= 0.12 * 73.13 + 2.3 + 23 - 0.936 + 14.38 \\
 &= 47.52 \text{ T/h}
 \end{aligned}$$

heat in :

$$\begin{aligned} \text{Total heat in} &= \text{FEXH} * \text{EN3} \\ &= 47.53 * 690073 \\ &= 32.79 * 10^6 \text{ kcal/h} \end{aligned}$$

heat out :

$$\begin{aligned} \text{Total heat out} &= \text{mass out} * \text{EN3} \\ &= 47.52 * 690073 \\ &= 32.79 * 10^6 \text{ kcal/h} \end{aligned}$$

Balance 11. Around the splitting point of 17K house service

steam.

mass in :

$$\begin{aligned} \text{Total mass in} &= x(1) * \text{RC} \\ &= 73.13 * 0.092 \\ &= 6.72 \text{ T/h} \end{aligned}$$

mass out :

$$\begin{aligned} \text{Total mass out} &= \text{TOAT} + X(11) \\ &= 0.044 + 6.676 \text{ T/h} \\ &= 6.72 \text{ T/h} \end{aligned}$$

heat in :

$$\begin{aligned} \text{Total heat in} &= \text{mass in} * \text{EN2} \\ &= 6.72 * 691000 \\ &= 4.648 * 10^6 \text{ kcal/T} \end{aligned}$$

heat out :

$$\begin{aligned} \text{Total heat out} &= \text{mass out} * \text{EN2} \\ &= 6.72 * 691000 \\ &= 4.648 * 10^6 \text{ kcal/T} \end{aligned}$$

Balance 12. Around the splitting point of 3K house service

steam

mass in :

$$\begin{aligned}
 \text{Total mass in} &= \text{RD} * x(1) + 2.3 * \text{RE} \\
 &= 0.12 * 73.13 + 2.3 \\
 &= 8.776 + 2.3 \\
 &= 11.076 \text{ T/h}
 \end{aligned}$$

mass out :

$$\text{Total mass out} = \text{TODT} + \text{TOAPH} + \text{TOFOH}$$

TOFOH

$$\begin{aligned}
 \text{TOFOH} * (\text{EN4} - 0.1 * 10^6) &= \text{CPOIL} (T)_{\text{oil}} Q_{\text{oil}} \\
 \text{TOFOH} * (\text{EN4} - 0.1 * 10^6) &= 0.538 \text{ kcal /kg}^{\circ}\text{C} * (90 - 60) \text{ C} * 52011/\text{h} \\
 &\quad * 0.9465 \text{ kg/l} \\
 &= 0.079 * 10^6 \text{ kcal/h} \\
 \text{TOFOH} &= (0.079 * 10^6) / (0.575 * 10^6) \\
 &= 0.1374 \text{ T/h}
 \end{aligned}$$

TOAPH

$$\begin{aligned}
 \text{TOAPH} * \text{EN4} &= \text{CPAIR} (T)_{\text{air}} Q_{\text{air}} \\
 &= 0.237 \text{ kcal/kg}^{\circ}\text{C} * (122 - 35)^{\circ}\text{C} * 13.19 \text{ m}^3/\text{kg}_{\text{oil}} \\
 &\quad * 1.29 \text{ kg/m}^3 \\
 &= 351.0 \text{ kcal/kg}_{\text{oil}} \\
 &= 351.0 * 5201 \text{ l/h} * 0.9465 \text{ kg/l} \\
 &= 1.73 * 10^6 \text{ kcal/h} \\
 \text{TOAPH} &= 1.72 * 10^6 / 0.675 * 10^6 \\
 &= 2.56 \text{ T/h}
 \end{aligned}$$

TODT

$$\begin{aligned} \text{TODT} &= \text{mass in} - \text{TOFOH} - \text{TOAPH} \\ &= 11.076 - 0.1374 - 2.56 \\ &= 8.378 \text{ T/h} \end{aligned}$$

$$\begin{aligned} \text{Total mass out} &= 8.378 + 2.56 + 0.1374 \\ &= 11.076 \text{ T/h} \end{aligned}$$

heat in :

$$\begin{aligned} \text{Total heat in} &= \text{mass in} * \text{EN4} \\ &= 11.076 * 0.675 * 10^6 \\ &= 7.47 * 10^6 \text{ kcal/h} \end{aligned}$$

heat out :

$$\begin{aligned} \text{Total heat out} &= \text{mass out} * \text{EN4} \\ &= 11.076 * 0.675 * 10^6 \\ &= 7.47 * 10^6 \text{ kcal/h} \end{aligned}$$

Balance 13. Around the splitting point of 3K heating steam.

mass in :

$$\begin{aligned} \text{Total mass in} &= \text{RC} * x(1) + 2.3 * \text{RE} - \text{TODT} \\ &= 0.12 * 73.13 + 2.3 - 8.38 \\ &= 11.07 - 8.38 \\ &= 2.69 \text{ T/h} \end{aligned}$$

mass out :

$$\begin{aligned} \text{Total mass out} &= \text{TOFOH} + \text{TOAPH} \\ &= 0.11 + 2.56 \\ &= 2.69 \text{ T/h} \end{aligned}$$



heat in :

$$\begin{aligned} \text{Total heat in} &= \text{mass in} * EN4 \\ &= 2.69 * 0.675 * 10^6 \\ &= 1.82 * 10^6 \text{ kcal/h} \end{aligned}$$

heat out :

$$\begin{aligned} \text{Total heat out} &= \text{mass out} * EN4 \\ &= 2.69 * 0.675 * 10^6 \\ &= 1.82 * 10^6 \text{ kcal/h} \end{aligned}$$

Balance 14. Around the section enclosed by loop P.14

mass in :

$$\begin{aligned} \text{Total mass in} &= \text{CON} + x(7) + x(11) + \text{RD} * x(1) + 2.3 \\ &= 35 + 26.07 + 6.676 + 11.076 \\ &= 78.82 \text{ T/h} \end{aligned}$$

mass out :

$$\begin{aligned} \text{Total mass out} &= \text{TOFOH} + \text{TOAPH} + x(8) + 1.01 * x(1) \\ &= 0.137 + 2.56 + 2.04 + 73.86 \\ &= 78.592 \text{ T/h} \end{aligned}$$

heat in :

$$\begin{aligned} \text{Total heat in} &= \text{CON} * x(13) * 1000 + X(7) * 0.03 * 10^6 + x(11) \\ &\quad * EN2 + (\text{RD} * x(1) + 2.3) * EN4 \\ &= 35 * 0.095 * 10^6 + 26.07 * 0.03 * 10^6 + 6.67 \\ &\quad * 0.691 * 10^6 + 11.07 * 0.675 * 10^6 \\ &= 3.325 * 10^6 + 0.78 * 10^6 + 4.61 * 10^6 + 7.47 \\ &\quad * 10^6 \\ &= 16.18 * 10^6 \text{ kcal/h} \end{aligned}$$

heat out :

$$\begin{aligned}
 \text{Total heat out} &= (\text{TOFOH} + \text{TOAPH}) * \text{EN4} + x(8) * 0.14 * 10^6 \\
 &+ 1.01 * x(1) * 0.19 * 10^6 \\
 &= 2.697 * 0.675 * 10^6 + 2.04 * 0.14 * 10^6 \\
 &+ 1.01 * 73.13 * 0.19 * 10^6 \\
 &= 1.82 * 10^6 + 0.28 * 10^6 + 14.03 * 10^6 \\
 &= 16.13 * 10^6 \text{ kcal/h}
 \end{aligned}$$

Balance 15. Around the boiler

mass in :

$$\begin{aligned}
 \text{Total mass in} &= 1.01 * x(1) \\
 &= 1.01 * 73.13 \\
 &= 73.86 \text{ T/h}
 \end{aligned}$$

mass out :

$$\begin{aligned}
 \text{Total mass out} &= x(1) + 0.01 * x(1) \\
 &= 73.13 + 0.073 \\
 &= 73.86 \text{ T/h}
 \end{aligned}$$

heat in :

$$\begin{aligned}
 \text{Total heat in} &= (\text{heat from air}) + (\text{heat from oil}) + \\
 &(\text{heat from feed water}) + (\text{heat of combustion}) \\
 &+ (\text{heat of atomizing steam})
 \end{aligned}$$

$$\begin{aligned}
 \text{heat from air} &= \text{CPAIR} (\Delta T)_{\text{air}} Q_{\text{air}} \\
 &= 0.237 \text{ kcal/kg}^{\circ\text{C}} (22-25)^{\circ\text{C}} * 13.19 \text{ m}^3/\text{kg}_{\text{oil}} \\
 &\quad * 1.29 \text{ kg/m}^3 \\
 &= 391.16 \text{ kcal/kg}_{\text{oil}} \\
 &= 391.16 \text{ kcal/kg}_{\text{oil}} * 5201 \text{ l/h} * 0.9465 \text{ kg/l} \\
 &= 1.925 * 10^6 \text{ kcal/h}
 \end{aligned}$$

$$\begin{aligned}
 \text{heat from oil} &= C_{POIL} (\Delta T)_{oil} Q_{oil} \\
 &= 0.538 \text{ kcal/kg}^{\circ}\text{C} (90-25)^{\circ}\text{C} * 5201 \text{ l/h} * 0.9465 \text{ kg/l} \\
 &= 0.172 * 10^6 \text{ kcal/h}
 \end{aligned}$$

$$\begin{aligned}
 \text{heat from feed water} &= 1.01 * x(1) * 0.19 * 10^6 \text{ kcal/h} \\
 &= 1.01 * 73.13 * 0.19 * 10^6 \text{ kcal/h} \\
 &= 14.03 * 10^6 \text{ kcal/h}
 \end{aligned}$$

$$\begin{aligned}
 \text{heat of combustion} &= \text{heating value} * x(6) \\
 &= 9294.63 \text{ kcal/l} * 5201 \text{ l/h} \\
 &= 48.34 * 10^6 \text{ kcal/h}
 \end{aligned}$$

$$\begin{aligned}
 \text{heat of atomizing steam} &= [RC * x(1) - x(11)] * EN2 \\
 &= (6.72 - 6.676) * 0.691 * 10^6 \\
 &= 0.03 * 10^6 \text{ kcal/h}
 \end{aligned}$$

$$\begin{aligned}
 \text{Total heat in} &= 1.925 * 10^6 + 0.172 * 10^6 + 14.03 \\
 &\quad * 10^6 + 48.34 * 10^6 + 0.03 * 10^6 \\
 &= 64.494 * 10^6 \text{ kcal/h}
 \end{aligned}$$

heat out :

$$\begin{aligned}
 \text{Total heat out} &= (\text{heat of superheated steam}) + \\
 &\quad (\text{heat of flue gas}) + \\
 &\quad (\text{heat in blow down}) + (\text{heat losses})
 \end{aligned}$$

$$\begin{aligned}
 \text{heat of superheated} &= x(1) * 0.806 * 10^6 \text{ kcal/h} \\
 &= 73.13 * 0.806 * 10^6 \text{ kcal/h} \\
 &= 58.94 * 10^6 \text{ kcal/h}
 \end{aligned}$$

$$\begin{aligned}
 \text{heat of flue gas} &= C_{PAIR} (T)_{air} Q_{air} \\
 &= 0.237 \text{ kcal/kg}^{\circ}\text{C} (195-25) \\
 &\quad * 13.19 \text{ m}^3/\text{kg}_{oil} * 1.29 \text{ kg/m}^3 \\
 &= 685.54 \text{ kcal/kg}_{oil} \\
 &= 685.54 \text{ kcal/kg}_{oil} * 5201 \text{ l/h} \\
 &\quad * 0.9465 \text{ kg/l}
 \end{aligned}$$

$$\begin{aligned}
 &= 3.37 * 10^6 \text{ kcal/h} \\
 \text{heat in blow down} &= 0.01 * x(1) * 0.5 * 10^6 \text{ kcal/h} \\
 &= 0.01 * 73.13 * 0.5 * 10^6 \\
 &= 0.36 * 10^6 \text{ kcal/h} \\
 \text{heat losses} &= 64.494 * 10^6 - 58.94 * 10^6 - 3.37 * 10^6 \\
 &\quad - 0.36 * 10^6 \\
 &= 1.82 * 10^6 \text{ kcal/h} \\
 \% \text{ heat loss} &= [(1.82 * 10^6 / (64.49 * 10^6))] * 100 \\
 &= 2.82\% \\
 \text{Total heat out} &= 58.94 * 10^6 + 3.37 * 10^6 + 0.36 * 10^6 \\
 &\quad + 1.82 * 10^6 \\
 &= 64.49 * 10^6 \text{ kcal/h}
 \end{aligned}$$

Balance 16. Around the dealration tank

mass in :

$$\begin{aligned}
 \text{Total mass in} &= \text{CON} + \text{make-up water} + x(11) + \text{TODT} \\
 &= 35 + 26.07 + 6.676 + 8.378 \\
 &= 76.124 \text{ T/h}
 \end{aligned}$$

mass out :

$$\text{Total mass out} = 75.93 \text{ T/h}$$

heat in :

$$\begin{aligned}
 \text{Total heat in} &= (\text{CON} + \text{make-up water}) * x(12) * 1000 \\
 &\quad + x(11) * 0.16 * 10^6 + \text{TODT} * \text{EN4} \\
 &= 61.07 * 0.067 * 10^6 + 6.676 * 0.16 * 10^6 \\
 &\quad + 8.37 * 0.675 * 10^6 \\
 &= 4.09 + 1.07 + 5.65 \text{ kcal/h} \\
 &= 10.81 \text{ kcal/h}
 \end{aligned}$$

heat out :

$$\begin{aligned}
 \text{Total heat out} &= \text{mass out} * 0.142 * 10^6 \\
 &= 75.93 * 0.142 * 10^6 \text{ kcal/h} \\
 &= 10.78 \text{ kcal/h}
 \end{aligned}$$

Balance 17. Around the boiler feed pump

mass in :

$$\begin{aligned}
 \text{Total mass in} &= \text{CON} + \text{make-up water} + x(11) + \text{TOdT} \\
 &= 35 + 26.07 + 6.676 + 8.37 \\
 &= 76.12 \text{ T/h}
 \end{aligned}$$

mass out :

$$\begin{aligned}
 \text{Total mass out} &= 1.01 * x(1) - x(8) \\
 &= 73.86 + 2.04 \text{ T/h} \\
 &= 75.90 \text{ T/h}
 \end{aligned}$$

heat in :

$$\begin{aligned}
 \text{Total heat in} &= \text{mass in} * 0.142 * 10^6 \\
 &= 76.12 * 0.142 * 10^6 \\
 &= 10.81 * 10^6 \text{ kcal/h}
 \end{aligned}$$

heat out :

$$\begin{aligned}
 \text{Total heat out} &= \text{mass out} * 0.142 * 10^6 \\
 &= 75.9 * 0.142 * 10^6 \\
 &= 10.77 * 10^6 \text{ kcal/h}
 \end{aligned}$$

Balance 18. Around the high pressure heater

mass in :

$$\begin{aligned}
 \text{Total mass in} &= 1.01 * x(1) + x(11) \\
 &= 73.86 + 6.676 \text{ T/h} \\
 &= 80.536 \text{ T/h}
 \end{aligned}$$

mass out :

$$\begin{aligned} \text{Total mass out} &= 1.01 * x(1) + x(11) \\ &= 73.86 + 6.676 \\ &= 80.536 \text{ T/h} \end{aligned}$$

heat in :

$$\begin{aligned} \text{Total heat in} &= 1.01 * x(1) * 0.142 * 10^6 + x(11) \text{ EN2} \\ &= 73.86 * 0.142 * 10^6 + 6.676 * 0.691 * 10^6 \\ &= 10.49 * 10^6 + 4.61 * 10^6 \\ &= 15.10 * 10^6 \text{ kcal/h} \end{aligned}$$

heat out :

$$\begin{aligned} \text{total heat out} &= 1.01 * x(1) * 0.19 * 10^6 + x(11) * 0.16 * 10^6 \\ &= 73.86 * 0.19 * 10^6 + 6.676 * 0.16 * 10^6 \\ &= (14.03 + 1.07) * 10^6 \\ &= 15.10 * 10^6 \text{ kcal/h} \end{aligned}$$

Balance 19. Around the fuel oil heater

mass in :

$$\begin{aligned} \text{Total mass in} &= \text{TOFOH} \\ &= 0.117 \text{ T/h} \end{aligned}$$

mass out :

$$\begin{aligned} \text{Total mass out} &= \text{mass in} \\ &= 0.117 \text{ T/h} \end{aligned}$$

heat in :

$$\begin{aligned} \text{Total heat in} &= \text{TOFOH} * \text{EN4} + \text{CPOIL} (\Delta T)_{\text{oil}} Q_{\text{oil}} \\ &= 0.137 * 0.675 * 10^6 + 0.538 (60-25) * 5201 \\ &\quad * 0.9465 \\ &= 0.092 * 10^6 + 0.0927 * 10^6 \\ &= 0.185 * 10^6 \text{ kcal/h} \end{aligned}$$

heat out :

$$\begin{aligned}
 \text{total heat out} &= \text{TOFOH} * 0.1 * 10^6 + \text{CPOIL} (\Delta T)_{\text{oil}} Q_{\text{oil}} \\
 &= 0.137 * 0.1 * 10^6 + 0.538 (90-25) * 5201 \\
 &\quad * 0.9465 \\
 &= 0.0137 * 10^6 + 0.172 * 10^6 \\
 &= 0.185 * 10^6 \text{ kcal/h}
 \end{aligned}$$

Balance 20. Around the air preheater

mass in :

$$\begin{aligned}
 \text{Total mass in} &= \text{TOAPH} \\
 &= 2.56 \text{ T/h}
 \end{aligned}$$

mass out :

$$\begin{aligned}
 \text{total mass out} &= \text{mass in} \\
 &= 2.56 \text{ T/h}
 \end{aligned}$$

heat in :

$$\begin{aligned}
 \text{Total heat in} &= \text{TOAPH} * EN4 + \text{CPAIR} (\Delta T)_{\text{air}} Q_{\text{air}} \\
 &= 2.56 * 0.675 * 10^6 + 0.237 (35-25) * 13.19 \\
 &\quad * 1.29 * 5201 * 0.9465 \\
 &= 1.73 * 10^6 + 0.198 * 10^6 \\
 &= 1.928 * 10^6 \text{ kcal/h}
 \end{aligned}$$

heat out :

$$\begin{aligned}
 \text{total heat out} &= \text{CPAIR} (\Delta T)_{\text{air}} Q_{\text{air}} \\
 &= 0.237 (122-25) * 13.19 * 1.29 * 5201 * 0.9465 \\
 &= 1.925 * 10^6 \text{ kcal/h}
 \end{aligned}$$

Balance 21. Around the pure water tank

mass in :

$$\begin{aligned}
 \text{Total mass in} &= \text{CON} + \text{make-up water} \\
 &= 35 + 26.07 \text{ T/h} \\
 &= 61.07 \text{ T/h}
 \end{aligned}$$

mass out :

$$\begin{aligned}
 \text{total mass out} &= \text{mass in} \\
 &= 61.07 \text{ T/h}
 \end{aligned}$$

heat in :

$$\begin{aligned}
 \text{total heat in} &= \text{CON} * x(13) * 1000 + \text{BFW} * 0.03 * 10^6 \\
 &= 35 * 0.095 * 10^6 + 26.07 * 0.03 * 10^6 \\
 &= 3.325 * 10^6 + 0.782 * 10^6 \\
 &= 4.107 * 10^6 \text{ kcal/h}
 \end{aligned}$$

heat out :

$$\begin{aligned}
 \text{total heat out} &= (\text{CON} + \text{BFW}) * x(12) * 1000 \\
 &= 61.07 * 0.067 * 10^6 \\
 &= 4.09 * 10^6 \text{ kcal/h}
 \end{aligned}$$






Fig C.1 Location of Heat and Mass Balance

3. Computer print out for both starting point and optimal point.

PARAMETERS

NV 13  
 NIN 6  
 NEG 9  
 NEVL 20  
 NTO 6  
 ITET 20  
 ICCNJ 1  
 IDIAG 0  
 ITHAX 20  
 KFIL 1  
 KLTH 0  
 NCO 15  
 ITSOR 1  
 ISOLSUR 20  
 EPSIL 0.1E+00  
 EPSILO 0.1E-03  
 EPSILI 0.1E-03  
 EPSIL2 0.1E-03  
 PC 0.0E+00

INITIAL REMARK TEST NO. SCALL AT JACOBIAN

COGENERATION PROBLEM  
REMARK DAY 5TH APRIL NORMAL RUN

COST OF MATERIAL

FUEL COST (BATH/LITRE) 2.620 ELECTRIC COST (BATH/KWH) 1.438  
 CW; COST OF BOILER FEED WATER BATH/LITRE 10.000  
 CS; COST OF 17K STEAM FOR SALE BATH/LITRE 122.878  
 CB; COST OF 3K BLOW STEAM BATH/LITRE 79.962

PROCESS REQUIREMENT

TOTAL REQUIREMENT OF ELECTRIC KWH 12000.000  
 TOTAL REQUIREMENT OF STEAM T/H 50.200  
 CONDENSATE WATER T/H 35.000  
 STEAM FOR SALE T/H 6.000

SUMMARY OF INDIVIDUAL VARIABLE  
 BOILER LOAD T/H AT 100 KG/CM<sup>2</sup> 73.130  
 PRODUCED ELECTRIC KWH 8536.000  
 3K BLOW STEAM T/HR 14.380  
 PURCHASE ELECTRIC KWH 2464.000  
 ABUS ELECTRIC KWH 2463.000  
 FUEL OIL CONSUMPTION L/H 5201.000  
 BOILER FEED WATER T/H ---26.070  
 DESUPERHEAT WATER T/H 2.040  
 17K STEAM GENERATION T/H 20.000  
 3K STEAM GENERATION T/H 23.000

INTERESTING VARIABLE  
 TURBINE AND GENERATOR EFFICIENCY 0.993  
 17K PROCESS REQUIREMENT T/H 29.000  
 3K PROCESS REQUIREMENT T/H 32.200  
 17K HOUSE SERVICE T/H 6.728  
 3K HOUSE SERVICE T/H 11.076  
 BUSTIE ELECTRIC KWH 1.000  
 B9US ELECTRIC KWH 9537.000

INTERESTING HEAT BALANCE  
 OBJECTIVE FUNCTION VALUE  
 FUEL COST BATH/HK 13626.619  
 ELECTRIC COST BATH/HK 3543.231  
 BOILER FEED WATER COST BATH/HR 260.700  
 SALE STEAM COST BATH/HK 737.268  
 3K BLOW STEAM COST BATH/HR 1149.859  
 TOTAL COST BATH/HK 17843.142

HEAT AND MASS BALANCE  
 POINT 1. MASS BALANCE AROUND BIG LCOG  
 SUM CF MASS IN 75.170 T/H SUM OF MASS OUT  
 HEAT BALANCE AROUND BIG LCOG  
 SUM OF HEAT IN .59790+08 KCAL/H SUM CF HEAT OUT 75.184 T/H % RELATIVE ERROR -0.018  
 POINT 2. MASS BALANCE AROUND TURBOGENERATOR  
 SUM CF MASS IN 72.355 T/H SUM OF MASS OUT 72.359 T/H % RELATIVE ERROR 0.000  
 HEAT BALANCE AROUND TURBOGENERATOR  
 SUM OF HEAT IN .58980+08 KCAL/H SUM OF HEAT OUT .58980+08 KCAL/H % RELATIVE ERROR -0.034

POINT 3. MASS BALANCE AT DESUP PCINT CF 3K  
 SUM CF MASS IN 34.076 T/H SUM OF MASS OUT -0.000  
 HEAT BALANCE AT DESUP PCINT CF 3K  
 SUM OF HEAT IN .230010+08 KCAL/H % RELATIVE ERROR 0.000  
 SUM OF HEAT OUT

POINT 4. MASS BALANCE AT DESUP PCINT OF 17K  
 SUM OF MASS IN 26.728 T/H SUM OF MASS OUT -0.000  
 HEAT BALANCE AT DESUP PCINT OF 17K  
 SUM OF HEAT IN .184690+08 KCAL/H % RELATIVE ERROR 0.000  
 FUEL= 1.888 Fuel= 9.937  
 SUM OF HEAT OUT

POINT 5. MASS BALANCE AT SECCND LGOP  
 SUM CF MASS IN 75.184 T/H SUM CF MASS OUT -0.000  
 HEAT BALANCE AT SEPARATE CF DECAL  
 SUM OF HEAT IN .599020+08 KCAL/H % RELATIVE ERROR -0.908  
 SUM OF HEAT OUT

POINT 6. MASS BALANCE AT DESUP ANC 3P  
 SUM OF MASS IN 2.825 T/H % RELATIVE ERROR -0.482  
 HEAT BALANCE AT DESUP ANC 3P  
 SUM OF HEAT IN .401140+08 KCAL/H % RELATIVE ERROR 0.000  
 BPL=0.136 UP2=0.635 D1=1.698  
 SUM OF HEAT OUT D2=0.342

POINT 7. MASS BALANCE AT 3L AND BP  
 SUM CF MASS IN 73.130 T/H % RELATIVE ERROR 0.000  
 HEAT BALANCE AT 8L AND BP  
 SUM OF HEAT IN .589900+08 KCAL/H % RELATIVE ERROR 0.000  
 SUM OF HEAT OUT

POINT 8. MASS BALANCE AT SEPARATE CF 17K  
 SUM OF MASS IN 26.728 T/H % RELATIVE ERROR 0.000  
 HEAT BALANCE AT SEPARATE OF 17K  
 SUM OF HEAT IN .184690+08 KCAL/H % RELATIVE ERROR 0.000  
 SUM OF HEAT OUT

POINT 9. MASS BALANCE AT SEPARATE CF 3K  
 SUM CF MASS IN 34.076 T/H % RELATIVE ERROR -0.000  
 HEAT BALANCE AT SEPARATE OF 3K  
 SUM OF HEAT IN .230010+08 KCAL/H % RELATIVE ERROR -0.000  
 SUM OF HEAT OUT

POINT 10. MASS BALANCE AT 8LCH 3K  
 SUM OF MASS IN 47.518 T/H % RELATIVE ERROR 0.000  
 HEAT BALANCE AT SEPARATE OF 3K  
 SUM OF HEAT IN .327910+08 KCAL/H % RELATIVE ERROR 0.000  
 SUM OF HEAT OUT

POINT 11. MASS BALANCE AT 17K TO AT  
 XINHPH= 6.670 Fuel= 0.052  
 SUM OF MASS IN 6.728 T/H % RELATIVE ERROR 0.000  
 HEAT BALANCE AT 17K TO AT  
 SUM OF HEAT IN .469900+07 KCAL/H % RELATIVE ERROR 0.000  
 SUM OF HEAT OUT

POINT 12. MASS BALANCE AT 3K TO CT  
 TOFUH=.138180+00  
 TOAPH=.255860+01  
 TODT=.837880+01  
 SUM CF MASS IN 11.076 T/H % RELATIVE ERROR 0.000  
 HEAT BALANCE AT 3K TO CT  
 SUM OF HEAT IN .747600+07 KCAL/H % RELATIVE ERROR 0.000  
 SUM OF HEAT OUT

POINT 13. MASS BALANCE AT 3K TO CT  
 TOFUH=.138180+00  
 TOAPH=.255860+01  
 TODT=.837880+01  
 SUM CF MASS IN 11.076 T/H % RELATIVE ERROR 0.000  
 HEAT BALANCE AT 3K TO CT  
 SUM OF HEAT IN .747600+07 KCAL/H % RELATIVE ERROR 0.000  
 SUM OF HEAT OUT

POINT 14. MASS BALANCE AT 3K TO CT  
 TOFUH=.138180+00  
 TOAPH=.255860+01  
 TODT=.837880+01  
 SUM CF MASS IN 11.076 T/H % RELATIVE ERROR 0.000  
 HEAT BALANCE AT 3K TO CT  
 SUM OF HEAT IN .747600+07 KCAL/H % RELATIVE ERROR 0.000  
 SUM OF HEAT OUT



GRADIENT REJUIT GENERALISE

NOMBRE DE VARIABLES NATURELLES 13  
 NOMBRE TOTAL DE VARIABLES 28  
 NOMBRE DE CONTRAINTEJ 15  
 EPSILON DE NEWTON 0.1000E-03  
 EPSILON TEST GRADIENT 0.1000E-03

FONCTION ECONOMIQUE -0.173431+22789280+35

	BOURNE INFERIEURE	VARIABLE NATURELLE	BOURNE SUPERIEURE	
X(1)	0.5000000000000000+02	0.7510000000000000+02	XSI(1)	0.7500000000000000+02
X(2)	0.6500000000000000+04	0.8530000000000000+04	XSI(2)	0.9000000000000000+04
X(3)	0.0000000000000000+00	0.1438000000000000+02	XSI(3)	0.1500000000000000+02
X(4)	0.2010000000000000+04	0.2400000000000000+04	XSI(4)	0.1200000000000000+05
X(5)	0.1000000000000000-05	0.2400000000000000+04	XSI(5)	0.1200000000000000+05
X(6)	0.3580000000000000+04	0.5201000000000000+04	XSI(6)	0.5330000000000000+04
X(7)	0.2400000000000000+01	0.2607000000000000+02	XSI(7)	0.7500000000000000+02
X(8)	0.1000000000000000-01	0.2040000000000000+01	XSI(8)	0.3450000000000000+01
X(9)	0.2000000000000000+02	0.2000000000000000+02	XSI(9)	0.4000000000000000+02
X(10)	0.1500000000000000+02	0.2300000000000000+02	XSI(10)	0.4000000000000000+02
X(11)	0.0000000000000000+00	0.6070000000000000+01	XSI(11)	0.7360000000000000+01
X(12)	0.5500000000000000+02	0.6700000000000000+02	XSI(12)	0.9000000000000000+02
X(13)	0.6000000000000000+02	0.9540000000000000+02	XSI(13)	0.1000000000000000+03

VALEUR DES CONTRAINTES

C( 1) -0.1700000000000000  
 C( 2) -0.23494648855230+00  
 C( 3) -0.217156078746250+00  
 C( 4) -0.419605562994940-01  
 C( 5) -0.13128335634240+02  
 C( 6) -0.108716610565760+02  
 C( 7) 0.277712210034160+00  
 C( 8) -0.100000000000000+04  
 C( 9) -0.113845463904510+00  
 C(10) 0.135610973834970-01  
 C(11) 0.23484042733110+00  
 C(12) -0.209940163605070+00  
 C(13) -0.171999969482420+02  
 C(14) -0.371661601942390-02  
 C(15) 0.294106066128770-02

IT	1	2	3	4	5	6	7	8	9	10	11	12	13	14
PHI	-0.0000000000000000	0.6600000000000000	0.6600000000000000	0.6600000000000000	0.6600000000000000	0.6600000000000000	0.6600000000000000	0.6600000000000000	0.6600000000000000	0.6600000000000000	0.6600000000000000	0.6600000000000000	0.6600000000000000	0.6600000000000000
DIR	GRAD	GRAD	GRAD	GRAD	GRAD	GRAD	GRAD	GRAD	GRAD	GRAD	GRAD	GRAD	GRAD	GRAD
ITERATION	NO 4	NO 5	NO 8	NO 5	NO 8	NO 9	NO 9	NO 10	NO 10	NO 10	NO 12	NO 11	NO 12	NO 12
YI	0.440+00	0.300+00	0.170+00	0.180+00	0.170+00	0.110+00	0.480+00	0.950+00	0.140+00	0.140+00	0.170+00	0.290+00	0.280+00	0.000+00
BASE	DEGENERE	DEGENERE	DEGENERE	DEGENERE	DEGENERE	DEGENERE	DEGENERE	DEGENERE	DEGENERE	DEGENERE	DEGENERE	DEGENERE	DEGENERE	DEGENERE
DELTA	1	1	1	1	1	1	1	1	1	1	1	1	1	1
ETA	0.62E+09	0.62E+09	0.62E+09	0.62E+09	0.62E+09	0.62E+09	0.31E+16	0.43E+14	0.11E+18	0.62E+09	0.62E+09	0.56E+05	0.24E+05	0.00E+00
NCDB	1	1	4	4	5	1	1	2	1	1	1	1	1	1
NCN	2	1	4	3	2	4	6	9	2	2	10	3	3	3
NITN	6	6	6	6	6	6	6	20	6	20	3	10	10	6

IMPOSSIBILITE D'AVOIR UN POINT REALISABLE  
 ESSAYEZ DE MODIFIER LES PENALITES SUR LES VARIABLES ARTIFICIELLES DONT VOICI LA LISTE

XI	20	21	22	23	24	25	26	27	28
VARIABLE	ARTIFICIELLE	ARTIFICIELLE	ARTIFICIELLE	ARTIFICIELLE	ARTIFICIELLE	ARTIFICIELLE	ARTIFICIELLE	ARTIFICIELLE	ARTIFICIELLE
RELATIVE	A LA CONTRAINTE	A LA CONTRAINTE	A LA CONTRAINTE	A LA CONTRAINTE	A LA CONTRAINTE	A LA CONTRAINTE	A LA CONTRAINTE	A LA CONTRAINTE	A LA CONTRAINTE
ETA	7	8	9	10	11	12	13	14	15
NCDB	1	1	1	1	1	1	1	1	1
NCN	1	1	1	1	1	1	1	1	1
NITN	1	1	1	1	1	1	1	1	1



DIRECTION DE DEPLACEMENT

Y( 1)	0.0000000000000000	Y( 2)	0.0000000000000000	Y( 3)	-0.79624077011100+02	Y( 4)	0.0000000000000000
Y( 5)	0.0000000000000000	Y( 6)	0.0000000000000000	Y( 7)	0.0000000000000000	Y( 8)	0.0000000000000000
Y( 9)	0.0000000000000000	Y( 10)	0.0000000000000000	Y( 11)	0.0000000000000000	Y( 12)	0.0000000000000000
Y( 13)	0.0000000000000000	Y( 14)	0.0000000000000000	Y( 15)	0.0000000000000000	Y( 16)	0.0000000000000000
Y( 17)	0.0000000000000000	Y( 18)	0.0000000000000000	Y( 19)	0.0000000000000000	Y( 20)	0.0000000000000000
Y( 21)	0.0000000000000000	Y( 22)	0.0000000000000000	Y( 23)	0.0000000000000000	Y( 24)	0.0000000000000000
Y( 25)	0.0000000000000000	Y( 26)	0.0000000000000000	Y( 27)	0.0000000000000000	Y( 28)	0.0000000000000000

VARIABLE DUALE ASSOCIEE

V( 1)	=	0.
V( 2)	=	0.
V( 3)	=	-0.79624077011100+02
V( 4)	=	0.
V( 5)	=	0.0000000000000000
V( 6)	=	0.223113738665600+02
V( 7)	=	0.
V( 8)	=	0.
V( 9)	=	0.
V( 10)	=	0.
V( 11)	=	0.
V( 12)	=	0.
V( 13)	=	0.

VARIABLE NATURELLE

X( 1)	=	0.749916140227170+02
X( 2)	=	0.80009777340940+04
X( 3)	=	0.100000000017110-29
X( 4)	=	0.3959102222559160+04
X( 5)	=	0.2463000000000000+04
X( 6)	=	0.5350000000000000+09
X( 7)	=	0.237237028784870+02
X( 8)	=	0.34064108100950+01
X( 9)	=	0.336872426035130+02
X( 10)	=	0.265127542827290+02
X( 11)	=	0.688914751855000+01
X( 12)	=	0.68309081130900+02
X( 13)	=	0.997481570811050+02

= X( 6)

VARIABLE DUALE ASSOCIEE

CONTRAINTE

CONTRAINTE 1	-0.147610222655140+04	U1 1) =	J.000J000000000000+00
CONTRAINTE 2	-0.10700004749750-03	U1 2) =	0.216249252285500+04
CONTRAINTE 3	-0.205870647205670+03	U1 3) =	0.003J000000000000+00
CONTRAINTE 4	-0.107000031749750-03	U1 4) =	J.999999999998670+01
CONTRAINTE 5	-0.232708366362870+02	U1 5) =	J.000J000000000000+00
CONTRAINTE 6	-0.072916336376260+01	U1 6) =	J.000J000000000000+00
CONTRAINTE 7	0.311495402627320-05	U1 7) =	J.288597939789800+03
CONTRAINTE 8	-0.909494701772910-12	U1 8) =	-0.143799972534180+01
CONTRAINTE 9	0.307000000000000+03	U1 9) =	-J.249365589072090+02
CONTRAINTE 10	0.170413430515430-04	U1 10) =	J.648655286755980+05
CONTRAINTE 11	-0.333066907387530-14	U1 11) =	-0.627030361527430+05
CONTRAINTE 12	0.307000000000000+03	U1 12) =	-J.626930361527430+05
CONTRAINTE 13	-0.355271357880050-14	U1 13) =	-0.183235909286610+04
CONTRAINTE 14	-0.193140199994610-08	U1 14) =	0.000000000000000+00
CONTRAINTE 15	0.155140197978010-08	U1 15) =	J.000000000000000+00





0.6+9330+00	-J.972500+00	0.000000+00	0.000000+00	0.000000+00	0.000000+00													
LIGNE DE RANG	8																	
0.000000+00	J.100000+01	0.000000+00	0.100000+01	0.000000+00	0.000000+00													
0.000000+00	0.000000+00	0.000000+00	0.000000+00	0.000000+00	0.000000+00													
LIGNE DE RANG	9																	
-0.691800+02	0.000000+00	0.000000+00	0.000000+00	0.000000+00	0.000000+00													
0.000000+00	0.000000+00	0.000000+00	0.000000+00	0.000000+00	0.000000+00													
LIGNE DE RANG	10																	
-0.780000+00	0.000000+00	0.000000+00	0.000000+00	0.000000+00	0.000000+00													
0.100000+01	0.000000+01	0.000000+00	0.000000+00	0.000000+00	0.000000+00													
LIGNE DE RANG	11																	
-0.890000+00	0.000000+00	0.000000+00	0.000000+00	0.000000+00	0.000000+00													
0.000000+00	0.000000+00	0.000000+00	0.000000+00	0.000000+00	0.000000+00													
LIGNE DE RANG	12																	
-0.102000+00	0.000000+00	0.000000+00	0.000000+00	0.000000+00	0.000000+00													
0.100000+01	0.100000+01	-0.100000+01	0.000000+00	0.000000+00	0.000000+00													
LIGNE DE RANG	13																	
0.000000+00	0.000000+00	0.000000+00	0.000000+00	0.000000+00	0.000000+00													
0.100000+01	0.100000+01	0.000000+00	0.000000+00	0.000000+00	0.000000+00													
LIGNE DE RANG	14																	
-0.110000+01	0.000000+00	0.000000+00	0.000000+00	0.000000+00	0.000000+00													
0.000000+00	0.000000+00	0.000000+00	0.000000+00	0.000000+00	0.000000+00													
LIGNE DE RANG	15																	
0.000000+00	0.000000+00	0.000000+00	0.000000+00	0.000000+00	0.000000+00													
0.000000+00	0.000000+00	0.000000+00	0.000000+00	0.000000+00	0.000000+00													

ORDRE DES CUNIKAINIL 5 6 7 8 9 10 11 12 13 14 15

VARIABLES D ECART

VARIABLES ARTIFICIELLES

CONTRAINTE 1	X( 14)	0.147510212659150+04	X( 20)	0.000000000000000D+00
CONTRAINTE 2	X( 15)	0.000000000000000+00	X( 21)	0.000000000000000D+00
CONTRAINTE 3	X( 16)	0.26577004720092D+00	X( 22)	0.000000000000000D+00
CONTRAINTE 4	X( 17)	0.000000000000000+00	X( 23)	-0.17041343054913D-04
CONTRAINTE 5	X( 18)	0.23270733803660D+02	X( 24)	0.000000000000000D+00
CONTRAINTE 6	X( 19)	0.67290661983319D+01	X( 25)	0.000000000000000D+00
CONTRAINTE 7			X( 26)	0.000000000000000D+00
CONTRAINTE 8			X( 27)	0.000000000000000D+00
CONTRAINTE 9			X( 28)	0.000000000000000D+00
CONTRAINTE 10				
CONTRAINTE 11				
CONTRAINTE 12				
CONTRAINTE 13				
CONTRAINTE 14				
CONTRAINTE 15				

COGENERATION PROBLEME  
REMARK DAY 5TH APRIL NORMAL RUN

COST OF MATERIAL

FUEL COST (BATH/LITRE)	2.620	ELECTRIC CCST (9BATH/KWH)	1.430
CH; COST OF BOILER FLEU WATER	BATH/LITRE	10.000	
CS; COST OF 17K STEAM FOR SALE	BATH/LITRE	-122.878	
CB; COST OF 3K BLOW SILAM	BATH/LITRE	79.962	

PROCESS REQUIREMENT

TOTAL REQUIREMENT OF ELECTRIC	KWH	12000.000
TOTAL REQUIREMENT OF SILAM	T/H	60.200
CONDENSATE WATER	T/H	35.000
STEAM FOR SALE	T/H	6.000

SUMMARY OF INDEPENDENT VARIABLE

BOILER LOAD	T/H AT 100 KG/CY**2	74.992
PRODUCED ELECTRIC	KWH	8060.858
3K BLOW STEAM	T/HR	0.000
PURCHASE ELECTRIC	KWH	3939.102
ABUS ELECTRIC	KWH	2463.000
FUEL OIL CONSUMPTION	L/H	5330.000
BOILER FEED WATER	T/H	28.724
DESUPERHEAT WATER	T/H	9.406
17K STEAM GENERATION	T/H	33.607
3K STEAM GENERATION	T/H	26.513

INTERESTING VARIABLE  
 TURBINE AND GENERATOR EFFICIENCY 0.982  
 17K PROCESS REQUIREMENT T/H 28.000  
 3K PROCESS REQUIREMENT T/H 32.200  
 17K HOUSE SERVICE T/H 6.855  
 3K HOUSE SERVICE T/H 11.299  
 BUSTIE-ELECTRIC KWH 1476.102  
 BBUS ELECTRIC KWH 5537.000

INTERESTING HEAT BALANCE  
 OBJECTIVE FUNCTION VALUE  
 FUEL COST BATH/HK 13964.559  
 ELECTRIC COST BATH/HR 5664.428  
 BOILER FEED WATER COST BATH/HK 287.237  
 SALE STEAM COST BATH/HR 737.268  
 3K BLOW STEAM COST BATH/HR 0.000  
 TOTAL COST BATH/HK 15178.995

HEAT AND MASS BALANCE

POINT	DESCRIPTION	UNIT	VALUE	% RELATIVE ERROR
POINT 1.	MASS BALANCE AROUND BIG LOOP	T/H	78.398	-0.000
SUM OF MASS IN		T/H	78.398	
HEAT BALANCE AROUND BIG LOOP		KCAL/H	600300+00	0.566
SUM OF HEAT IN		KCAL/H	600300+00	
SUM OF MASS OUT		T/H	78.398	
SUM OF HEAT OUT		KCAL/H	600300+00	
POINT 2.	MASS BALANCE AROUND TURBOGENERATOR	T/H	74.492	0.000
SUM OF MASS IN		T/H	74.492	
HEAT BALANCE AROUND TURBOGENERATOR		KCAL/H	600760+00	0.021
SUM OF HEAT IN		KCAL/H	600760+00	
SUM OF MASS OUT		T/H	74.492	
SUM OF HEAT OUT		KCAL/H	600760+00	
POINT 3.	MASS BALANCE AT DESUP POINT OF 3K	T/H	37.812	-0.000
SUM OF MASS IN		T/H	37.812	
HEAT BALANCE AT DESUP POINT OF 3K		KCAL/H	255230+00	0.000
SUM OF HEAT IN		KCAL/H	255230+00	
SUM OF MASS OUT		T/H	37.812	
SUM OF HEAT OUT		KCAL/H	255230+00	
POINT 4.	MASS BALANCE AT DESUP POINT OF 17K	T/H	40.586	-0.000
SUM OF MASS IN		T/H	40.586	
HEAT BALANCE AT DESUP POINT OF 17K		KCAL/H	280+50+00	0.000
SUM OF HEAT IN		KCAL/H	280+50+00	
FUEL FUE2		KCAL/H	1.040	
POINT 5.	MASS BALANCE AT SECOND LOOP	T/H	78.398	-0.000
SUM OF MASS IN		T/H	78.398	
HEAT BALANCE AT SEPARATE OF DECAL		KCAL/H	612000+00	-0.519
SUM OF HEAT IN		KCAL/H	612000+00	
SUM OF MASS OUT		T/H	78.398	
SUM OF HEAT OUT		KCAL/H	612000+00	

POINT 6. MASS BALANCE AT DESUP AND TP  
 SUM OF MASS IN 1.907 T/H  
 HEAT BALANCE AT DESUP AND BP 3.307 T/H % RELATIVE ERROR -0.000  
 SUM OF HEAT IN .52730+06 KCAL/H  
 BP1=0.065 BP=0.431 C1=2.770 SUM OF HEAT OUT .554730+06 KCAL/H % RELATIVE ERROR 0.000  
 D2=0.636

POINT 7. MASS BALANCE AT BL AND BP  
 SUM OF MASS IN 74.992 T/H  
 HEAT BALANCE AT BL AND BP 74.992 T/H % RELATIVE ERROR 0.000  
 SUM OF HEAT IN .604920+03 KCAL/H  
 SUM OF HEAT OUT .604920+03 KCAL/H % RELATIVE ERROR 0.000

POINT 8. MASS BALANCE AT SEPAKATE OF 17K  
 SUM OF MASS IN 40.586 T/H  
 HEAT BALANCE AT SEPAKATE OF 17K 40.586 T/H % RELATIVE ERROR -0.000  
 SUM OF HEAT IN .280450+03 KCAL/H  
 SUM OF HEAT OUT .280450+03 KCAL/H % RELATIVE ERROR -0.000

POINT 9. MASS BALANCE AT SEPAKATE OF 3K  
 SUM OF MASS IN 37.812 T/H  
 HEAT BALANCE AT SEPAKATE OF 3K 37.812 T/H % RELATIVE ERROR -0.000  
 SUM OF HEAT IN .255230+08 KCAL/H  
 SUM OF HEAT OUT .255230+08 KCAL/H % RELATIVE ERROR -0.000

POINT 10. MASS BALANCE AT ELCH 3K  
 SUM OF MASS IN 36.772 T/H  
 HEAT BALANCE AT SEPAKATE OF 3K 36.772 T/H % RELATIVE ERROR 0.000  
 SUM OF HEAT IN .253750+08 KCAL/H  
 SUM OF HEAT OUT .253750+08 KCAL/H % RELATIVE ERROR 0.000

POINT 11. MASS BALANCE AT 17K TO AT  
 XINHPH= 6.889 T/H  
 FLAT= 0.010  
 SUM OF MASS IN 6.899 T/H  
 HEAT BALANCE AT 17K TO AT 6.899 T/H % RELATIVE ERROR 0.000  
 SUM OF HEAT IN .470740+07 KCAL/H  
 SUM OF HEAT OUT .470740+07 KCAL/H % RELATIVE ERROR 0.000

POINT 12. MASS BALANCE AT 3K TO DT  
 TOFUH= .141610+00  
 TOAPH= .262210+01  
 TODT = .853530+01  
 SUM OF MASS IN 11.299 T/H  
 HEAT BALANCE AT 3K TO DT 11.299 T/H % RELATIVE ERROR 0.000  
 SUM OF HEAT IN .762030+07 KCAL/H  
 SUM OF HEAT OUT .762030+07 KCAL/H % RELATIVE ERROR 0.000

POINT 13. MASS BALANCE AT 3K TO FOH  
 SUM OF MASS IN 2.764 T/H  
 HEAT BALANCE AT 3K TO DT 2.764 T/H % RELATIVE ERROR 0.000  
 SUM OF HEAT IN .180550+07 KCAL/H  
 SUM OF HEAT OUT .180550+07 KCAL/H % RELATIVE ERROR 0.000

POINT 14. MASS BALANCE AT LGHER LCOP  
 SUM OF MASS IN 81.712 T/H  
 HEAT BALANCE AT LGHER LCOP 81.712 T/H % RELATIVE ERROR 0.000  
 SUM OF HEAT IN .107400+03 KCAL/H  
 SUM OF HEAT OUT .107400+03 KCAL/H % RELATIVE ERROR 0.000





APPENDIX D  
THE LISTED SUBROUTINES

Subroutines for cogeneration problem in a synthetic fibre plant is shown as follows.

1 \*\*\*\*\*PROGRAM AFTER THIS LINE IS PUT BY USER  
 2 \*\*\*\*\*WITH NUMERICAL DIFFERENTIATE; FIRST DATE 24 MAY 1988  
 3 \*\*\*\*\*THIS IS SUBPROGRAM FOR TEJIN CO., COGENERATION PROBLEM  
 4 \*\*\*\*\*SUBR.A 13 VARIABLE 9 EQUALITY CONSTRAINTS/MODEL OF FACTORY  
 5 \*\*\*\*\*COMPLETE 5 AUG 1988 2 INEQUALITY CONSTRAINTS  
 6 \*\*\*\*\*P1K AND P3K ARE VARIABLE

7 SUBROUTINE PHIX  
 8 IMPLICIT REAL\*8 (A-D,F-H,O-Z)  
 9 REAL \*4 PC  
 10 DIMENSION XC(150), XI(150), XS(150), C(150), VC(50)  
 11 DIMENSION X(150)  
 12 DIMENSION A(50,100), ALFA(50,50)  
 13 DIMENSION TCAST(50), TCF(50), IMJ(100), VC(50), IVAT(50)  
 14 COMMON/GREGO/NLV, NTO, ITET, ICDNJ, IDIAG, ITHA, KFIL, KLIM, NU, IISON  
 15 COMMON/GREG1/ISOLSR, EPSIL, EPSILO, EPSIL1, EPSIL2, PC  
 16 COMMON/GREG2/XC, XI, XS, C, VC  
 17 COMMON/GREG3/X, PHI, NV, NIN, NEG, MC  
 18 COMMON/GREG4/A, ALFA, IBA, Y, IHD, IVC, IVA  
 19 COMMON/GREG5/IVB, IVK, IVT, IVV, IVW, IVX, IVY, IVZ, IVAA, IVAB, IVAC, IVAD, IVAE, IVAF, IVAG, IVAH, IVAI, IVAJ, IVAK, IVAL, IVAM, IVAN, IVAO, IVAP, IVAQ, IVAR, IVAS, IVAT, IVAU, IVAV, IVAW, IVAX, IVAY, IVAZ, IVBA, IVBB, IVBC, IVBD, IVBE, IVBF, IVBG, IVBH, IVBI, IVBJ, IVBK, IVBL, IVBM, IVBN, IVBO, IVBP, IVBQ, IVBR, IVBS, IVBT, IVBU, IVBV, IVBW, IVBX, IVBY, IVBZ, IVCA, IVCB, IVCC, IVCD, IVCE, IVCF, IVCG, IVCH, IVCI, IVCJ, IVCK, IVCL, IVCM, IVCN, IVCO, IVCP, IVCQ, IVCR, IVCS, IVCT, IVCU, IVCV, IVCW, IVCX, IVCY, IVCZ, IVDA, IVDB, IVDC, IVDD, IVDE, IVDF, IVDG, IVDH, IVDI, IVDJ, IVDK, IVDL, IVDM, IVDN, IVDO, IVDP, IVDQ, IVDR, IVDS, IVDT, IVDU, IVDV, IVDW, IVDX, IVDY, IVDZ, IVEA, IVEB, IVEC, IVED, IVEF, IVEG, IVEH, IVEI, IV EJ, IV EK, IV EL, IV EM, IV EN, IV EO, IV EP, IV EQ, IV ER, IV ES, IV ET, IV EU, IV EV, IV EW, IV EX, IV EY, IV EZ, IVFA, IVFB, IVFC, IVFD, IVFE, IVFF, IVFG, IVFH, IVFI, IVFJ, IVFK, IVFL, IVFM, IVFN, IVFO, IVFP, IVFQ, IVFR, IVFS, IVFT, IVFU, IVFV, IVFW, IVFX, IVFY, IVFZ, IVGA, IVGB, IVGC, IVGD, IVGE, IVGF, IVGG, IVGH, IVGI, IVGJ, IVGK, IVGL, IVGM, IVGN, IVGO, IVGP, IVGQ, IVGR, IVGS, IVGT, IVGU, IVGV, IVGW, IVGX, IVGY, IVGZ, IVHA, IVHB, IVHC, IVHD, IVHE, IVHF, IVHG, IVHH, IVHI, IVHJ, IVHK, IVHL, IVHM, IVHN, IVHO, IVHP, IVHQ, IVHR, IVHS, IVHT, IVHU, IVHV, IVHW, IVHX, IVHY, IVHZ, IVIA, IVIB, IVIC, IVID, IVIE, IVIF, IVIG, IVIH, IVII, IVIJ, IVIK, IVIL, IVIM, IVIN, IVIO, IVIP, IVIQ, IVIR, IVIS, IVIT, IVIU, IVIV, IVIW, IVIX, IVIY, IVIZ, IVJA, IVJB, IVJC, IVJD, IVJE, IVJF, IVJG, IVJH, IVJI, IVJK, IVJL, IVJM, IVJN, IVJO, IVJP, IVJQ, IVJR, IVJS, IVJT, IVJU, IVJV, IVJW, IVJX, IVJY, IVJZ, IVKA, IVKB, IVKC, IVKD, IVKE, IVKF, IVKG, IVKH, IVKI, IVKL, IVKM, IVKN, IVKO, IVKP, IVKQ, IVKR, IVKS, IVKT, IVKU, IVKV, IVKW, IVKX, IVKY, IVKZ, IVLA, IVLB, IVLC, IVLD, IVLE, IVLF, IVLG, IVLH, IVLI, IVLJ, IVLK, IVLL, IVLM, IVLN, IVLO, IVLP, IVLQ, IVLR, IVLS, IVLT, IVLU, IVLV, IVLW, IVLX, IVLY, IVLZ, IVMA, IVMB, IVMC, IVMD, IVME, IVMF, IVMG, IVMH, IVMI, IVMJ, IVMK, IVML, IVMN, IVMO, IVMP, IVMQ, IVMR, IVMS, IVMT, IVMU, IVMV, IVMW, IVMX, IVMY, IVMZ, IVNA, IVNB, IVNC, IVND, IVNE, IVNF, IVNG, IVNH, IVNI, IVNJ, IVNK, IVNL, IVNO, IVNP, IVNQ, IVNR, IVNS, IVNT, IVNU, IVNV, IVNW, IVNX, IVNY, IVNZ, IVOA, IVOB, IVOC, IVOD, IVOE, IVOF, IVOG, IVOH, IVOI, IVOJ, IVOK, IVOL, IVOM, IVON, IVOP, IVOQ, IVOR, IVOS, IVOT, IVOU, IVOV, IVOW, IVOX, IVOY, IVOZ, IVPA, IVPB, IVPC, IVPD, IVPE, IVPF, IVPG, IVPH, IVPI, IVPJ, IVPK, IVPL, IVPM, IVPN, IVPO, IVPP, IVPQ, IVPR, IVPS, IVPT, IVPU, IVPV, IVPW, IVPX, IVPY, IVPZ, IVQA, IVQB, IVQC, IVQD, IVQE, IVQF, IVQG, IVQH, IVQI, IVQJ, IVQK, IVQL, IVQM, IVQN, IVQO, IVQP, IVQQ, IVQR, IVQS, IVQT, IVQU, IVQV, IVQW, IVQX, IVQY, IVQZ, IVRA, IVRB, IVRC, IVRD, IVRE, IVRF, IVRG, IVRH, IVRI, IVRJ, IVRK, IVRL, IVRM, IVRN, IVRO, IVRP, IVRQ, IVRR, IVRS, IVRT, IVRU, IVRV, IVRW, IVRX, IVRY, IVRZ, IVSA, IVSB, IVSC, IVSD, IVSE, IVSF, IVSG, IVSH, IVSI, IVSJ, IVSK, IVSL, IVSM, IVSN, IVSO, IVSP, IVSQ, IVSR, IVSS, IVST, IVSU, IVSV, IVSW, IVSX, IVSY, IVSZ, IVTA, IVTB, IVTC, IVTD, IVTE, IVTF, IVTG, IVTH, IVTI, IVTJ, IVTK, IVTL, IVTM, IVTN, IVTO, IVTP, IVTQ, IVTR, IVTS, IVTT, IVTU, IVTV, IVTW, IVTX, IVTY, IVTZ, IVUA, IVUB, IVUC, IVUD, IVUE, IVUF, IVUG, IVUH, IVUI, IVUJ, IVUK, IVUL, IVUM, IVUN, IVUO, IVUP, IVUQ, IVUR, IVUS, IVUT, IVUU, IVUV, IVUW, IVUX, IVUY, IVUZ, IVVA, IVVB, IVVC, IVVD, IVVE, IVVF, IVVG, IVVH, IVVI, IVVJ, IVVK, IVVL, IVVM, IVVN, IVVO, IVVP, IVVQ, IVVR, IVVS, IVVT, IVVU, IVVV, IVVW, IVVX, IVVY, IVVZ, IVWA, IVWB, IVWC, IVWD, IVWE, IVWF, IVWG, IVWH, IVWI, IVWJ, IVWK, IVWL, IVWM, IVWN, IVWO, IVWP, IVWQ, IVWR, IVWS, IVWT, IVWU, IVWV, IVWW, IVWX, IVWY, IVWZ, IVXA, IVXB, IVXC, IVXD, IVXE, IVXF, IVXG, IVXH, IVXI, IVXJ, IVXK, IVXL, IVXM, IVXN, IVXO, IVXP, IVXQ, IVXR, IVXS, IVXT, IVXU, IVXV, IVXW, IVXZ, IVYA, IVYB, IVYC, IVYD, IVYE, IVYF, IVYG, IVYH, IVYI, IVYJ, IVYK, IVYL, IVYM, IVYN, IVYO, IVYP, IVYQ, IVYR, IVYS, IVYT, IVYU, IVYV, IVYW, IVYX, IVYY, IVYZ, IVZA, IVZB, IVZC, IVZD, IVZE, IVZF, IVZG, IVZH, IVZI, IVZJ, IVZK, IVZL, IVZM, IVZN, IVZO, IVZP, IVZQ, IVZR, IVZS, IVZT, IVZU, IVZV, IVZW, IVZX, IVZY, IVZZ

25 C FUEL OIL COST PLUS PURCHASED ELECTRICAL COST

26 L  
 27 CFE1 DATA CF/2.58/CE/1.544/  
 28 CFE2 DATA CF/2.94/CE/1.438/  
 29 CFE3 DATA CF/3.01/CE/1.438/  
 30 CC DATA CF/1.5C/LE/1.438/  
 31 DATA CF/2.620/CE/1.438/  
 32 C

33 DATA CW/10.00/FS/6.0/  
 34 CC DATA LW/0.0L/FS/6.0/CS/0.0/CM/0.0/  
 35 CS=40.90\*CF  
 36 CC CS=40.90\*CF  
 37 CB=30.52\*CF

38 C CW AS COST OF MAKE-UP WATER (B/T)  
 39 C CW LS COST OF FUEL OIL (3/L)  
 40 C LE LS COST OF PURCHASED ELECTRIC (B/KW)  
 41 C LS LS COST OF SELLING STEAM (D/T)  
 42 C FS STEAM TO SELL (T/HP)  
 43 C WS AS COST OF 3K DLGH STEAM (B/T)

44 C  
 45 C  
 46 C TOTAL COST = MAKE-UP WATER COST + FUEL COST  
 47 C +PURCHASED ELECTRIC COST  
 48 C +3K DLGH STEAM COST - STEAM SELL PRICE  
 49 C

PHI = -(CW\*XC(7)+CF\*XC(8)+CE\*XC(4))-CS\*FS+CB\*XC(3)  
 RETURN  
 END  
 SUBROUTINE GRADFI  
 IMPLICIT REAL\*8 (A-D,F-H,O-Z)  
 REAL \*4 PC  
 DIMENSION XC(150), XI(150), XS(150), C(150), VC(50)  
 DIMENSION X(150)

58 DIMENSION A(50,100),ALFA(50,50)  
59 DIMENSION IBAS(50),Y(150),IHJ(100),IVC(50),IVA(100)  
60 CUMHJN/GREGO/NEVL,HTO,ITET,ICONJ,IDIAG,ITHAX,KFIL,KLID,NGU,ITSOR  
61 CUMHJN/GREGI/ISOLSR,EPSIL,EPSSILO,EPSSIL2,PC  
62 CUMHJN/GREG2/XL,XI,XS,C,VC  
63 CUMHJN/GREG3/X,PHI,MV,MEN,NEG,NC  
64 CUMHJN/GREG4/ALFA,IBAS,Y,IHJ,IVC,IVA  
65 CUMHJN/GREG5/IVB,NK,NTV,NV1,NEV,MINI,MIN2,MIN3,NI,N4,NVINI,NI,YSORT  
66 CUMHJN/GREG6/HVINI2,MVINI3,INDEX,II,IP,IRI,IS,ISL,IT,IBP,ICD9,LC  
67 CUMHJN/GREG7/JCDB,KCDB,KREN,KO,FIL,PSI,PSI2,IB,IC,TU,KFOAL,KGRAD  
68 CUMHJN/GREG8/KLONT,KINVI,KINV2,KCDBA,KJACO,KMAX1,KMAX2,KKENI,JKO  
69 CUMHJN/GREG9/KKEN2,KINV,KCDBA1,KREN1,KREN2,IDIREL,DELTFI,ETA  
70  
71 JATA CF/2.56/CE/1.544/  
72 JATA CF/2.94/CE/1.438/  
73 JATA CF/3.01/CE/1.438/  
74 JATA CF/1.50/CE/1.438/  
75 JATA CF/2.620/CL/1.438/  
76  
77 JATA CH/10.CG/FS/6.0/  
78 JATA CH/0.0C/FS/6.0/CS/3.0/CD/0.0/  
79 CS=40.90\*CF  
80 CS=110.0  
81 CS=30.52\*LF  
82  
83 C(1)=0.0  
84 C(2)=0.0  
85 C(3)=-Cb  
86 C(4)=-CL  
87 C(5)=0.  
88 C(6)=CF  
89 C(7)=-Ch  
90 C(9)=0.  
91 C(10)=0.  
92 C(11)=0.  
93 C(12)=0.  
94 C(13)=0.  
95 RLTOJN  
96 LNU  
97 SUKJUTIME LPHI  
98 INPLICIT REAL\*8 (A=0,F=H,0=Z)  
99 KLAB \*4 PC  
100 DIMENSION XC(150),XI(150),XS(150),C(150),VC(150)  
101 DIMENSION X(150)  
102 DIMENSION A(50,100),ALFA(50,50)  
103 DIMENSION IBAS(50),Y(150),IHJ(100),IVC(50),IVA(100)  
104 CUMHJN/GREGO/NEVL,HTO,ITET,ICONJ,IDIAG,ITHAX,KFIL,KLID,NGU,ITSOR  
105 CUMHJN/GREG1/ISOLSR,EPSIL,EPSSILO,EPSSIL2,PC  
106 CUMHJN/GREG2/XL,XI,XS,C,VC  
107 CUMHJN/GREG3/X,PHI,MV,MEN,NEG,NC  
108 CUMHJN/GREG4/ALFA,IBAS,Y,IHJ,IVC,IVA  
109 CUMHJN/GREG5/IVB,NK,NTV,NV1,NEV,MINI,MIN2,MIN3,NI,N4,NVINI,NI,YSORT  
110 CUMHJN/GREG6/HVINI2,MVINI3,INDEX,II,IP,IRI,IS,ISL,IT,IBP,ICD9,LC  
111 CUMHJN/GREG7/JCDB,KCDB,KREN,KO,FIL,PSI,PSI2,IB,IC,TU,KFOAL,KGRAD  
112 CUMHJN/GREG8/KLONT,KINVI,KINV2,KCDBA,KJACO,KMAX1,KMAX2,KKENI,JKO  
113 CUMHJN/GREG9/KKEN2,KINV,KCDBA1,KREN1,KREN2,IDIREL,DELTFI,ETA  
114

115 DATA 7/11000.0/0.1717K/28.333/0.33K/33.16/  
 116 DATA P TOTAL/52.0/0.00N/35.00/  
 117 C  
 118 DATA KA/O.566/RU/O.392/0.00/O.12/0.0E/L.0/  
 119 DATA I SUP/500.0/  
 120 C

121 C PELTSTER PLANT

122 C VARIABLE = DESCRIPTION(UNITS)  
 123 C XL(1) BOILER LOAD (T/H) AT 100 KG/CY\*\*2 (KPH)  
 124 C XL(2) ELECTRIC GENERATION (T/HR)  
 125 C XL(3) 3K DUM STEAM (KWH)  
 126 C XL(4) PURCHASED ELECTRIC (KWH)  
 127 C XL(5) ABUS-ELECTRIC (KWH)  
 128 C XL(6) FUEL OIL CONSUMPTION (L/H)  
 129 C XL(7) MAKE-UP WATER (T/HR)  
 130 C XL(8) DESUPERHEAT WATER (T/HR)  
 131 C XL(9) 17K STEAM GENERATION (T/H)  
 132 C XL(10) 3K STEAM GENERATION (T/H)  
 133 C XL(11) 17K THROUGH-17PH (T/H)  
 134 C XL(12) TEMP OF WATER FROM DFP ( C )  
 135 C XL(13) TEMP OF CONDENSATE ( C )  
 136 C DEFINITION OF CONSTANTS  
 137 C

138 L AB TOTAL REQUIREMENT OF ELECTRIC LOAD (KA)  
139 C P17AL TOTAL REQUIREMENT OF STEAM-ELECTRIC LOAD (T/H)

140 C P17K 17K WORK PROCESS(T/H)  
 141 C P3K 3K WORK PROCESS(T/H)  
 142 C CUN CONDENSATE WATER RECOVER  
 143 C  
 144 C ENTHALPY OF EACH POINT  
 145 EN1 = 577.714\*TSUP+513866  
 146 L12 = 691600  
 147 EN3 = 727.5\*TSUP+326323  
 148 EN4 = 675000  
 149 EN5 = 142000  
 150 EN6 = 700.0\*TSUP+456543  
 151 C

CPVAL = 0.556  
 CPAIR = 0.237  
 UEMAK = 1.25  
 JENVAL = 0.9465  
 HL = 9300

157 TUF31 = (CPVAL\*(90-60)\*XC(16)+JENVAL)/(EN4-100000)  
 158 TUAPH = CPAIR\*(122-35)\*13.19\*JENVAL\*(XC(16)+JENVAL/EN4  
 159 TOUT = R0\*XC(11)+2.3\*TCFO1-TOAP1  
 160 C

161 AL = 1-KC\*(EN2-EN5)/(EN1-EN5)-R0\*(EN4-EN5)/(EN3-EN5)  
 162 AC = (EN6-RU\*(L11+EN2-EN5))/(EN1-EN5)-R0\*(EN4-EN5)/(EN3-EN5)/AL  
 163 C

164 C THIS IS ANEQUALITY CONSTRAINT VC(11).LE.0  
 165 C ELECTRIC BALANCE  
 166 C PURCHASE ELECTRIC = 17K3 ELECTRIC + GUSTYLE ELECTRIC  
 167 C

168 C  
 169 C THIS IS ANEQUALITY CONSTRAINT VC(17).LE.0  
 170 C DESUP.ALL.DECAL  
 171 V.(12) = X.(10)\*0.5 - ((EN1-EN2)/(EN1-EN5))\*(XC(10)+AL\*(XC(11)))

172 C  $S = (EN3 - EN4) / (EN3 - EN5) * (XC(11) + RD * XC(17) + 2 * J * RC)$

173 C

174 C \* THIS IS INEQUALITY CONSTRAIN VC(3).LE.0

175 C  $TOT = UT * 0.04 * RC * XC(1)$

176 C  $VL(1) = 0.90 * KC * XC(1) - XC(11)$

177 C

178 C  $TOT * 0.01$

179 C  $V_0(4) = 0.01 * XC(11) - RC * XC(1)$

180 C

181 C  $V_0(1) = 140 - ((CUN * XC(7) * XC(11)) + TOT)$

182 C  $S * EN3 - ((CON * XC(7)) * XC(12) * 1000 + TOT * EN4) / XC(11) * 1.0E-3$

183 C

184 C

185 C  $TOUTHP = UT * GT * 174 * VC(6).LE.0$

186 C  $VL(6) = -170 * ((CON * XC(7)) * XC(11) * TOT)$

187 C  $S * L * W - ((CUN * XC(7)) * XC(12) * 1000 + TOT * EN4) / XC(11) * 1.0E-3$

188 C

189 C  $HLAT$  BALANCE AROUND TURBINE

190 C  $V - 177 = (XC(7) * 360) - (17 * 170 * 99 * XC(2) * 1.7 * J) + (17 * 170 * 99 * XC(2) * 1.7 * J) * (17 * 170 * 99 * XC(2) * 1.7 * J)$

191 C  $S - ((EN4 - EN1) / (EN2 - EN3)) * ((EN2 - EN1) / (EN1 - EN5)) * XC(9)$

192 C  $S - ((EN4 - EN5) / (EN3 - EN5)) * (XC(10) * 2.3 * RC) - XC(3)$

193 C

194 C  $PP$  ADJUSTED ELECTRIC + PURCHASED ELECTRIC = GIVEN ELECTRICAL LOAD

195 C  $VL(10) = XC(2) * XL(4) - A3$

196 C

197 C  $UIL$  CONSUMPTION AND STEAM PRODUCED

198 C

199 C  $VL(19) = XC(6) - (XC(11) * 1000) / (13.9190 + (XC(11) * 45) * 5E-03)$

200 C

201 C  $CALCULATION$  OF MILLER LOAD

202 C  $STEAM$  FROM BOILER + WATER FOR DESUP HEAT = 17K TO PROCESS

203 C + 3K TO PROCESS + 3K BLOW OFF + 17K HOUSE SERVICE + 3K HOUSE SERVICE

204 C

205 C

206 C  $VL(13) = XC(15) + XC(10) + XC(3) + RC * XC(11) + (RD * XC(11) * 2.3 * RE) - (XC(1) - XC(8))$

207 C

208 C  $WATER$  MASS BALANCE AROUND HPH AND DT

209 C

210 C  $IN$  HPH + 3K HOUSE SERVICE + DFW + CON = BOILER INLET + DESUP

211 C + TUFOH + TOAPH

212 C  $VL(14) = XC(11) + (RD * XC(11) * 2.3 * RE) + XC(17) + CON$

213 C + 1.04 \* XC(11) - XC(10) - (CPJIL \* 190 - 60) \* XC(6) \* DENHIL / (EN4 - 100000)

214 C  $S - CPATR * (122 - 35) * 13.17 * DENAIR * XC(5) * DENHIL / EN4$

215 C

216 C  $OVERALL$  WATER BALANCE

217 C  $BF + CON - FCH + API + AT + B3 + HS + LS + B5$

218 C

219 C

220 C  $VL(11) = CPATR * (122 - 35) * 13.17 * DENAIR * XC(6) * DENHIL / EN4$

221 C + (CPJIL \* 190 - 60) \* XC(5) \* DENHIL / (EN4 - 100000)

222 C  $S * KC * XC(11) - XC(11) * 0.01 * XC(11) * XC(9) + XC(17) * XC(17) - XC(17) - CON$

223 C  $STEAM$  REQUIRED IN PROCESS

224 C  $17K$  STEAM + 3K STEAM = STEAM REQUIREMENT

225 C  $VL(15) = XC(5) * XC(10) - PJTAL$

226 C  $HEAT$  BALANCE AROUND HPH, JEP AND DT

227 C  $HEAT$  FROM TURPH + HEAT FROM TOT + HEAT FROM PH = HEAT OF BOILER INLET

228 C  $VL(16) = EX(11) * FN2 + (RD * XC(11) * 2.3 * RE) * FN4$

229	C	3-CH4*(CPULL*(90-60)*XC(5)+DENHIL)/(E*14-13000)	
230	C	3-PAIR*(122-35)*13.19*DENAIR*(C(6)+DENHIL)	
231	C	3*LUY*(X(7)+X(12)+1000-1.0)*XC(1)*.1956-XC(8)*LNS)*+.01E-07	
232	C	HEAT BALANCE AFLUO PIT AND OFF	
233	C	HEAT FROM CON + HEAT FROM PAT= HEAT OUT	
234	C	VC(L2)=(CON*(13)+103C	
235	C	3*XC(7)*0.03E6*(CON*(13)+103C)*1.0E-07	
236	C	KL1UKV	
237	C	LND	
238	C	SJOKJTIME (P(L,V)	
239	C	IMPLICIT REAL*8 (A-D,F-H,I)-Z1	
240	C	REAL *4 PC	
241	C	DIMENSION Z(1),V(1)	
242	C		
243	C	DATA AR/11000.0/P17K/20.03/P3K/33.16/	
244	C	DATA PTOTAL/62.0/CON/35.00/	
245	C		
246	C	DATA KA/C.586/R.0.092/RD/0.12/RE/L.0/	
247	C	DATA TSUP/500.0/	
248	C	PULVERIZER PLANT	
249	C	VARIABLE = DESCRIPTOR(UHITS)	
250	C	BOILER LOAD (T/H) AT 130 KG/C4**2	
251	C	Z(1) ELECTRIC GENERATION (KWH)	
252	C	Z(2) 3K BLEND STEAM (T/H)	
253	C	Z(3) PULVERIZED ELECTRIC (KWH)	
254	C	Z(4) ABUS ELECTRIC (KWH)	
255	C	Z(5) FUEL LIL CONSUMPTION (L/H)	
256	C	Z(6) BOILER FLEW WATER (T/HR)	
257	C	Z(7) DESUPHEAT WATER (T/HR)	
258	C	Z(8) 17K STEAM GENERATION (T/H)	
259	C	Z(9) 3K STEAM GENERATION (T/H)	
260	C	Z(10) 17K THROUGH HPH (T/H)	
261	C	Z(11) TLPP LF WATER FROG JFP ( C )	
262	C	Z(12) TEMP OF CONDENSATE ( C )	
263	C	Z(13) TEMP OF CONDENSATE ( C )	
264	C	DEFINITION OF CONSTANTS	
265	C		
266	C	TOTAL REQUIREMENT OF ELECTRIC LOAD (KW)	
267	C	TOTAL REQUIREMENT OF STEAM ELECTRIC LOAD (T/H)	
268	C	17K WORK PROCESS(T/H)	
269	C	3K WORK PROCESS(T/H)	
270	C	CONDENSATE WATER RECOVER	
271	C		
272	C	ENTHALPY OF EACH POINT	
273	C	LH1 = 437.714*TSUP+513860	
274	C	LH2 = 0.71*CO	
275	C	LH3 = 727.5*TSUP+326323	
276	C	LH4 = 675000	
277	C	LH5 = 142000	
278	C	LH6 = 700.0*TSUP+45566.3	
279	C		
280	C	WPU = 0.536	
281	C	WPAI = 0.237	
282	C	WUWA = 1.25	
283	C	DENHIL = 0.9405	
284	C	1*PUL = (CPULL*(90-60)*XC(5)+DENHIL)/(E*14-10000)	
285	C	T*PAIR = (122-35)*13.19*DENAIR*(C(6)+DENHIL)	

286 C TOUT=RD\*Z(1)+Z(3)-TOF0H-TOAPH

287 C  
288 C A1=1-3C\*(EN2-EN5)/(EN1-EN5)-R7\*(LN4-EN5)/(EN3-LN5)  
289 C A2=(LN6-KC\*U11+EN2-EN5)/(EN1-EN5)-RD\*EN3\*(EN4-EN5)/(EN3-LN5)/A1

290 C  
291 C \*THIS IS INEQUALITY CONSTRAINT V(1),LE.0  
292 C ELECTRIC BALANCE

293 C PURCHASED ELECTRIC =AUS ELECTRIC + DUSTILE ELECTRIC  
294 C V(1)=-Z(4)+Z(5)

295 C  
296 C ULSUP=L.UECAL

297 C V(2)-Z(6)+C.5-(L\*U1-LN2)/(EN1-EN5)+Z(7)+K\*Z(11)  
298 C \*THIS IS INEQUALITY CONSTRAINT V(1),LE.0

299 C  
300 C \*THIS IS INEQUALITY CONSTRAINT V(1),LE.0

301 C TOUT=UT.GT.0.04\*RC\*(1)  
302 C V(3)=U.96\*KL\*Z(11)-Z(11)

303 C  
304 C TOUT=UT.GT.0.01

305 C V(4)=L.01+Z(11)-K\*Z(11)

306 C  
307 C V(5)=14C-(1+CON\*Z(7)+Z(11)+TOUT)  
308 C \*RD-(1+CON\*Z(7)+Z(11)+1000+TOUT\*EN4)/Z(11)+1.0E-5

309 C  
310 C V(6)=-170+(1+CON\*Z(7)+Z(11)+TOUT)  
311 C \*LN2-(1+CON\*Z(7)+Z(11)+1000+TOUT\*EN4)/Z(11)+1.0E-5

312 C  
313 C HEAT-BALANCE FURNACE TURBINE  
314 C V(7)=Z(12)+600\*(1+(1.099+Z(12))\*1.95)/((1+(A2-EN3))  
315 C \*(1+(A2-EN3))/(A2-EN3))\*(EN2-EN5)/(EN1-EN5)+Z(9)  
316 C \*(1+(EN4-LN5)/(EN3-EN5))\*Z(10)+2.3\*REF-Z(3)

317 C  
318 C PURCHASED ELECTRIC + PURCHASED ELECTRIC = GIVEN ELECTRIC LOAD  
319 C V(8)=Z(12)+Z(4)-A9

320 C  
321 C UTIL CONSUMPTION AND STEAM PRODUCED

322 C V(9)=Z(17)+1000/T(3.5173+Z(11)+55)\*5E-0377

323 C  
324 C CALCULATION OF MILLER LOAD  
325 C STEAM FROM BOILER + WATER FJK DESUPERHEAT = 17K TO PROCESS  
326 C + 3K TO PROCESS +JK BLOW OFF +17K HOUSE SERVICE +JK HOJSL SERVICE

327 C  
328 C V(10)=-Z(5)+Z(10)+Z(3)+K\*Z(11)+(K0\*Z(11)+2.3\*RE)-Z(11)-Z(8)

329 C  
330 C 10 MPH +3K HOUSE SERVICE +DFH +CO1 = MILLER INLET +ULSUP  
331 C \*TUF0H+TOAPH

332 C V(11)=Z(11)+(RU+Z(11)+2.3\*RE)+Z(17)+CON  
333 C \*1.01+Z(17)-Z(3)-(CPOIC\*(50-60)\*Z(6)+DEN0117\*(EN4-100000)

334 C  
335 C \*CPAIN\*(122-35)\*13.19+DENAIR\*Z(6)+DEN01L/EN4  
336 C  
337 C MILLER WATER BALANCE  
338 C UFA+UN=APH+FOH+AT+BB+HS+LS+03

339 C  
340 C V(12)=-CPAIF\*(122-35)\*13.19+DENAIR\*Z(6)+DEN01L/EN4  
341 C \*(CPJIL\*(90-60)+Z(6)+DEN0117)/(EN4-100000)

342 C  
343 C \*RC\*Z(11)-Z(11)+0.01\*Z(11)+Z(9)+Z(10)+Z(11)+Z(11)-Z(11)-CJH









```

514 WRITL(6,20CC)
515 FURMAT(IX,'INTERESTING HEAT BALANCE')
516 WRITL(6,600)
517 FURMAT(IX,'OBJECTIVE FUNCTION VALUE',7)
518 XUF=XI*XC(6)
519 XUL=XI*XC(4)
520 XCB=XI*XC(7)
521 A=XI*XC(5)
522 XUB=XI*XC(3)
523 WRITL(6,610) XCF
524 WRITL(6,620) XCE
525 WRITL(6,630) XCH
526 WRITL(6,640) XCS
527 WRITL(6,650) XCB
528 XTOTAL=XCF+XCE+XCH+XCB+XCS
529 WRITL(6,660) XTOTAL
530 FURMAT(IX,'FUEL COST' DAHT/HR 'F10.3)
531 FURMAT(IX,'ELECTRIC COST' DAHT/HR 'F10.3)
532 FURMAT(IX,'MAKE-UP WATER COST' DAHT/HR 'F10.3)
533 FURMAT(IX,'SALE STEAM COST' DAHT/HR 'F10.3)
534 FURMAT(IX,'3K BLOW STEAM COST' DAHT/HR 'F10.3)
535 FURMAT(IX,'TOTAL COST' DAHT/HR 'F10.3)
536 C*****
537 WRITL(6,30GG)
538 3000 FURMAT(77,IX,'HEAT AND MASS BALANCE',777)
539 C
540 C DESCRIPTION IN THIS SUBSET
541 C GENERAL FORMAT OF MASS BALANCE
542 302C FURMAT(IX,'SUM OF MASS IN',5X,F10.3,3X,'T/10',5X,
543 'SUM OF MASS OUT',4X,F10.3,3X,'T/10',5X,
544 '$' 'RELATIVE ERROR',3X,F10.3)
545 C GENERAL FURMAT OF HEAT BALANCE
546 303C FURMAT(IX,'SUM OF HEAT IN',5X,510.5,3X,'KCAL/H',5X,
547 'SUM OF HEAT OUT',4X,510.5,3X,'KCAL/H',5X,
548 '$' 'RELATIVE ERROR',3X,F10.3)
549 C
550 WRITL(6,30IG)
551 301G FURMAT(7,IX,'POINT 1. MASS BALANCE AROUND BIG LUMP',1
552 XMAIN-XC(1)+XC(8)
553 XMAUT=XI*XC(5)+XC(7)+XC(10)+X15+X15
554 RELERR=(XMAIN-XMAUT)/XMAIN*100
555 WRITL(6,3020) XMAIH,XMAUT,REERR
556 C
557 WRITL(6,304G)
558 304G FURMAT(IX,' HEAT BALANCE AROUND BIG LUMP',1
559 XH11-XC(1)+EHG+XC(9)+EVJ
560 XHEOUT=XI*XC(3)+EN3+XC(7)+EN2+XC(10)+EN4+X15*EN2+XC(12)+860/RB
561 XLEIN=(XHEIN-XHEOUT)/XHEIN*100
562 WRITL(6,3030) XHEIH,XHEOUT,REERR
563 C
564 C
565 WRITL(6,3050)
566 3050 FURMAT(7,IX,'PLINT 2. MASS BALANCE AROUND TURBOJENL KALUR',1
567 FUL1=(EN1-LN2)/(EN1-CN3)/(RC*XC(1)+XC(9))
568 FDE2=(CN3-EN4)/(EN3-EN3)/(10*XC(1)+2.3*XC(10))
569 FLX1=KC*XC(1)+XC(9)-FDEL
570 FEKH=RD*XC(1)+2.3*XC(10)+XC(9)-FDE2

```

```

571 XMAI=FEHT+FEH
572 XMAUT=FEHT+FEH
573 TUR=XMAI
574 XLM= ((XMAI-XMAUT)/XMAI)*100
575 AKIL(6,3020)XMAI,XMAUT,REGR
576 C
577 MKIL(6,3020)
578 FURMAT(IX,'
HEAT BALANCE AROUND TURBOCHARGER')
579 XIL=XMAI*ENI
580 XLUJ=FLX*ENI+FEH*ENI+XC(12)*960/RB
581 XLR= ((XHEI-XHEUT)/XHEI)*100
582 MKIL(6,3030)XHEI,XHEUT,REGR
583 C
584 C
585 MKIL(6,3070)
586 FURMAT(IX,'PLINT 3. MASS BALANCE AT DESUP POINT JF JK')
587 XALY=FEH-XC(3)+FJEZ
588 XMAUT=XL(10)+FD*XC(11)+2.3*RE
589 XLR= ((XMAI-XMAUT)/XMAI)*100
590 MKIL(6,3020)XMAI,XMAUT,REGR
591 C
592 *KIT(4,3080)
593 FURMAT(IX,' HEAT BALANCE AT DESUP POINT UF JK')
594 XHEI= ((FEH-XC(3))*EH3+FJE2*E45
595 XHEUJ=XMAUT*EH4
596 XLR= ((XHEI-XHEUT)/XHEI)*100
597 MKIL(6,3020)XHEI,XHEUT,REGR
598 C
599 C
600 AKIL(6,3050)
601 FURMAT(IX,'POINT 4. MASS BALANCE AT DESUP POINT UF LK')
602 XMAI=FLX+DEL
603 XMAUT=XL(9)+RL*XC(1)
604 XLM= ((XMAI-XMAUT)/XMAI)*100
605 MKIL(6,3020)XMAI,XMAUT,REGR
606 C
607 MKIL(6,3100)
608 FURMAT(IX,' HEAT BALANCE AT DESUP POINT UF LK')
609 XIL=FEH*ENI+FUDEL*ENS
610 XLUJ=XMAUT*LI2
611 XLR= ((XHEI-XHEUT)/XHEI)*100
612 MKIL(6,3030)XHEI,XHEUT,REGR
613 C
614 *KIT(4,3100)FUDEL,FDEZ
615 FURMAT(IX,'FDEL=',F10.3,3X,'FDEZ=',F10.3)
616 C
617 C
618 MKIL(6,3110)
619 FURMAT(IX,'PLINT 5. MASS BALANCE AT SECOND LOOP')
620 XMAI=TUR*FUDEL+FJES2
621 XMAUT=XL(9)+RC*XC(1)+XC(10)+RC*XC(11)+2.3*RC+XC(3)
622 XLM= ((XMAI-XMAUT)/XMAI)*100
623 MKIL(6,3020)XMAI,XMAUT,REGR
624 C
625 MKIL(6,3120)
626 FURMAT(IX,' HEAT BALANCE AT SECOND LOOP')
627 XHEI=TUR*ENS+FOLI*EN3+FJE2*E45

```

MUSIC ID: ZJAHU00

FILE NAME: SJUL.A

WED FEB 01, 1989

PAGE 12

628 XHLUJT=XC(12)\*J00/R0\*XC(1)\*E13+G\*XC(1)\*E12+K\*XC(1)\*E11+L\*XC(1)\*E10+M\*XC(1)\*E9+  
 629 XHEUJT=XHLUJT+XC(0)\*E12+XC(10)\*E13  
 630 KLLAN=(XHEIN-XHEOUT)/XHEIN\*100  
 631 KATL(6,303C)XHEIN,XHEOUT,REGR  
 632 C  
 633 L

634 KATL(6,313D)  
 635 FURMAT(1,1X)POINT 6. MASS BALANCE AT DECUP AND UP1  
 636 LN=15 9000  
 637 LNB=43 303C  
 638 UP=X(1)-TUP  
 639 UP1=(FUE1+FUE2)\*E13-UP\*E13+XC(0)\*E13/(LN-EH0)  
 640 UP2=UP-BPI

641 J1=(FUE1+LNS-UP1)\*E13/ERJ  
 642 U2=X(1)-U1  
 643 XMAIN=BP+XC(18)  
 644 XMAUJ=FDE1+FDE2  
 645 RELK4=(XMAIN-XMAUJ)/XMAIN\*100  
 646 KATL(6,302C)XMAIN,XMAUJ,REGR

647 L  
 648 KATL(6,314C)  
 649 FURMAT(1X)  
 650 XHEIN=UP1\*LN+UP2\*END+XC(18)\*E15  
 651 XHEOUT=(FUE1+FUE2)\*E13  
 652 REGR=(XHEIN-XHEOUT)/XHEIN\*100  
 653 KATL(6,303C)XHEIN,XHEOUT,REGR  
 654 L

655 KATL(6,3145)UPI,UP2,U1,J2  
 656 FURMAT(1X,UPI=\*,F5,J,5X,UP2=\*,F5,J,5X,DI=\*,F5,J,5X,DC=\*,F5,J)  
 657 C  
 658 C

659 KATL(6,315C)  
 660 FURMAT(1,1X)POINT 7. MASS BALANCE AT DL AND UP1  
 661 XMAIN=XC(1)  
 662 XMAUJ=TUR+CP  
 663 RELK4=(XMAIN-XMAUJ)/XMAIN\*100  
 664 KATL(6,302C)XMAIN,XMAUJ,REGR

665 L  
 666 KATL(6,316C)  
 667 FURMAT(1X)  
 668 XHLUJ=XC(1)\*E13  
 669 XHEUJ=XHLUJ+XC(10)\*E13  
 670 KLLAN=(XHEIN-XHEOUT)/XHEIN\*100  
 671 KATL(6,303C)XHEIN,XHEOUT,REGR  
 672 L  
 673 C

674 KATL(6,317C)  
 675 FURMAT(1,1X)POINT 8. MASS BALANCE AT SEPARATE OF 17X  
 676 XMAUJ=XC(1)\*E13  
 677 XMAUJ=XC(1)\*E13  
 678 RELK4=(XMAIN-XMAUJ)/XMAIN\*100  
 679 KATL(6,302C)XMAIN,XMAUJ,REGR  
 680 C

681 KATL(6,318C)  
 682 FURMAT(1X)  
 683 XHEIN=XMAIN\*E12  
 684 XHEOUT=XMAIN\*E12  
 685 REGR=(XHEIN-XHEOUT)/XHEIN\*100  
 686 KATL(6,303C)XHEIN,XHEOUT,REGR

MUSIC ID: ZJAHUUG FILE NAME: SUDK.A

685 KLEH= ((XHLIN-XHEOUT)/XHEIN)\*100  
 686 MNIL(6,3030)XHEIN,XHEOUT,REGR  
 687 C  
 688 C  
 689  
 690 3190 MNIL(5,3150)  
 691 FJKAH(1,1X,POINT 3, MASS BALANCE AT SEPARATE OF JK)  
 692 XMAUT=XC(11)+XC(1)\*XU+2.3\*AE  
 693 KLEH= ((XMAIN-XMAOUT)/XMAIN)\*100  
 694 MNIL(6,3020)XMAIN,XMAOUT,REGR  
 695 C  
 696  
 697 3200 MNIL(6,3200)  
 698 FJKAH(1,1X, POINT 10, MASS BALANCE AT SEPARATE OF JK)  
 699 XHEI=XMAIN\*EN  
 700 XHEOUT=XMAOUT\*EN  
 701 RLEH= ((XHLIN-XHEOUT)/XHEIN)\*100  
 702 MNIL(6,3030)XHEIN,XHEOUT,REGR  
 703 C  
 704  
 705 3210 MNIL(6,3210)  
 706 FJKAH(1,1X, POINT 10, MASS BALANCE AT DLON JK)  
 707 XMAUT=XC(11)+2.3\*RS-FDE2+XC(13)  
 708 RLEH= ((XMAH-XMAOUT)/XMAH)\*100  
 709 MNIL(6,3020)XMAH,XMAOUT,REGR  
 710 C  
 711  
 712 3220 MNIL(6,3220)  
 713 FJKAH(1,1X, POINT 11, MASS BALANCE AT 17K TO AT)  
 714 XHEI=XMAIN\*EN  
 715 XHEOUT=XMAOUT\*EN  
 716 RLEH= ((XHEIN-XHEOUT)/XHEIN)\*100  
 717 MNIL(6,3030)XHEIN,XHEOUT,REGR  
 718 C  
 719  
 720 3230 MNIL(6,3230)  
 721 FJKAH(1,1X, POINT 11, MASS BALANCE AT 17K TO AT)  
 722 TOUT=XC(11)+XC(11)  
 723 MNIL(6,3235)XC(11),TOUT  
 724 FJKAH(1,1X, XIMP=,F10.3,36, TOUT=,F10.3)  
 725 XMAUT=XC(11)\*RC  
 726 XMAUT=XC(11)+10AT  
 727 XLEH= ((XMAIN-XMAOUT)/XMAIN)\*100  
 728 MNIL(6,3020)XMAIN,XMAOUT,REGR  
 729 C  
 730  
 731 3240 MNIL(6,3240)  
 732 FJKAH(1,1X, POINT 12, MASS BALANCE AT 17K TO AT)  
 733 XHEI=XMAIN\*EN  
 734 XHEOUT=XMAOUT\*EN  
 735 KLEH= ((XHLIN-XHEOUT)/XHEIN)\*100  
 736 MNIL(6,3030)XHEIN,XHEOUT,REGR  
 737 C  
 738  
 739 3250 MNIL(6,3250)  
 740 FJKAH(1,1X, POINT 12, MASS BALANCE AT 3K TO DT)  
 741 XMAUT=XLS  
 742 XMAUT=0.536

MUSIC ID: ZJAM000 FILE NAME: SJDR.A

742	CPAIR=0.237	
743	ULNAR=1.25	
744	DENJUL=0.5405	
745	HL=9.20	
746	TJFJ=(CPOI)*(YO-60)*XC(6)*DEYU(1)/(EY4-100000)	
747	TUWAF=CPAIR*(122-35)*13.1942*VIR*XC(6)*DENJUL/LH4	
748	TCUT=X*XC(1)*2.3-TOFCH-TOAPH	
749	XMAJUT=TOU(TUOH+TCAPH	
750	NRITL(6,3255)TUFOH,TOAPH,TOOT	
751	J.55 FURMAT(1X)*TOFCH=*,LL3.5,	
752	6/LX,TOAPH=*,E10.5,	
752	6/LX,TOOT=*,L19.5)	
754	KEERH=((XHEIN-XMAJUT)/XMAIH)*100	
755	NRITL(6,320)XMAIH,XMAJUT,KEERH	
756		
757	NRITL(6,3260)	
758	FURMAT(1X)*	HEAT BALANCE AT JK TO UT*
759	XHEIN=XMAIH*EN4	
760	XHEUT=XMAJUT*LN4	
761	ALERT=((XHEIN-XHEUT)/XHEIN)*100	
762	NRITL(6,3050)XHEIN,XHEUT,KEERH	
763		
764		
765	NRITL(6,3270)	
766	FURMAT(7,1X)*POINT 13. MASS BALANCE AT JK TO TON*	
767	XMAIH=XLS-TCUT	
768	XMAJUT=TOFCH+TOAPH	
769	ALERT=((XMAIH-XMAJUT)/XMAIH)*100	
770	NRITL(6,3020)XMAIH,XMAJUT,KEERH	
771		
772	NRITL(6,3200)	
773	FURMAT(1X)*	HEAT BALANCE AT JK TO UT*
774	XHEIN=XMAIH*EN4	
775	XHEUT=XMAJUT*LN4	
776	ALERT=((XHEIN-XHEUT)/XHEIN)*100	
777	NRITL(6,3030)XHEIN,XHEUT,KEERH	
778		
779		
780	NRITL(6,3250)	
781	FURMAT(7,1X)*POINT 14. MASS BALANCE AT LOWER LOOP*	
782	XMAIH=CON*XC(7)+XC(11)+RDS*XC(1)*2.3	
783	XMAJUT=TOU(CH+TCAPH)*XC(3)+1.01*XC(1)	
784	ALERT=((XMAIH-XMAJUT)/XMAIH)*100	
785	NRITL(6,3020)XMAIH,XMAJUT,KEERH	
786		
787	NRITL(6,3300)	
788	FURMAT(1X)*	HEAT BALANCE AT LOWER LOOP*
789	XHEIN=CON*XC(13)+1000*XC(7)*.035+XC(11)*E(2)*K*XC(1)+2.3)*LN4	
790	XHEUT=((TCFCH+TOAPH)*EN+XC(7)*E(3)+1.01*XC(1)*LN4	
791	ALERT=((XHEIN-XHEUT)/XHEIN)*100	
792	NRITL(6,3030)XHEIN,XHEUT,KEERH	
793		
794		
795		
796	NRITL(6,3310)	
797	FURMAT(7,1X)*POINT 15. MASS BALANCE AROUND BOILER*	
798	XMAIH=1.01*XC(1)	
799	XMAJUT=XC(11)+0.01*XC(1)	



```

800 REGR=(IXMAIN-XHOUT)/XMAIN*100
801 MAJL(6,350)XMAIN,XMAOUT,REGR
802 MAJL(6,332)
803 FURNAT(IX,
804 HEAT I/H = HEAT FROM AIR+HEAT FROM OIL+HEAT FROM WATER INLET
805 +HEAT OF COMBUSTION+HEAT OF TOAT
806 XHL(1)=CPAIR*(122-25)*13.19+XC(6)*DENCOIL*DENAIR
807 XHL(2)=LPOIL*(50-25)*XC(6)*DENCOIL*DENAIR
808 XHL(3)=1.01*XC(1)*0.19E6
809 XHL(4)=9254.03*XC(6)
810 XHL(5)=(RC*XC(1))-XC(11)*EN2
811 XHEAT=XHEIN+XHEI2+XHEI3+XHEI4+XHEI5
812 HEAT OUT= HEAT FROM STEAM+HEAT FROM AIR OUTLET
813 +HEAT OF BLW DRAIN+HEAT LOSS
814 XHUJ1=XU(1)*EN6
815 XHUJ2=CPAIR*(195-25)*13.19+XC(5)*DENCOIL*DENAIR
816 XHUJ3=0.01*XC(1)*0.5E6
817 XHUJ4=XHEIN-XHUJ1-XHUJ2-XHUJ3
818 XHUJ5=XHOUT1+XHCIT2+XHUJ4+XHUJ5
819
820 ENL(16,335) XHEIN,XHEI2,XHEI3,XHEI4,XHEI5
821 FURNAT(IX,HEAT FROM AIR=5X,ELO.5,
822 IX,HEAT FROM OIL=5X,ELO.5,
823 IX,HEAT FROM WATER INLET=5X,ELO.5,
824 IX,HEAT OF COMBUSTION=5X,ELO.5,
825 IX,HEAT OF TOAT=5X,ELO.5)
826 ENL(16,336) XHUJ1,XHUJ2,XHUJ3,XHUJ4
827 FURNAT(IX,HEAT FROM STEAM=5X,ELO.5,
828 IX,HEAT FROM AIR OUTLET=5X,ELO.5,
829 IX,HEAT OF BLW DRAIN=5X,ELO.5,
830 IX,HEAT LOSS=5X,ELO.5)
831 ENL(XHOUT4/XHEIN*100
832 MAJL(6,350) REGR
833 FURNAT(IX,HEAT LOSS=5X,ELO.5)
834 ENL=(IXHEIN-XHOUT)/XHEIN*100
835 MAJL(6,303)XHEIN,XHOUT,REGR
836 C
837 C
838
839 MAJL(6,350)
840 FURNAT(IX,POINT 15, MASS BALANCE AROUND DT*)
841 XMAJL=CON+XC(7)+XC(11)+J31
842 XMAJL=XMAJL
843 REGR=(IXMAIN-XMAJL)/XMAIN*100
844 MAJL(6,337) XMAJL,XMAJL,REGR
845 MAJL(6,337)
846 FURNAT(IX,
847 TOUTHP=TEMP OF XC(11) OUT FROM HP
848 TOUTHP=TEMP OF XC(11)
849 MAJL(6,337) TOUTHP
850 FURNAT(IX,TOUTHP=5,10.5)
851 XHEIN=(CON+XC(7))+XC(12)+1030+XC(11)*TOUTHP*1000+J31*DT*LN4
852 XHUJ5=(1.01*XC(1)+XC(8))*LN5
853 REGR=(IXHEIN-XHOUT)/XHEIN*100
854 MAJL(6,303) XHEIN,XHOUT,REGR
855 C

```

FILE NAME: SUBR.A

MUSIC ID: ZJAH000

856 NRITL(6,3300)  
 857 3300 FURMAT(1,1X,POINT 17. MASS BALANCE AROUND BFP\*)  
 858 XNAL=CUN\*XC(7)+XC(11)+TODI  
 859 XNAOJ=1.01\*XC(1)+XC(3)  
 860 XELKM=((XMAIN-XNAOJ)/XMAIN)\*100  
 861 NRITL(6,3020)XPAIH,XNAOJ,REERH

862 NRITL(6,3350)  
 863 3350 FURMAT(1X, HEAT BALANCE AROUND BFP\*)  
 864 XHLIN=XMAIN\*ENS  
 865 XHEJUT=XNALUT\*ENS  
 866 XELKM=((XHEIH-XHEJUT)/XHEIH)\*100  
 867 NRITL(6,3050)XHEIH,XHEJUT,REERH

868  
 869  
 870  
 871 3400 NRITL(6,3400)  
 872 XNAL=1.01\*XC(1)+XC(11)  
 873 XNAOJ=XMAIN  
 874 XELKM=((XMAIN-XNAOJ)/XMAIN)\*100  
 875 NRITL(6,3020)XNAOJ,XNAOJ,REERH  
 876 NRITL(6,3410)  
 877 3410 FURMAT(1X, HEAT BALANCE AROUND HPH\*)  
 878 XHEIH=1.01\*XC(1)+ENS\*XC(11)+E\*2  
 879 XHEJUT=1.01\*XC(1)+O.19\*XC(11)+TOUT\*IP\*100  
 880 XELKM=((XHEIH-XHEJUT)/XHEIH)\*100  
 881 NRITL(6,3030)XHEIH,XHEJUT,REERH  
 882  
 883  
 884  
 885 3420 NRITL(6,3420)  
 886 FURMAT(1,1X,POINT 19. MASS BALANCE AROUND FUI\*)  
 887 XNAOJ=XMAIN  
 888 XELKM=((XNAOJ-XNAOJ)/XNAOJ)\*100  
 889 NRITL(6,3020)XNAOJ,XNAOJ,REERH  
 890 NRITL(6,3430)  
 891 3430 FURMAT(1X, HEAT BALANCE AROUND FOH\*)  
 892 XHEIH=TODI\*ER\*CP\*100-25)\*XC(5)\*DENRIL  
 893 XHEJUT=CP\*100-25)\*XC(5)\*DENRIL+TODI\*O\*1.0  
 894 XELKM=((XHEIH-XHEJUT)/XHEIH)\*100  
 895 NRITL(6,3030)XHEIH,XHEJUT,REERH  
 896  
 897  
 898 3440 NRITL(6,3440)  
 899 FURMAT(1,1X,POINT 20. MASS BALANCE AROUND APH\*)  
 900 XNAOJ=XNAOJ  
 901 XELKM=((XMAIN-XNAOJ)/XMAIN)\*100  
 902 NRITL(6,3020)XPAIH,XNAOJ,REERH  
 903 NRITL(6,3450)  
 904 3450 FURMAT(1X, HEAT BALANCE AROUND APH\*)  
 905 XHEIH=TODI\*ER\*EN\*CP\*100-13.17\*1.29\*XC(6)\*DENRIL  
 906 XHEJUT=CP\*100-122-25)\*13.15\*XC(6)\*DENRIL+DENRIL  
 907 XELKM=((XHEIH-XHEJUT)/XHEIH)\*100  
 908 NRITL(6,3030)XHEIH,XHEJUT,REERH  
 909 NRITL(6,3460)  
 910 3460 FURMAT(1,1X,POINT 21. MASS BALANCE AROUND PIT\*)  
 911 XNAOJ=CCN\*XC(7)





**VITA**

Mister Wuchara Kanidtabud was born on July 27, 1957 at Prachaubkirikan Province, Thailand. He graduated with a Bachelor Degree of Engineering in Chemical Engineering from King Mongkut's Institute of Technology, Thonburi Campus in 1979.