




## เอกสารอ้างอิง


1. อเนก ผลเจริญ . 2539 . การออกแบบระบบบำบัดกลิ่นเหม็นจากเมรุเผาศพด้วยปฏิกิริยาเคมีอิเล็กตรอน , รายงานโครงการทางวิศวกรรมเคมี คณะวิศวกรรมศาสตร์ จุฬาลงกรณ์มหาวิทยาลัย
2. เมตตา ตริศิริเนตร . 2537 . การศึกษาวิเคราะห์ไฮโดรเจนซัลไฟด์จากเตาศพชนิดที่ใช้น้ำมันและพื้นเป็นเชื้อเพลิง , วิทยานิพนธ์ปริญญาวิทยาศาสตรบัณฑิต สาขาวิชาวิทยาศาสตร์ สภาวะแวดล้อม จุฬาลงกรณ์มหาวิทยาลัย
3. กรมควบคุมมลพิษ . 2539 . รายงานผลการตรวจวัดการระบายสารมลพิษทางอากาศจากปล่องเมรุวัด , กระทรวงวิทยาศาสตร์และสิ่งแวดล้อม
4. ชีคาโอะ คานาโอกะ และ วิวัฒน์ ตันทะพานิชกุล . 2528 . มลภาวะอากาศ , สมาคมส่งเสริมเทคโนโลยี (ไทย-ญี่ปุ่น)
5. กัญจนา บุญเกียรติ . 2531 . การคำนวณชั้นต้นในวิชาวิศวกรรมเคมี , สำนักพิมพ์จุฬาลงกรณ์มหาวิทยาลัย
6. คณะแพทยศาสตร์ มหาวิทยาลัยมหิดล. 2539. ชีวเคมี, คณะแพทยศาสตร์ มหาวิทยาลัยมหิดล
7. นิชิตะและคณะ . 2539. มาตรการสำหรับสิ่งแวดล้อมเป็นพิษที่พบได้จากสถานที่จริงเกี่ยวกับกลิ่นเหม็นจากโรงเผาศพ
8. Wiwut Tanthapanichakoon , L. Kittasak , K. Paisarn , C. Tawatchai , T. Hajime , O. Morio , S. Noriaki . 1996 . Basic Study on the application of Electron Attachment Reaction to the Treatment of Crematory Emission Gas
9. Donald Q. Kern . 1965 . Process Heat Transfer , Mcgraw – Hill
10. Gessner G. Hawley . 1981 . The Condensed Chemical Dictionary , Van Nostrand Reinhold Company
11. Robert H. Perry , Don Green . 1984 . Perry's Chemical Engineer' Handbook, Mcgraw-Hill
12. Calvin R. Runner . 1993 . Hazardous Waste Incinerator , Mcgraw-Hill
13. Noel De Nevers . 1995 . Air Pollution Control Engineering , Mcgraw-Hill
14. Richard C. Flagan , John H Seinfeld . 1988 . Fundamentals of Air Pollution Engineering , Prentice-Hall
15. Robert C. Reid , John M. Prausnitz , Bruce E. Paling . 1987 . The Properties of Gases & Liquids , Mcgraw-Hill

16. EPA U.S. Environment Protection Agency , Office of Research and Development Center for Environmental Research Information . 1981 . Control Technology for Hazardous Air Pollutants, Government Institutes, Inc.
17. John C. Mycock , John D. McKenna , Louis Theodore . 1995 . Air Pollution Control Engineering and Technology , Lewis Publishers
18. Joseph J. Seiwert , Jr. . 1994 . : <http://www.smitheng.com/paper1.htm> , Smith Engineering Company.
19. Eckert , J. S. 1970 . Chem.Eng.progr.66(3):39
20. Ernest E. Ludwig . 1980 . Applied Process Design for Chemical and Petrochemical Plants , Gulf Publishing.
21. David Leith. 1981 . Hand book of Powder Science,Mcgraw-Hill.
22. ASHRAE. 1981 . Duct Design, ASHRAE.
23. Otto York. 1997. Mist Eliminator, Otto York Catalogue.
24. Weishaupt. 1997. Installation and Operation Instructions, Weishaupt Manual Book.
25. ABB, - , ABB Motor Selection, ABB Motor Catalogue.
26. National, - , National Fan / Blower Selection Guide book, National Catalogue.
27. Ingersoll, Ingersoll Pump Selection Handbook, Ingersoll Catalogue.
28. Lechler, Spray Nozzle Selection Handbook, Lechler Catalogue
29. Nichicon, - , Portable DC High Voltage Generator User Manual , Nichicon Catalogue.
30. Richardson Engineering Services, Inc., International Construction Analysts. 1975. Process Plant Construction Estimating Standards, Richardson Engineering Services.
31. Warren L. McCabe, Julian C. Smith, Peter Harriott. 1993. Unit Operations of Chemical Engineering, Mcgraw-Hill.
32. TEC-Lodge-Sturtevant,-,Dry Type Electrostatic Precipitator,Tecno frontier Co.,Ltd Catalogue.


ภาคผนวก ก ข้อมูลการทดลองประสิทธิภาพการกำจัดก๊าซมลพิษด้วย Electron Attachment




รูปที่ ก.1 ประสิทธิภาพการกำจัด  $SF_6$  ที่กระแสค่าต่างๆ (7)




รูปที่ ก.2 ประสิทธิภาพการกำจัด  $SF_6$  ที่ Space Velocity ค่าต่างๆ (7)




รูปที่ ก.3 ประสิทธิภาพการกำจัด  $CS_2$  ในกระแสก๊าซที่มี  $O_2$  อยู่ร่วม (7)




รูปที่ ก.4 ประสิทธิภาพการกำจัด  $COS$  ในกระแสก๊าซที่มี  $H_2O$  อยู่ร่วม (7)




รูปที่ ก.5 ประสิทธิภาพการกำจัด  $SO_2$  ในกระแสก๊าซที่มี  $O_2$  และ  $H_2O$  อยู่รวม (7)




รูปที่ ก.6 ภาคตัดขวางของเครื่องปฏิกรณ์ชนิดคาโทดเดี่ยวและคาโทด 5 เส้น (7)




รูปที่ ก.7 ความสัมพันธ์ระหว่างกระแสและแรงดันไฟฟ้าในการกำจัด CH<sub>3</sub> (7)



รูปที่ ก.8 ความสัมพันธ์ระหว่าง E/P กับกระแสไฟฟ้าในการกำจัด CH<sub>3</sub> (7)



รูปที่ ก.9 ประสิทธิภาพการกำจัด  $\text{CH}_3\text{I}$  ที่กระแสไฟฟ้าและคาโอดขนาดต่างๆ (7)




รูปที่ ก.10 ประสิทธิภาพการกำจัด  $\text{CH}_3\text{I}$  ที่กำลังไฟฟ้าและคาโอดขนาดต่างๆ (7)


รูปที่ ก.11 ประสิทธิภาพการกำจัด  $\text{CH}_3\text{I}$  ที่กำลังไฟฟ้าและคาโรตขนาดต่างๆ (7)

รูปที่ ก.12 ประสิทธิภาพการกำจัด  $\text{CH}_3\text{CHO}$  จากอากาศและจาก  $\text{N}_2$  ที่กำลังไฟฟ้าต่างๆ (7)






รูปที่ ก.13 ประสิทธิภาพการกำจัด  $C_2Cl_3F_3$  ที่กระแสไฟฟ้าและคาโตรูปปร่างต่างๆ (7)




รูปที่ ก.14 ประสิทธิภาพการกำจัด  $C_2Cl_3F_3$  ที่กำลังไฟฟ้าและคาโตรูปปร่างต่างๆ (7)

ต้นฉบับ หน้าขาดหาย



รูปที่ ก.17 ประสิทธิภาพการกำจัด  $\text{CH}_3\text{CHO}$  ที่กระแสไฟฟ้าต่างๆ ด้วยคาโธด 1 เส้นและ 5 เส้น (7)



รูปที่ ก.18 ประสิทธิภาพการกำจัด  $\text{CH}_3\text{CHO}$  ที่กำลังไฟฟ้าต่างๆ ด้วยคาโธด 1 เส้นและ 5 เส้น (7)

ตาราง ก.1 อิทธิพลของความเข้มข้นของก๊าซต่อประสิทธิภาพการกำจัด (7)

Sample Gas	Experimental Conditions					Removal Efficiency		
	I (mA)	Sv (h <sup>-1</sup> )	C <sub>in</sub> (ppm)	C <sub>O2</sub> (%)	C <sub>H2O</sub> (ppm)	Change of $\psi$		$\psi_{Max}$
						I	C <sub>in</sub>	
SF <sub>6</sub>	0.25 ~ 1.6	18.9	0.176 ~ 298	0	0	incr.	decr.	1.0
SO <sub>2</sub>	0.25 ~ 1.6	18.9	32.7 ~ 304	0	0	incr.	decr.	0.44
(CH <sub>3</sub> ) <sub>2</sub> S	0.25 ~ 1.5	18.9	3.88 ~ 89	0	0	incr.	decr.	0.90
CH <sub>3</sub> I	0.1 ~ 2.0	47.3	27.6 ~ 144.3	0	0	incr.	decr.	0.65
C <sub>2</sub> Cl <sub>3</sub> F <sub>3</sub>	0.1 ~ 3.0	18.9	50 ~ 400	0	0	incr.	decr.	1.0
CH <sub>3</sub> CHO	0.1 ~ 1.0	21.8	9.9 ~ 35.6	0	0	incr.	decr.	0.88
(CH <sub>3</sub> ) <sub>3</sub> N	0.5 ~ 1.0	58.6	43	0	0	incr.	-	0.40

Note : Maximum  $\psi$  under the experimental conditions.

ตาราง ก.2 อิทธิพลของค่า SV ต่อประสิทธิภาพการกำจัด (7)

Sample Gas	Experimental Conditions					Removal Efficiency		
	I (mA)	Sv (h <sup>-1</sup> )	C <sub>in</sub> (ppm)	C <sub>O2</sub> (%)	C <sub>H2O</sub> (ppm)	Change of $\psi$		$\psi_{Max}$
						I	SV	
SF <sub>6</sub>	1.2	4.7 ~ 163	1.05	0	0	-	decr.	1.0
CH <sub>3</sub> I	0.1 ~ 2.0	24.6 ~ 76.1	81.5	0	0	incr.	decr.	0.80
CH <sub>3</sub> CHO	0.25 ~ 1.5	21.8 ~ 66.2	35.6	0	0	incr.	decr.	0.70

ตาราง ก.3 อิทธิพลของการมีอยู่ร่วมของ O<sub>2</sub> และ by product ต่อประสิทธิภาพการกำจัด (7)

Sample Gas	Experimental Conditions					Reaction By-Products	Removal Efficiency		
	I (mA)	Sv (h <sup>-1</sup> )	C <sub>in</sub> (ppm)	C <sub>O2</sub> (%)	C <sub>H2O</sub> (ppm)		Change of $\psi^S$		$\psi^S_{Max}$
	V (KV)						I	C <sub>O2</sub>	
SO <sub>2</sub>	0.25 ~ 1.5 (10.1 ~ 14.5)	18.9	101	0 ~ 18	0	None	incr.*	incr.*	0.95
CS <sub>2</sub>	0.18 ~ 1.5 (9.3 ~ 14.8)	18.9	30	0 ~ 49	0	SO <sub>2</sub> COS	incr.	max at 2% *	0.98
COS	0.2 ~ 1.5 (9.5 ~ 14.8)	18.9	29	0 ~ 50	0	SO <sub>2</sub>	incr.	max at 2% *	0.92
CH <sub>3</sub> SH	0.05 ~ 1.0 (6.3 ~ 14.9)	18.9	69	0 ~ 20	0	SO <sub>2</sub> H <sub>2</sub> S or COS	incr.	incr.	1.0
(CH <sub>3</sub> ) <sub>2</sub> S	0.25 ~ 1.0 (6.0 ~ 10)	18.9	70	0 ~ 22	0	None	incr.	incr.	1.00
C <sub>2</sub> Cl <sub>3</sub> F <sub>3</sub>	0.1 ~ 1.5 (9.2 ~ 15.2)	18.9	400	0 ~ 20	0	HCl or HF	incr.	decr.	0.88 **
(CH <sub>3</sub> ) <sub>3</sub> N	0.05 ~ 0.15 (8.3 ~ 14.0)	69.4	25	0 ~ 20	0	CH <sub>3</sub> CHO, C <sub>2</sub> H <sub>5</sub> OH, (CH <sub>3</sub> ) <sub>2</sub> CO or CH <sub>3</sub> NO <sub>2</sub>	incr.	incr.	1.0 **

Note : \*  $\psi^S$  for SO<sub>2</sub> increased with discharge current;  $\psi^S$  for SO<sub>2</sub> increased with the conc. Of O<sub>2</sub> and  $\psi^S$  of CS<sub>2</sub> becomes maximum at 2% of O<sub>2</sub> concentration.  
\*\* Maximum  $\psi$  is calculated by eq.1

ตาราง ก.4 อิทธิพลของการมีอยู่ร่วมของไอน้ำ และ by product ต่อประสิทธิภาพการกำจัด (7)


Sample Gas	Experimental Conditions					Reaction By-Products	Removal Efficiency		
	I (mA)	Sv (h <sup>-1</sup> )	C <sub>in</sub> (ppm)	C <sub>O2</sub> (%)	C <sub>H2O</sub> (ppm)		Change of $\psi^S$		$\psi^S_{Max}$
	V (KV)						I	C <sub>H2O</sub>	
H <sub>2</sub> S	0.2 ~ 1.45 (3.5 ~ 8.7)	37.8	60	0	400 ~ 11000	None	incr.	incr.	1.0
SO <sub>2</sub>	0.25 ~ 1.5 (4.5 ~ 5.7)	37.8	122	0	400 ~ 13000	None	incr.	incr.	0.39
CS <sub>2</sub>	0.25 ~ 1.4 (4.9 ~ 7.5)	37.8	48	0	300 ~ 11000	SO <sub>2</sub> COS	incr.	incr.	0.66
COS	0.25 ~ 1.5 (4.5 ~ 5.7)	37.8	53	0	650 ~ 10000	SO <sub>2</sub>	incr.	incr.	0.64
CH <sub>3</sub> SH	0.1 ~ 1.5 (4.8 ~ 6.5)	37.8	40	0	1000 ~ 10000	SO <sub>2</sub>	Max at 0.25~0.5 mA	incr.	0.65
(CH <sub>3</sub> ) <sub>2</sub> S	0.25 ~ 1.5 (4.5 ~ 5.6)	52.9	38	0	1100 ~ 9100	SO <sub>2</sub>	Max at 0.5 mA	incr.	0.27

ตาราง ก.5 อิทธิพลของการมีอยู่ร่วมของไอน้ำและ O<sub>2</sub> และ by product ต่อประสิทธิภาพการกำจัด (7)

Sample Gas	Experimental Conditions					Reaction By-Products	Removal Efficiency		
	I (mA)	Sv (h <sup>-1</sup> )	C <sub>in</sub> (ppm)	C <sub>O2</sub> (%)	C <sub>H2O</sub> (ppm)		Change of $\psi^S$		$\psi^S_{Max}$
	V (KV)						I	C <sub>H2O</sub>	
SO <sub>2</sub>	0.25 ~ 1.5 (9.0 ~ 14.5)	37.8	120	5.0	600 ~ 6300	None	incr.	incr.*	0.89
CS <sub>2</sub>	0.25 ~ 1.5 (8.5 ~ 14.0)	37.8	65	14.5	600 ~ 9500	SO <sub>2</sub> COS	incr.	decr.	0.93
(CH <sub>3</sub> ) <sub>2</sub> S	0.1 ~ 1.5 (8.0 ~ 14.0)	52.9	39	7.9	600 ~ 5600	SO <sub>2</sub>	incr.	incr.	0.98

Note : \* Negligible in high discharge current.

ภาคผนวก ข. ข้อมูลการหาความดันลดแบบแพคภายในหอสั้มน้้ตรง (19)



Packing Factors\*  
(DUMPED PACKING)

Packing Type	Material	Nominal Packing Size (Inches)										
		1/4	3/8	1/2	5/8	3/4	1 or #1	1 1/4	1 1/2	2 or #2	3	3 1/2 or #3
Intalox®	Metal						41		25	16		13
Hy-Pak™	Metal						43		26	18		15
Super Intalox® Saddles	Ceramic						60			30		
Super Intalox Saddles	Plastic						33			21		16
Pall Rings	Plastic				57		52		40	24		16
Pall Rings	Metal				70		48		33	20		16
Intalox® Saddles	Ceramic	725	330	200		145	92		52	40	22	
Raschig Rings	Ceramic	1600	1000	580	380	255	155	125	95	65	37	
Raschig Rings	1/32" metal	700	390	300	170	155	115					
Raschig Rings	1/16" metal			410	290	220	137	110	83	57	32	

\*By permission Norton Co., from data compiled in Norton Co. Laboratories, Copyright 1977.  
Packing factors determined with an air-water system in 30" I.D. Tower.

ภาคผนวก ค ค่าพารามิเตอร์ในการทำนายประสิทธิภาพในการจับฝุ่น (20)

ตาราง ค.1 ค่าพารามิเตอร์ในการทำนายประสิทธิภาพในการจับฝุ่น (20)

Aerosol	Scrubber type	$\alpha$	$\beta$
Raw gas (lime dust and soda fume)	Venturi and cyclonic spray	1.470	1.050
Prewashed gas (soda fume)	Venturi, pipe line and cyclonic spray	0.915	1.050
Talc dust	Venturi	2.970	0.362
	Orifice and pipe line	2.700	0.362
Black liquor recovery furnace fume	Venturi and cyclonic spray	1.750	0.620
Cold scrubbing water humid gases			
Hot fume solution for scrubbing (humid gases)	Venturi, pipe line and cyclonic spray	0.740	0.861
Hot black liquor for scrubbing (dry gases)	Venturi evaporator	0.522	0.861
Phosphoric acid mist	Venturi	1.330	0.647
Foundry cupola dust	Venturi	1.350	0.621
Open-hearth steel furnace fume	Venturi	1.260	0.569
Talc dust	Cyclone	1.160	0.655
Copper sulfate	Solivore (A) with mechanic spray generator	0.390	1.140
	(B) with hydraulic nozzles	0.562	1.060
Ferrosilicon furnace fume	Venturi and cyclonic spray	0.870	0.459
Odorous mist	Venturi	0.363	1.410



ภาคผนวก ง สรุปการคำนวณหาความสามารถในการละลายของก๊าซต่างๆ ในน้ำของระบบ  
บำบัดแบบ Electron Attachment

ตาราง ง.1 การคำนวณหา Activity Coefficient ขององค์ประกอบก๊าซต่างๆ

at Temperature :  K

Component Name	Chemical Formula	Equation	No. of C	$\alpha$	$\varepsilon$	$\zeta$	$\log \gamma$	$\gamma$
Acetaldehyde	CH <sub>3</sub> CHO	a	2	-0.617	0.605	0.272	0.729	5.358
Styrene	C <sub>6</sub> H <sub>5</sub> CH=CH <sub>2</sub>	f	8	3.554	0.622	-0.466	10.336	2.166E+10
Acetic Acid	CH <sub>3</sub> COOH	a	2	-0.880	0.603	0.37	0.511	3.243
Propane	C <sub>3</sub> H <sub>8</sub>	a	3	0.688	0.642	0	2.614	411.150

Note :  
 1.) Reference "The Properties of Liquids and Gases", Reid, McGraw-Hill.  
 2.) Data is extrapolated from reference.

ตาราง ง.2 ค่าคงที่ของเฮนรีขององค์ประกอบก๊าซต่างๆ

at Temperature :  K

Component Name	Chemical Formula	Henry's Constant (1/K <sub>H</sub> )	Reference
Hydrogen Sulfide	H <sub>2</sub> S	1.30E-03	a
Carbon Dioxide	CO <sub>2</sub>	4.20E-04	a
Ammonia	NH <sub>3</sub>	2.8	a
Sulfur Dioxide	SO <sub>2</sub>	2.50E-05	a

Note : 1.) Reference a is from "Fundamental Calculation of Chemical Engineering"

ตาราง ง.3 ค่าความดันไอขององค์ประกอบก๊าซที่อุณหภูมิ 40 °C

at Temperature :

313.15 °K

Gaseous Component		Concentration		Physical Properties				Vapor Pressure			
Concentration Case	Component Name			MW	T <sub>b</sub>	T <sub>c</sub>	P <sub>c</sub>	h	ln P <sub>vpr</sub>	P <sub>vpr</sub>	P <sub>vp</sub>
		(ppm)	(mg/m <sup>3</sup> )		(K)	(K)	(barA)			(barA)	(barA)
High	N <sub>2</sub> (Nitrogen)			28	77.4	126.2	33.9	5.56749	3.32378	27.7652	941.24
	O <sub>2</sub> (Oxygen)			32	90.2	154.6	50.4	5.47199	2.7705	15.9667	804.72
Low	CO <sub>2</sub> (Carbondioxide)			44	194.6	304.1	73.8	7.62085	0.22024	1.24638	91.98
	H <sub>2</sub> O (Water)			18	373.2	647.3	221.2	7.33316	-7.8249	0.0004	0.0884
	NO <sub>x</sub>	8000	15041.6	46	121.4	180	64.8	8.61431	3.66277	38.969	2525.19
	SO <sub>x</sub>	580	1517.2	64	263.2	430.8	78.8	6.83715	-2.5687	0.07663	6.0388
	CH <sub>3</sub> COOH (Acetic Acid) Hydrocarbons (Propane)	2400 23000	4708.7 41364.5	48 44	391.1 231.1	592.7 369.8	57.9 42.5	7.8483 6.22544	-7.0062 -1.1262	0.00091 0.32426	0.05247 13.7811
Very low	CH <sub>3</sub> CHO (Acetaldehyde)	4	7.2	44	294	461	55.7	7.05392	-3.3304	0.03578	1.9928
	C <sub>6</sub> H <sub>5</sub> CH=CH <sub>2</sub> (Styrene)	1	4.3	104	418.3	647	39.9	6.71843	-7.1625	0.00078	0.0309
	H <sub>2</sub> S (Hydrogen Sulfide)	1	1.4	34	213.5	373.2	89.4	5.98917	-1.1485	0.31712	28.35
	CH <sub>3</sub> SH (Methyl Mercaptan)	0.1	0.2	48	279.1	470	72.3	6.23941	-3.1252	0.04393	3.1760
	((CH <sub>3</sub> ) <sub>2</sub> S) (Dimethyl Sulfide)	0.1	0.3	62	310.5	503	55.3	6.45132	-3.9112	0.02002	1.1069
	NH <sub>3</sub> (Ammonia)	37	25.7	17	239.8	405.5	113.5	6.82879	-2.0139	0.13347	15.1492
	((CH <sub>3</sub> ) <sub>3</sub> N) (Trimethyl Amine)	2.3	5.5	59	276	433.3	40.9	6.48849	-2.4895	0.08295	3.39266

Referonco :

- 1.) Reid, Prausnitz, Poling, "The Properties of Gases and Liquids", McGraw-Hill, Chapter 7, P. 205-238..
- 2.) Based on eq. 7.2.4 and 7.2.5.
- 3.) The equations are

$$\text{eq. 7.2.4 } h = T_{br} \cdot \ln(P_c / 1.01325) / (1 - T_{br})$$

$$\text{eq. 7.2.5 } \ln P_{vpr} = h(1 - 1/T_r)$$

$$P_{vpr} = P_{vp} / P_c$$

T<sub>b</sub> = Normal Boiling Temperature, K

T<sub>c</sub> = Critical Temperature, K

T<sub>r</sub> = Reduced Temperature, K

P<sub>c</sub> = Critical Pressure, barA

P<sub>vp</sub> = Vapor Pressure, barA

ตาราง ง.4 ความเข้มข้นขององค์ประกอบก๊าซที่ซึ่งละลายในน้ำ

at Temperature : **313.15** K

Component Name	Chemical Formular	MW	Concentration in Gas (ppm)	Vapor Press of Pure Comp (BarA)	Henry's Constant (1/K <sub>H</sub> )	Liquid Activity (γ <sub>A</sub> )	Case	Liquid Fraction (X <sub>A</sub> ) (Kg <sub>a</sub> /Kg <sub>w</sub> )
Acetaldehyde	CH <sub>3</sub> CHO	44	4	1.983	N/A	5.318	1	9.207E-07
Styrene	C <sub>6</sub> H <sub>5</sub> CH=CH <sub>2</sub>	104	1	0.031	N/A	2.166E+10	1	8.622E-15
Acetic Acid	CH <sub>3</sub> COOH	48	2400	0.052	N/A	3.243	1	3.761E-02
Propane	C <sub>3</sub> H <sub>8</sub>	44	23000	13.733	N/A	411.150	1	9.888E-06
Hydrogen Sulfide	H <sub>2</sub> S	34	1	28.253	1.30E-03	N/A	2	2.456E-09
Carbon Dioxide	CO <sub>2</sub>	44	20000	91.657	4.20E-04	N/A	2	2.053E-05
Ammonia	NH <sub>3</sub>	17	37	15.085	2.8	N/A	2	9.784E-05
Sulfur Dioxide	SO <sub>2</sub>	64	580	6.012	2.50E-05	N/A	2	5.156E-08
Nitrogen Oxide	NO	30	8000	2519.210	N/A	N/A	3	5.293E-06
Methyl Mercaptan	CH <sub>3</sub> SH	48	0.1	3.162	N/A	N/A	3	8.434E-08
Dimethyl Sulfide	((CH <sub>3</sub> ) <sub>2</sub> S)	62	0.1	1.101	N/A	N/A	3	3.127E-07
Trimethyl Amine	((CH <sub>3</sub> ) <sub>3</sub> N)	59	2.3	3.378	N/A	N/A	3	2.232E-06

Note :

1.) Reference a is from "Fundamental Calculation of Chemical Engineering"

2.) Case1 : Liquid fraction is calculated from Correlation constant for Activity coefficient at infinite dilution from "The Properties of Gases and Liquids"

$$X_A = Y P_T / \gamma_A P_A^*$$

Case2 : Liquid Fraction is calculated based on Henry's constant from "Perry's Chemical Engineering Handbook",

$$X_A = P_A / K_H$$

Case3: No data available . Assume the fluid as ideal solution and use Raoult's Law,

$$X_A = P_A / P_A^*$$

ตาราง ง.5 ความเข้มข้นขององค์ประกอบก๊าซทิ้งในกระแสก๊าซขาออกจากหอต้มผัดตรง

Inlet Gas data :	Total Flow Rate	1512.7	Kg/h	Outlet Water data :	Total Flow Rate	13404.7	Kg/h
	MW <sub>AV</sub>	28.82			Temperature	40	°C
Outlet Gas data :	Total Flow Rate	1455.4	Kg/h	Inlet Water data :	Total Flow Rate	13354	Kg/h
	MW <sub>AV</sub>	29.51			Temperature	30	°C

at Temperature : 313.15 K

Component Name	Chemical Formula	MW	Inlet Stream			Outlet Stream		
			Conc. In Water (X <sub>A,i</sub> ) (Kg <sub>A</sub> /Kg <sub>w</sub> )	Conc. In Gas (Y <sub>A,i</sub> )		Conc. In Water (X <sub>A,o</sub> ) (Kg <sub>A</sub> /Kg <sub>w</sub> )	Conc. In Gas (Y <sub>A,o</sub> )	
				(Kg <sub>A</sub> /Kg <sub>G</sub> )	(ppm)		(Kg <sub>A</sub> /Kg <sub>G</sub> )	(ppm)
Acetaldehyde	CH <sub>3</sub> CHO	44	0	6.107E-06	4.0	9.207E-07	-2.133E-06	-1.4
Styrene	C <sub>6</sub> H <sub>5</sub> CH=CH <sub>2</sub>	104	0	3.609E-06	1.0	8.622E-15	3.751E-06	1.1
Acetic Acid	CH <sub>3</sub> COOH	48	0	3.997E-03	2400.0	3.761E-02	-3.423E-01	-210426.7
Propane	C <sub>3</sub> H <sub>8</sub>	44	0	3.511E-02	23000.0	9.888E-06	3.641E-02	24416.8
Hydrogen Sulfide	H <sub>2</sub> S	34	0	1.180E-06	1.0	2.456E-09	1.204E-06	1.0
Carbon Dioxide	CO <sub>2</sub>	44	0	3.053E-02	20000.0	2.053E-05	3.155E-02	21158.3
Ammonia	NH <sub>3</sub>	17	0	2.183E-05	37.0	9.784E-05	-8.785E-04	-1525.0
Sulfur Dioxide	SO <sub>2</sub>	64	0	1.288E-03	580.0	5.156E-08	1.338E-03	617.0
Nitrogen Oxide	NO	30	0	8.328E-03	8000.0	5.293E-06	8.607E-03	8466.1
Methyl Mercaptan	CH <sub>3</sub> SH	48	0	1.666E-07	0.1	8.434E-08	-6.037E-07	-0.4
Dimethyl Sulfide	((CH <sub>3</sub> ) <sub>2</sub> S)	62	0	2.151E-07	0.1	3.127E-07	-2.657E-06	-1.3
Trimethyl Amine	((CH <sub>3</sub> ) <sub>3</sub> N)	59	0	4.709E-06	2.3	2.232E-06	-1.566E-05	-7.8

Note :

1.) Reference a is from "Fundamental Calculation of Chemical Engineering"

2.) Case1 : Liquid fraction is calculated from Correlation constant for Activity coefficient at infinite dilution from "The Properties of Gases and Liquids"

$$X_A = Y P_T / \gamma_A P_A$$

Case2 : Liquid Fraction is calculated based on Henry's constant from "Perry's Chemical Engineering Handbook",

$$X_A = P_A / H_A$$

Case3: No data available . Assume the fluid as ideal solution and use Raoult's Law,

$$X_A = P_A / P_A^*$$

ภาคผนวก จ สรุปการคำนวณออกแบบหอทำความเย็นแบบสัมผัสโดยตรง

Direct-Contact Gas Cooler Sizing

	A	B	C	D	E	F	G	H
1	Gas							
2	Mass Flow Rate	1392.67	(Kg/h.)		Water		13354.33	(Kg/h.)
3	Inlet Temp	400	(°C)		Mass Flow Rate		30.05	(°C)
4		673.15	(K)		Inlet Temp		303.2	(K)
5	Outlet Temp	150	(°C)		Outlet Temp		40.05	(°C)
6		423.15	(K)				313.2	(K)
7	C <sub>p</sub> In Gas	1.01	(KJ/Kg°C)					
8	C <sub>p</sub> Out Gas	1.01	(KJ/Kg°C)					
9	C <sub>p</sub> In Vap Water	2.11	(KJ/Kg°C)					
	C <sub>p</sub> Out Vap Water	1.94	(KJ/Kg°C)					

ตาราง ๑.1 ค่าเริ่มต้นและค่าสมมติฐานในการคำนวณ

Basis : 1 ft <sup>2</sup> (0.0929 m <sup>2</sup> ) of Ground Area								
10	Basic Assumption	Inlet Gas Load	G (Kg/h)	680.27	Assumption Water Diffusion from Inlet Gas to Water Body	%	42.2	Basic Assumption
11	Input Data	Inlet Humidity in Inlet Gas	X <sub>1</sub> (Kg/Kg)	0.08624	Outlet Humidity Content in Outlet Gas	X <sub>2</sub> (Kg/Kg)	0.04985	From (G-10)
12	Input Data	Total Water in Inlet Gas	(Kg/h)	58.67	Total Water in Outlet Gas	(Kg/h)	32.91	From (G-10)&(C-11)
13	Input Data	Inlet Dew Point	DP <sub>1</sub> (°C)	50.6	Outlet Dew Point	DP <sub>2</sub> (°C)	41.08	From (G-12)
14	Input Data	Latent Heat of Water at Sat. Temp	Lambda (KJ/Kg)	2380.76	Latent Heat of Water at Sat. Temp	Lambda (KJ/Kg)	2403.9	From (G-13)
15	Cal.	Enthalpy of Inlet Gas	H <sub>1</sub> (KJ/Kg <sub>dry air</sub> )	691.9	Enthalpy of Outlet Gas	H <sub>2</sub> (KJ/Kg <sub>dry air</sub> )	290.4	Cal.
16					Total Heat Load	H <sub>1</sub> - H <sub>2</sub> (KJ/h)	273110.8	From(C-15)&(G15)
17					Liquid Load	L (Kg/h)	6523.1	From (G-16)

ตาราง ๑.2 การคำนวณสภาวะของก๊าซทิ้งและน้ำภายในหอ

Description	Interval 1	Interval 2	Interval 3	Interval 4	Interval 5	Interval 6		
	K <sub>a</sub> v/L 0-0.025	K <sub>a</sub> v/L 0.025-0.050	K <sub>a</sub> v/L 0.050-0.075	K <sub>a</sub> v/L 0.075-0.1	K <sub>a</sub> v/L < 10-0.1123			
18	No. of Diffusion Unit	K <sub>a</sub> v/L	0.025	0.025	0.025	0.025	0.012	
19	Specific Heat of Inlet Gas	c (KJ/Kg°C)	1.192	1.192	1.192	1.192	1.192	
20	Lewis No.	L <sub>w</sub>	0.95	0.95	0.95	0.95	0.95	
21	Heat Transfer Coeff.	h <sub>a</sub> v (KJ/h°C)	184.7	184.7	184.7	184.7	90.9	
<b>Heat Transfer Convection</b>								
22	Convection Heat Transfer Rate	q <sub>c</sub> (KJ/h)	66482.5	51895.6	40527.5	31661.1	12733.5	
23	Diff Temp of Gas	del T (°C)	82.0	64.0	50.0	39.0	25.0	
24	Out Temp	T <sub>interval</sub> (°C)	318.0	254.0	204.1	165.0	150.0	
<b>Diffusion</b>								
25	Sat. Humidity at Inlet Water Temp	X* (Kg/Kg)	0.047	0.0394	0.03442	0.0306	0.02781	
26		K <sub>a</sub> v (Kg/h)/(Kg/Kg)	163.08	163.08	163.08	163.08	80.23	
27	Moisture Diffusion to Gas	K <sub>a</sub> v(X-X*) (Kg/h)	6.40	6.10	5.45	4.77	2.01	
28	Moisture Remain	(Kg/h)	52.27	46.16	40.71	35.94	33.93	
29	Latent Heat at Sat. Temp	Lambda (KJ/Kg)	2406.4375	2413.8	2419.38	2424.1	2427.88	2429.33
30	Diffusion Heat Transfer Rate	q <sub>d</sub> (KJ/h)	15398.88	14734.85	13193.28	11560.21	4874.39	
31	Total Heat Transfer Rate	q <sub>c</sub> +q <sub>d</sub> (KJ/h)	81881.39	66630.44	53720.83	43221.34	17607.92	
<b>Outlet Water Condition</b>								
32	Diff Temp	del t (°C)	3.00	2.44	1.97	1.58	0.62	
33	Out Water Temp	t <sub>interval</sub> (°C)	37.05	34.61	32.65	31.06	30.44	
34	Sat. Humidity of Gas at Outlet Water Temp	X* (Kg/Kg)	0.0394	0.03442	0.0306	0.02781	0.02688	
35	Humidity of Outlet Gas	X (Kg/Kg)	0.07683	0.06786	0.05984	0.05283	0.04988	

ตาราง ๑.3 สรุปการคำนวณของแต่ละช่วงภายในหอ

Interval	K <sub>a</sub> v/L	T (°C)	t (°C)	Water Diffuse (Kg/h)	q <sub>c</sub> (KJ/h)	q <sub>d</sub> (KJ/h)	Total Heat (KJ/h)
1	0.025	318.0	37.05	6.40	66482.5	15398.9	81881.4
2	0.025	254.0	34.61	6.10	51895.6	14734.9	66630.4
3	0.025	204.1	32.65	5.45	40527.5	13193.3	53720.8
4	0.025	165.0	31.06	4.77	31661.1	11560.2	43221.3
5	0.012	150.0	30.44	2.01	12173.5	4874.4	17047.9
6				0.00	0.0	0.0	0.0
Summary	0.1123			24.73	202740.3	55761.61	262501.9

ตาราง จ.4 การออกแบบขนาดของหอ

$n_d$ ( $K_x a V/L$ )		0.1123
Gas Load (G) (Kg/h.0.0929m <sup>2</sup> )		680.27
Actual Gas Load (Kg/h.)		1392.7
Cross section (S) (m <sup>2</sup> )		0.19
Liquid Load (L) (Kg/h.0.0929m <sup>2</sup> )		6523.1
Actual Liq Load (Kg/h)		13354.3
$K_x a$ (lb/h.ft <sup>3</sup> .lb/lb)		6188.3
Fill Height (Z) (m)		0.08
Safety Factor		6.3
Actual Fill Height (m)		0.50
Tower Diameter (D) (m)		0.5
Design Residence Time (t) (sec)		1
Tower Height (H) (m)		1.50



ภาคผนวก ฉ สรุปการทำนายประสิทธิภาพการจับฝุ่นและการออกแบบขนาดของ Demister

ตาราง ฉ.1 การทำนายประสิทธิภาพการจับฝุ่น

Press drop across Tower	(in.H <sub>2</sub> O) (mm.H <sub>2</sub> O)	( $\Delta P$ )	<b>0.54</b> <b>13.77</b>
Contacting power base on Gas stream energy input	(hp/1000 ACFM)	(P <sub>G</sub> )	<b>0.0851</b>
Liquid Inlet Press	(psi) (bar)	(P <sub>L</sub> )	<b>29</b> <b>2</b>
Liquid Feed Rate	(gpm) (m <sup>3</sup> /h)	(Q <sub>L</sub> )	<b>58.8</b> <b>13.35</b>
Gas Flow Rate	(ft <sup>3</sup> /min) (m <sup>3</sup> /h)	(Q <sub>G</sub> )	<b>1207.3</b> <b>2050.96</b>
Contacting power base on Liq stream energy input	(hp/1000 ACFM)	(P <sub>L</sub> )	<b>0.8228</b>
Total Contacting power Energy Input	(hp/1000 ACFM)	(P <sub>T</sub> )	<b>0.9080</b>
Alpha		( $\alpha$ )	<b>2.97</b>
Beta		( $\beta$ )	<b>0.362</b>
No. of Transfer Unit		(N <sub>t</sub> )	<b>2.8680</b>
Collection Efficiency	(%)	( $\eta$ )	<b>94.32</b>

ตาราง ฉ.2 การออกแบบขนาดของ Demister

Demister Type	Wire Mesh
Style	<b>780</b>
K Factor (General used)	<b>0.107</b>
Liquid Density (Kg/m <sup>3</sup> )	<b>992.0</b>
Gas Density (Kg/m <sup>3</sup> )	<b>0.902</b>
Design Velocity (m/s)	<b>3.55</b>
Area Required (m <sup>2</sup> )	<b>0.136</b>
Dia of Demister (mm)	<b>0.42</b>
Selected Dia (mm)	<b>0.5</b>
Pressure Drop (mmAq)	<b>5.0</b>

ภาคผนวก ข สรุปการคำนวณออกแบบแพคเบคของหอสังฆ์สตรงของระบบ Electron Attachment


ตาราง ข.1 การคำนวณหาความดันจากแพคเบคภายในหอสังฆ์สตรง

Pressure Drop across Packing		$\Delta P = \alpha (10\beta^L).(G^2/\rho_G)$	
Type of Packing		1" Raschig,SS	
Packing Characteristic			
Alpha	( $\alpha$ )		0.97
Beta	( $\beta$ )		0.25
Gas Load	(G)	(Kg/h.0.0929m <sup>2</sup> ) (lb/ft <sup>2</sup> .s)	680.27 0.417
Liquid Load	(L)	(Kg/h.0.0929m <sup>2</sup> ) (lb/ft <sup>2</sup> .s)	6523.1 3.995
Gas Density	( $\rho_G$ )	(Kg/m <sup>3</sup> ) (lb/ft <sup>3</sup> )	0.505 0.032
Liquid Density	( $\rho_L$ )	(Kg/m <sup>3</sup> ) (lb/ft <sup>3</sup> )	995 62.117
Pressure Drop /	( $\Delta P$ )	(mmH <sub>2</sub> O/m)	17.499
Packing Height		(inH <sub>2</sub> O/ft)	0.210
<b>Actual Pressure Drop</b>		<b>(mmH<sub>2</sub>O)</b>	<b>8.77</b>
		<b>(inH<sub>2</sub>O)</b>	<b>0.35</b>

ตาราง ข.2 การตรวจสอบ Flooding Point ของแพคเบค

Domain		$= (L/G).( \rho_G / \rho_L )^{1/2}$	
Liquid Load	(L)	(Kg/h.0.0929m <sup>2</sup> ) (lb/ft <sup>2</sup> .s)	6523.1 3.995
Gas Load	(G)	(Kg/h.0.0929m <sup>2</sup> ) (lb/ft <sup>2</sup> .s)	680.27 0.417
Liquid Density	( $\rho_L$ )	(Kg/m <sup>3</sup> ) (lb/ft <sup>3</sup> )	995 62.117
Gas Density	( $\rho_G$ )	(Kg/m <sup>3</sup> ) (lb/ft <sup>3</sup> )	0.505 0.032
<b>Domain</b>		<b>0.216</b>	
Abcissa		$= G^2 . F . \psi^2 . \mu^{0.2} / (\rho_G . \rho_L . g_c)$	
Liquid den/Water den	( $\psi$ )		1
Liquid Viscosity	( $\mu$ )	(cP)	0.8
Packing Factor	(F)	(a/ε <sup>3</sup> )	115
<b>Abcissa</b>		<b>0.303</b>	
<b>Result</b>	<b>From Fig. 3.3.1, Process condition is not exceed Flooding point .</b>		

ภาคผนวก ข การคำนวณหาขนาดของปั๊มของระบบ Electron Attachment

PIPING PRESSURE DROP AND PUMP DESIGN CALCULATION SHEET			0	24.Mar'99.	N.A.																															
Work No.	Project Name	Item No.	No. of Required	Service	Rev.	Date	Made	Chkd	Remarks																											
	Gas Treatment	P-101	1 + 0	Water Pump																																
1) FLOW																																				
D-101 Liq. Level Max. EL 0 Min. EL -1,000							Fitting in Suction Line																													
Pump Nozzle Elev. Suc. EL -1,000 Dis. EL 1,500							<table border="1"> <tr><td>Ord. Entrance</td><td></td><td></td></tr> <tr><td>Borda Entranc</td><td></td><td></td></tr> <tr><td>90° Elbow (S)</td><td></td><td></td></tr> <tr><td>90° Elbow (L)</td><td></td><td></td></tr> <tr><td>45° Elbow</td><td></td><td></td></tr> <tr><td>Tee Side Outle</td><td></td><td></td></tr> <tr><td>Straight Tee</td><td></td><td></td></tr> <tr><td>Gate Valve</td><td></td><td></td></tr> <tr><td>3/4 Contractio</td><td></td><td></td></tr> </table>			Ord. Entrance			Borda Entranc			90° Elbow (S)			90° Elbow (L)			45° Elbow			Tee Side Outle			Straight Tee			Gate Valve			3/4 Contractio		
Ord. Entrance																																				
Borda Entranc																																				
90° Elbow (S)																																				
90° Elbow (L)																																				
45° Elbow																																				
Tee Side Outle																																				
Straight Tee																																				
Gate Valve																																				
3/4 Contractio																																				

2) OPERATING CONDITIONS

		Water	
1. Fluid Name		Water	
2. Temp. Min./Nor. Max. (°C)		/	30 / 40
3. Sp.Gr. Min./Nor. Max. (-)		0.992 /	0.995 /
4. Vis. Min./Nor. Max. (cP)		0.66 /	0.9 /
5. Vap. Press. Max. (Kg/cm²A)		0.042	
6. Capa. Nor/Des/Overdes (m³/hr)		13.3 /	16 / 20.3%

3) SUCTION CONDITIONS

		PUMP	
0. Destination		PUMP	
Flow Rate (m³/hr)		16	
Temperature (°C)		30	
Sp.Gr. (-)		0.995	
Viscosity (cP)		0.9	
1. Line Size			
Nominal Pipe Size (inches)			
Thickness (-)			
Pipe Inside Dia. (mm)			
Pipe Roughness (mm)		0.0457	
2. Velocity (m/s)			
3. Actual Pipe Length (m)			
4. Total Equiv. Length (m)			
5. Fri. Loss (Kg/cm²/100m)			
6. Min. Drum Press. (Kg/cm²G)		0	
7. Min. Liq. Static Head (m)		0.00	
(Kg/cm²)		0.000	
8. Line Loss (Kg/cm²)			
9. Strainer Loss (Kg/cm²)		0	
10. Other Loss (Kg/cm²)			
11. Min. Suc. Press. (Kg/cm²G)		0.000	

5) DIFFERENTIAL PRESSURE

1. Rated Dis. Press. (Kg/cm²G)	2.569
2. Rated Suc. Press. (Kg/cm²G)	0
3. incl. Special Margin (Kg/cm²)	0.000
4. Differential Press. (Kg/cm²)	2.569
5. Head *1 (m)	25.9

6) NET POSITIVE SUCTION HEAD

1. Min. Suc. Press. (Kg/cm²G)	0.000
2. Vap. Press. (Kg/cm²G)	-0.991
3. Net (Kg/cm²)	0.991
4. Sp.Gr. (-)	0.995
NPSH Available *2 (m)	9.9
NPSH Required *2 (m)	

4) DISCHARGE CONDITIONS

0. Destination		C-101	
Elevation (EL)		1,500	
Flow Rate (m³/hr)		16	
Temperature (°C)		30	
Sp.Gr. (-)		0.995	
Viscosity (cP)		0.9	
1. Line Size		ANSI	
Nominal Pipe Size (inches)		1.1/2"	
Thickness (-)		SCH40	
Pipe Inside Dia. (mm)		40.94	
Pipe Roughness (mm)		0.0457	
2. Velocity (m/s)		3.4	
3. Actual Pipe Length (m)		1.5	
4. Total Equiv. Length (m)		2.25	
5. Friction Loss (Kg/cm²/100m)		3.083	
6. Press. Loss (Kg/cm²)			
a. Line		0.069	
b. Onfice		2	
c. Exchangers			
d. Heaters			
e. Miscellaneous		0.5	
Sub-total(a-e)		2.569	
7. Control Valve Loss (Kg/cm²)			
8. Max. Desti. Press. (Kg/cm²G)		0	
9. Elevation Loss (m)		0.00	
(Kg/cm²)		0.000	
10. Req'd Dis. Press. (Kg/cm²G)		2.569	

7) BRAKE HORSEPOWER

$$\text{BHP} = \frac{16 \text{ m}^3/\text{hr (Des.)} \times 0.995 \text{ (Sp.Gr.)}^{*2} \times 25.9 \text{ m}}{36 \times 1} \times 0.500 \text{ (Pump Effi-Frac.)}$$

$$= 2.2 \text{ kW}$$

8) MAX. SHUT OFF PRESSURE (As guide only)

1. Suction Drum Pressure (Kg/cm²G)	0
2. Max. Liquid Static Head (m)	1.00
Sp.Gr. for Max. Suc. Static Head (-)	0.995
Max. Liquid Static Head (Kg/cm²)	0.10
3. Max. Suction Pressure (Kg/cm²G)	0.10
4. Max. Shut-off Pressure	
= Max Suc 0.10 + 1.2 x Diff. Press 2.58 *3 x 1.05	
= 3.35 Kg/cm²G	

Notes; \*1 To be checked by controlling case (Min. Sp.Gr.)

\*2 To be checked by controlling case (Max. Vap. Press.)

\*3 To be checked by controlling case (Max. Sp.Gr.)

ภาคผนวก ฉ สรุปการคำนวณความดันสูญเสียของระบบ Electron Attachment เพื่อกำหนด  
ขนาดของพัดลม

ตาราง ฅ.1 สรุปการคำนวณความดันสูญเสียของระบบ Electron Attachment

Stream	Fitting		Type of Fitting	Flow Rate (m <sup>3</sup> /h)	Duct Size Equiv. (mm)	Velocity (m/s)	Velocity Press (Pa)	Length (m)	Fitting loss coefficient C <sub>o</sub>	Duct Press drop /m (Pa)	Total Press drop (Pa)	Sectional drop (Pa)	Overall Press drop	
	No.	Source											(Pa)	(mmAq)
1,2	1	-	Duct	2957.6	304.8	11.26	32.02	13.5	-	2.370	31.994	203.303	1968.8	200.7
	2	6.6,6.2	Tee Tr	2957.6	-	11.26	32.02	-	0.55	-	17.611			
	3	7.4	Gate	2957.6	-	11.26	32.02	-	4.8	-	153.6979			
-	C-101			-	-	-	-	-	-	-	490	490		
4,5	1	-	Duct	1741.8	304.8	6.63	19.84	4.5	-	1.468	6.607	109.557		
	2	3.5	Elbow	1741.8	-	6.63	19.84	-	0.13	-	2.579			
	3	3.5	Elbow	1741.8	-	6.63	19.84	-	0.13	-	2.579			
	4	3.5	Elbow	1741.8	-	6.63	19.84	-	0.13	-	2.579			
	5	7.4	Gate	1741.8	-	6.63	19.84	-	4.8	-	95.214			
-	R-101			-	-	-	-	-	-	-	490.5	490.5		
6	1	-	Duct	1741.8	304.8	6.63	19.84	5	-	1.468	7.341	615.677		
	2	3.5	Elbow	1741.8	-	6.63	19.84	-	0.13	-	2.579			
	3	3.5	Elbow	1741.8	-	6.63	19.84	-	0.13	-	2.579			
	4	3.5	Elbow	1741.8	-	6.63	19.84	-	0.13	-	2.579			
	5	4.2	Diffuser	1741.8	-	6.63	19.84	-	0.7	-	13.885			
	6	-	Duct	6708	406.4	14.36	107.74	1	-	5.981	5.981			
	7	6.6,6.2	Tee Tr	6708	-	14.36	107.74	-	0.59	-	63.568			
	8	7.4	Gate	6708	-	14.36	107.74	-	4.8	-	517.165			
8	1	-	Duct	6708	406.4	14.36	107.74	10	-	5.981	59.807	59.807		

Project	Emission Gas Treatment (Electron Attachment System)	REV.	DATE
LINE	Stream 1	0	Mar.25'99
	MADE		

**STATIC REGAIN DUCT SIZING**

DENSITY **0.505** kg/m<sup>3</sup>      ROUGHNESS **0.15** mm  
 VISC. **0.0348898** cP = 3.49E-05 N.s/m<sup>2</sup>

	PREVIOUS	THIS	
WIDTH		380	mm
HIGH		190	mm
DIAMETER	12"	304.8	mm
		0.3048	m
AREA		0.072966	m <sup>2</sup>
FLOW		<b>2957.6</b>	m <sup>3</sup> /hr
VELOCITY		11.25945	m/s
REYNOLDS		49673.53	

FRICTION OF THIS SECTION			
ITER.	f	LEFT	RIGHT
1	1000	0.031623	7.741878
2	0.016684	7.741878	6.561000
3	0.023231	6.561000	6.665965
4	0.022505	6.665965	6.656104
5	0.022571	6.656104	6.657026
6	0.022565	6.657026	6.656940
7	0.022566	6.656940	6.656948
8	0.022566	6.656948	6.656947
9	0.022566	6.656947	6.656947
10	<b>0.022566</b>	6.656947	6.656947

LENGTH **10** m  
 DROP/m@THIS SECTION 2.369903 Pa/m

TOTAL DROP 23.69903 Pa  
**2.42** mmAq  
 STATIC PRESSURE REGAIN -24.00805 Pa

USE DUCT 380 x 190 mm

Attachment

Project	Emission Gas Treatment (Electron Attachment System)	REV.	DATE
LINE	Stream 2	0	Mar.25'99
	MADE		

**STATIC REGAIN DUCT SIZING**

DENSITY 0.505 kg/m<sup>3</sup>      ROUGHNESS 0.15 mm  
 VISC. 0.0348898 cP = 3.49E-05 N.s/m<sup>2</sup>

	PREVIOUS	THIS	
WIDTH		380	mm
HIGH		190	mm
DIAMETER	12"	304.8	mm
		0.3048	m
AREA		0.072966	m <sup>2</sup>

FLOW 2957.6 m<sup>3</sup>/hr  
 VELOCITY 11.25945 m/s  
 REYNOLDS 49673.53

LENGTH 3.5 m  
 DROP/m@THIS SECTION 2.369903 Pa/m

TOTAL DROP 8.294659 Pa  
0.85 mmAq  
 STATIC PRESSURE REGAIN -24.00805 Pa

USE DUCT 380 x 190 mm

FRICTION OF THIS SECTION			
ITER.	f	LEFT	RIGHT
1	1000	0.031623	7.741878
2	0.016684	7.741878	6.561000
3	0.023231	6.561000	6.665965
4	0.022505	6.665965	6.656104
5	0.022571	6.656104	6.657026
6	0.022565	6.657026	6.656940
7	0.022566	6.656940	6.656948
8	0.022566	6.656948	6.656947
9	0.022566	6.656947	6.656947
10	0.022566	6.656947	6.656947

Attachment

Project	Emission Gas Treatment (Electron Attachment System)	REV.	DATE
LINE	Stream 4	0	Mar.25'99
	MADE		

**STATIC REGAIN DUCT SIZING**

DENSITY 0.902 kg/m<sup>3</sup>      ROUGHNESS 0.15 mm  
 VISC. 0.019 cP = 0.000019 N.s/m<sup>2</sup>

	PREVIOUS	THIS	
WIDTH		380	mm
HIGH		190	mm
DIAMETER	12"	304.8	mm
		0.3048	m
AREA		0.072966	m <sup>2</sup>

FLOW 1741.8 m<sup>3</sup>/hr  
 VELOCITY 6.630953 m/s  
 REYNOLDS 95949.76

LENGTH 3.5 m  
 DROP/m@THIS SECTION 1.468126 Pa/m

TOTAL DROP 5.138441 Pa  
 0.52 mmAq  
 STATIC PRESSURE REGAIN -14.8727 Pa

USE DUCT 380 x 190 mm

FRICTION OF THIS SECTION			
ITER.	f	LEFT	RIGHT
1	1000	0.031623	7.741878
2	0.016684	7.741878	6.561000
3	0.023231	6.561000	6.665965
4	0.022505	6.665965	6.656104
5	0.022571	6.656104	6.657026
6	0.022565	6.657026	6.656940
7	0.022566	6.656940	6.656948
8	0.022566	6.656948	6.656947
9	0.022566	6.656947	6.656947
10	0.022566	6.656947	6.656947



Attachment

Project	Emission Gas Treatment (Electron Attachment System)	REV.	DATE
LINE	Stream 5	0	Mar.25'99
	MADE		

**STATIC REGAIN DUCT SIZING**

DENSITY 0.902 kg/m<sup>3</sup>      ROUGHNESS 0.15 mm  
 VISC. 0.019 cP = 0.000019 N.s/m<sup>2</sup>

	PREVIOUS	THIS
WIDTH		380 mm
HIGH		190 mm
DIAMETER	12"	304.8 mm
		0.3048 m
AREA		0.072966 m <sup>2</sup>
FLOW		<u>1741.8</u> m <sup>3</sup> /hr
VELOCITY		6.630953 m/s
REYNOLDS		95949.76

FRICTION OF THIS SECTION			
ITER.	f	LEFT	RIGHT
1	1000	0.031623	7.741878
2	0.016684	7.741878	6.561000
3	0.023231	6.561000	6.665965
4	0.022505	6.665965	6.656104
5	0.022571	6.656104	6.657026
6	0.022565	6.657026	6.656940
7	0.022566	6.656940	6.656948
8	0.022566	6.656948	6.656947
9	0.022566	6.656947	6.656947
10	<b>0.022566</b>	6.656947	6.656947

LENGTH 1 m  
 DROP/m@THIS SECTION 1.468126 Pa/m

TOTAL DROP 1.468126 Pa  
0.15 mmAq  
 STATIC PRESSURE REGAIN -14.8727 Pa

USE DUCT 380 x 190 mm

Attachment

Project	Emission Gas Treatment (Electron Attachment System)	REV.	DATE
LINE	Stream 6	0	Mar.25'99
	MADE		

**STATIC REGAIN DUCT SIZING**

DENSITY **0.902** kg/m<sup>3</sup>      ROUGHNESS **0.15** mm  
 VISC. **0.019** cP = 0.000019 N.s/m<sup>2</sup>

	PREVIOUS	THIS	
WIDTH		380	mm
HIGH		190	mm
DIAMETER	12"	304.8	mm
		0.3048	m
AREA		0.072966	m <sup>2</sup>

FLOW **1741.8** m<sup>3</sup>/hr  
 VELOCITY **6.630953** m/s  
 REYNOLDS **95949.76**

LENGTH **5** m  
 DROP/m@THIS SECTION **1.468126** Pa/m

TOTAL DROP **7.34063** Pa  
**0.75** mmAq  
 STATIC PRESSURE REGAIN **-14.8727** Pa

USE DUCT **380** x **190** mm

FRICTION OF THIS SECTION			
ITER.	f	LEFT	RIGHT
1	1000	0.031623	7.741878
2	0.016684	7.741878	6.561000
3	0.023231	6.561000	6.665965
4	0.022505	6.665965	6.656104
5	0.022571	6.656104	6.657026
6	0.022565	6.657026	6.656940
7	0.022566	6.656940	6.656948
8	0.022566	6.656948	6.656947
9	0.022566	6.656947	6.656947
10	<b>0.022566</b>	6.656947	6.656947

Attachment

Project	Emission Gas Treatment (Electron Attachment System)	REV.	DATE
LINE	Stream 7	0	Mar.25'99
	MADE		

**STATIC REGAIN DUCT SIZING**

DENSITY 1.13 kg/m<sup>3</sup>      ROUGHNESS 0.15 mm  
 VISC. 0.018 cP = 0.000018 N.s/m<sup>2</sup>

	PREVIOUS	THIS	
WIDTH		500	mm
HIGH		250	mm
DIAMETER	16"	406.4	mm
		0.4064	m
AREA		0.129717	m <sup>2</sup>
FLOW		4856.6	m <sup>3</sup> /hr
VELOCITY		10.39998	m/s
REYNOLDS		265333.6	

FRICTION OF THIS SECTION			
ITER.	f	LEFT	RIGHT
1	1000	0.031623	7.741878
2	0.016684	7.741878	6.561000
3	0.023231	6.561000	6.665965
4	0.022505	6.665965	6.656104
5	0.022571	6.656104	6.657026
6	0.022565	6.657026	6.656940
7	0.022566	6.656940	6.656948
8	0.022566	6.656948	6.656947
9	0.022566	6.656947	6.656947
10	0.022566	6.656947	6.656947

LENGTH 5 m  
 DROP/m@THIS SECTION 3.393202 Pa/m

TOTAL DROP 16.96601 Pa  
1.73 mmAq  
 STATIC PRESSURE REGAIN -45.83263 Pa

USE DUCT 500 x 250 mm

Attachment

Project	Emission Gas Treatment (Electron Attachment System)	REV.	DATE
LINE	Stream 8	0	Mar.25'99
	MADE		

**STATIC REGAIN DUCT SIZING**

DENSITY 1.044 kg/m<sup>3</sup>      ROUGHNESS 0.15 mm  
 VISC. 0.019 cP = 0.000019 N.s/m<sup>2</sup>

	PREVIOUS	THIS	
WIDTH		500	mm
HIGH		250	mm
DIAMETER	16"	406.4	mm
		0.4064	m
AREA		0.129717	m <sup>2</sup>

FLOW 6708 m<sup>3</sup>/hr  
 VELOCITY 14.36459 m/s  
 REYNOLDS 320770.1

LENGTH 10 m  
 DROP/m@THIS SECTION 5.980716 Pa/m

TOTAL DROP 59.80716 Pa  
6.11 mmAq  
 STATIC PRESSURE REGAIN -80.78269 Pa

USE DUCT 380 x 190 mm

FRICTION OF THIS SECTION			
ITER.	f	LEFT	RIGHT
1	1000	0.031623	7.741878
2	0.016684	7.741878	6.561000
3	0.023231	6.561000	6.665965
4	0.022505	6.665965	6.656104
5	0.022571	6.656104	6.657026
6	0.022565	6.657026	6.656940
7	0.022566	6.656940	6.656948
8	0.022566	6.656948	6.656947
9	0.022566	6.656947	6.656947
10	0.022566	6.656947	6.656947

Attachment

Project	Emission Gas Treatment (Electron Attachment System)	REV.	DATE
LINE	Electron Attachment	0	Mar.25'99
	MADE		

**STATIC REGAIN DUCT SIZING**

DENSITY **0.902** kg/m<sup>3</sup>      ROUGHNESS **0.15** mm  
 VISC. **0.019** cP = 0.000019 N.s/m<sup>2</sup>

	PREVIOUS	THIS	
WIDTH		-	mm
HIGH		-	mm
DIAMETER	1"	25.4	mm
		0.0254	m
AREA		0.000507	m <sup>2</sup>

FLOW **0.2561** m<sup>3</sup>/hr  
 VELOCITY **0.140394** m/s  
 REYNOLDS **169.292**

LENGTH **3** m  
 DROP/m@THIS SECTION **0.007898** Pa/m

TOTAL DROP **0.023693** Pa  
**0.0024** mmAq  
 STATIC PRESSURE REGAIN **-0.006667** Pa

USE DUCT - x - mm


FRICTION OF THIS SECTION			
ITER.	f	LEFT	RIGHT
1	1000	0.031623	7.741878
2	0.016684	7.741878	6.561000
3	0.023231	6.561000	6.665965
4	0.022505	6.665965	6.656104
5	0.022571	6.656104	6.657026
6	0.022565	6.657026	6.656940
7	0.022566	6.656940	6.656948
8	0.022566	6.656948	6.656947
9	0.022566	6.656947	6.656947
10	<b>0.022566</b>	6.656947	6.656947

**ต้นฉบับ หน้าขาดหาย**

C-101  
DIRECT CONTACT COOLER  
DIA : 500x1500 mm  
PACKING : 1" PALLRING SS  
DP : -300/100 mmAq  
OT : 450 °C

T-101  
WATER TANK  
WxLxH: 1000x1800x1000 mm  
VOL : 1.8 m<sup>3</sup>

R-101  
ELECTRON ATTACHMENT REACTOR  
EFFICIENCY 80 %, SV 120 h<sup>-1</sup>



P-101  
CIRCULATING WATER PUMP  
13.4 m<sup>3</sup>/h, 26 m

B-101  
BLOWER  
CAPACITY : 5590 Nm<sup>3</sup>/h  
DIFF HEAD : 200 mmAq

แบบแสดงท่อและอุปกรณ์วัดคุม.

## EQUIPMENT LIST

Plant  
System

Emission Gas Treatment  
Electron Attachment System


Sheet 1 of 1

Rev	Date	Made	hecko	Approved
0	Feb,09,199	N.A	N.A	

ITEM NO.	NAME	NO. REQ'D		DESIGN CONDITION		OPERATING CONDITION		FLUID	TYPE	SPECIFICATIONS	MATERIAL	MOTOR kW	ELEC. kW	REMARKS	
		W	S	PRESS. barG	TEMP. °C	PRESS. barA	TEMP. °C								
				mmAq		mmAq									
1	R-101	Electron Attachment Reactor	1	-	-300/100 mmAq	200	-100 mmAq	150	Emission Gas	Electron Attachment	No,of tube 6800,CS Tube Dia 1"x3000 mm	CS/SS	-	-	
2	RX-101 -A-G	DC Generator	7	-	-	-	-	-	-	DC Generator	0-15 KV,0.4A	-	-	12	
3	C-101	Direct Contact Cooler	1	-	-300/100 mmAq	450	-200 mmAq	400/150	Emission Gas / Water	Packed Plate	Dia,500 mm x 1500 mm	CS	-	-	
4	CX-101 A	Packing	1	-	-300/100 mmAq	450	-200 mmAq	400/150	Emission Gas / Water	1" Pall Ring	Pack Height 500 mm	304LSS	-	-	
5	CX-101 B	Demister	1	-	-300/100 mmAq	450	-200 mmAq	400/150	Emission Gas / Water	Wire Mesh	80 Kg/m <sup>3</sup>	304LSS	-	-	
6	CX-101 C	Spray Nozzle	1	-	3	60	2	30	Water	Full Cone	13,4 m <sup>3</sup> /h , 60°, 2" NPT	Brass	-	-	
7	T-101	Water Tank	1	-	FW	60	ATM	30-40	Water	Rectangular w/ Partition and Wire Mesh 40	1000 x 1000 x 1800 mm Volume 1,8 m <sup>3</sup>	CS	-	-	
8	P-101	Water Pump	1	-	3	60	2.6	30	Water	Sump	13,4 m <sup>3</sup> /h , 26 m , 2.2 KW	CS/316SS	3		
9	B-101	Blower	1	-	-300/100 mmAq	200	-200 mmAq	54	Treated Gas	Centrifugal	5590 Nm <sup>3</sup> /h , 200 mmAq 5,5 KW , 380 V , 3 Ph , 50 HZ	CS/CS	7.5		




		PLANT :	EMISSION GAS TREATMENT																
<b>DESIGN DATA</b>		ITEM NO. :	C-101																
CODE	<input type="checkbox"/> ASME/ANSI RTP-1	<input type="checkbox"/> JIS B 824	<input checked="" type="checkbox"/> NONE																
DESIGN PRESS.	-0.05 bar / FW						<b>WEIGHT &amp; CAPACITY</b>												
DESIGN TEMP.	450 °C																		
CORROSION ALLOWANCE	1.0 mm																		
HYDRO. TEST PRESS.	<input type="checkbox"/> AS PER CODE	<input checked="" type="checkbox"/> FW kg/cm <sup>2</sup> G					ERECTION WEIGHT	200	kg										
PNEUM. TEST PRESS.	<input type="checkbox"/> AS PER CODE	<input checked="" type="checkbox"/> NONE kg/cm <sup>2</sup> G					OPERATING WEIGHT	200	kg										
POST WELD HEAT TREATMENT	<input type="checkbox"/> AS PER CODE	<input type="checkbox"/> YES	<input checked="" type="checkbox"/> NONE			FULL WATER WEIGHT	790	kg											
RADIOGRAPHY	<input checked="" type="checkbox"/> AS PER CODE	<input checked="" type="checkbox"/> NO					CAPACITY	0.6	m <sup>3</sup>										
LONG JOINT EFFICIENCY	<input type="checkbox"/> AS PER CODE	<input checked="" type="checkbox"/> 0.7					<b>NOZZLE SCHEDULE</b> <input checked="" type="checkbox"/> ANSI B16.5 <input type="checkbox"/>												
INSULATION	<input type="checkbox"/> HOT	<input type="checkbox"/> COLD	<input checked="" type="checkbox"/> P.P. (MM)		<input type="checkbox"/> NO														
WIND PRESSURE	None						MARK	NO. REQD	SIZE	RATING	TYPE	FACING	DESIGNATION						
EARTHQUAKE FACTOR	None						A	1	20"	Welding End		WATER OUTLET							
<b>MATERIAL SPECIFICATIONS</b>													B	1	10"	Cal		FF	GAS INTLET
													C	1	8"	Cal		FF	GAS INTLET
													D	1	2"	# 150	SW	RF	WATER INTLET
													SHELL & HEAD	CS					
SUPPORTS	CS																		
INTERNALS	SS																		
NOZZLE NECKS	CS																		
FLANGES	CS																		
BOLTS & NUTS	CS																		
GASKETS	CAF																		



2								
1								
0								FOR PROPOSAL
REV.	DWG	CHK	GL	SC	MGR	APPR	DATE	DESCRIPTION


DWG. NO.

		PLANT :	EMISSION GAS TREATMENT								
<b>DESIGN DATA</b>		ITEM NO. :	T-101								
CODE	<input type="checkbox"/> ASME/ANSI RTP-1	<input type="checkbox"/> JIS B 824	<input checked="" type="checkbox"/> NONE	SERVICE NAME :				WATER TANK			
DESIGN PRESS.	FW										
DESIGN TEMP.	60 °C										
CORROSION ALLOWANCE	1.0 mm										
				<b>WEIGHT &amp; CAPACITY</b>							
HYDRO. TEST PRESS.	<input type="checkbox"/> AS PER CODE	<input checked="" type="checkbox"/> FW	kg/cm <sup>2</sup> G	ERECTION WEIGHT	256			kg			
PNEUM. TEST PRESS.	<input type="checkbox"/> AS PER CODE	<input checked="" type="checkbox"/> NONE	kg/cm <sup>2</sup> G	OPERATING WEIGHT				kg			
POST WELD HEAT TREATMENT	<input type="checkbox"/> AS PER CODE	<input type="checkbox"/> YES	<input checked="" type="checkbox"/> NONE	FULL WATER WEIGHT				kg			
RADIOGRAPHY	<input type="checkbox"/> AS PER CODE	<input checked="" type="checkbox"/> NO		CAPACITY	1.6			m <sup>3</sup>			
LONG JOINT EFFICIENCY	<input type="checkbox"/> AS PER CODE	<input checked="" type="checkbox"/> 0.7		<b>NOZZLE SCHEDULE</b>				<input checked="" type="checkbox"/> ANSI B16.5			
INSULATION	<input type="checkbox"/> HOT	<input type="checkbox"/> COLD	<input checked="" type="checkbox"/> P.P. (MM)					<input type="checkbox"/> NO			
WIND PRESSURE	None			MARK	NO. REQD	SIZE	RATING	TYPE	FACING	DESIGNATION	
EARTHQUAKE FACTOR	None			A	1	20"	Weldind End		WATER INTLET		
<b>MATERIAL SPECIFICATIONS</b>				B	1	24"	# 150	SW	RF	WATER OUTLET	
				C	1	3/4"	# 150	NPT	NPT	MAKE UP WATER	
SHELL & HEAD	CS			D	1	1"	# 150	NPT	NPT	OVERFLOW	
SUPPORTS	CS			E1/2	2	3/4"	# 150	NPT	NPT	LG CONN.	
INTERNALS	CS / SS			F	1	3/4"	# 150	NPT	NPT	DRAIN	
NOZZLE NECKS	CS			G	1	3/4"	# 150	NPT	NPT	DRAIN	
FLANGES	CS			H	1	8"	# 150	NPT	NPT	HANDHOLE	
BOLTS & NUTS	CS			I	1	3/4"	# 150	NPT	NPT	TI CONN.	
GASKETS	CAF										



2											
1											
0										FOR PROPOSAL	
REV.	DWG	CHK	GL	SC	MGR	APPR	DATE	DESCRIPTION			DWG. NO.

				PLANT :	EMISSION GAS TREATMENT					
<b>DESIGN DATA</b>				ITEM NO. :	R-101					
CODE	<input type="checkbox"/> ASME/ANSI RTP-1	<input type="checkbox"/> JIS B 824	<input checked="" type="checkbox"/> NONE	SERVICE NAME :	ELECTRON ATTACHMENT REACTOR					
DESIGN PRESS.	-0.05 bar / FW			<b>WEIGHT &amp; CAPACITY</b>						
DESIGN TEMP.	450 °C									
CORROSION ALLOWANCE	1.0 mm									
HYDRO. TEST PRESS.	<input type="checkbox"/> AS PER CODE	<input checked="" type="checkbox"/> FW	kg/cm <sup>2</sup> G							
PNEUM. TEST PRESS.	<input type="checkbox"/> AS PER CODE	<input checked="" type="checkbox"/> NONE	kg/cm <sup>2</sup> G							
POST WELD HEAT TREATMENT	<input type="checkbox"/> AS PER CODE	<input type="checkbox"/> YES	<input checked="" type="checkbox"/> NONE	ERECTION WEIGHT	43690			kg		
RADIOGRAPHY	<input type="checkbox"/> AS PER CODE	<input checked="" type="checkbox"/> NO		OPERATING WEIGHT	43690			kg		
LONG JOINT EFFICIENCY	<input type="checkbox"/> AS PER CODE	<input checked="" type="checkbox"/> 0.7		FULL WATER WEIGHT	63690			kg		
INSULATION	<input type="checkbox"/> HOT	<input type="checkbox"/> COLD	<input checked="" type="checkbox"/> P.P. ( MM )	<input type="checkbox"/> NO	CAPACITY	18.5			m <sup>3</sup>	
WIND PRESSURE	None			<b>NOZZLE SCHEDULE</b>					<input checked="" type="checkbox"/> ANSI B16.5	
EARTHQUAKE FACTOR	None								<input type="checkbox"/>	
<b>MATERIAL SPECIFICATIONS</b>				MARK	NO. REQ'D	SIZE	RATING	TYPE	FACING	DESIGNATION
				A	1	190X380		Cal	FF	GAS INLET
				B	1	190X380		Cal	FF	GAS OUTLET
				C	1	20"		Cal	FF	DUST OUTLET
SHELL & HEAD	CS									
SUPPORTS	CS									
INTERNALS	CS									
NOZZLE NECKS	CS									
FLANGES	CS									
BOLTS & NUTS	CS									
GASKETS	CAF									



2									
1									
0									FOR PROPOSAL
REV.	DWG	CHK	GL	SC	MGR	APPR	DATE	DESCRIPTION	

DWG. NO.

					CENTRIFUGAL PUMP DATA SHEET						
Customer					Rev.	Date	Made	Chkd.	Auth.	Dscrpt	
Plant Location											
Unit											
Purchaser			Work No.								
Item No. P-101			Req. No.								
Service of Unit Water Pump											
No. Req'd Working 1		Standby -		Total 1		0	Mar25,1999	N.A			
OPERATING CONDITIONS											
LIQUID WATER					FLOW NOR	13.3	m3/h	RATED	16	m3/h	Rev.
CORR./ERO. BY					PRESSURE						
PUMP.TEMP. 30 MIN. MAX. 40 degC					DISCH.		2.569		barG		
SPEC.GRAV.@PT 0.992 MAX. 0.995					SUCT.RATED		0		MAX. barG		
VAPOR PRESS.@PT 0.042 barA					DIFF.		2.569		bar		
VISCOSITY @PT 0.66 mPa.s					TOTAL HEAD		25.9		m		
<b>CONSTRUCTION</b>					NPSH AVAIL.		9.9		m		
					INSTALLATION ( ) INDOOR ( ) OUTDOOR						
<b>MATERIALS</b>					CODE: CASE INTRN.						
					CASE DUCTILE IRON						
MFR MODEL ESP2					IMPELLER/INDUCER CS /						
TYPE ( ) HOR. ( X ) VERT. ( ) SELF PRIMING					CASE WRG RING HARD.						
CASE MT. ( ) BRACK ( X ) C-LINE ( ) FOOT ( ) VERT.					IMP.WRG RING TEFLON HARD.						
VERT. ( ) INLINE ( ) BARREL ( X ) SUMP ( ) SUBMERG					SHAFT STEEL						
CASE TYPE ( ) SINGLE-VOL. ( ) DBL-VOL. ( ) DIFFUSER					SLEEVE						
CASE SPLIT ( ) AXIAL ( ) RADIAL ( ) RING-SECT					CASE GASKET						
NOZZLE SIZE RATING FACE POSITION					( ) LINING						
SUCTION DISCH. 1 1/2" NPT TOP					<b>PERFORMANCE</b>						
NO.OF STAGES: 1 ( ) OVHG ( ) BET-BRG											
IMPELLER: ( ) CLOSED ( ) SEMI-OPEN ( ) OPEN					SPEED rpm		NPSH REQ. ( WTR )		m		
( X ) SINGLE SUCT. ( ) DBL SUCT. ( ) W/INDUCER					RATED EFF %		RATED BHP		kW		
DIA.DES. mm MAX/MIN mm					MIN.FLOW TH.		ST.		m3/h		
WRG RING DIA mm CLEAR mm					FLOW RATE @ BEP		MAX.OPE.PRESS.		barG		
BRG RADIAL Ball NO					CASE DES. TEMP.		degC		PRESS. barG		
THRUST Ball NO					HYDRO TEST PRESS.				barG		
DN VALUE mm.rpm					PNEUM TEST PRESS.				barG		
LUBE ( ) RING OIL ( ) FLOOD ( ) FLING ( ) PRESS					SUCT.SP.SPEED rpm.m3/m.m						
( ) GREASE ( ) PURE MIST ( ) PURGE MIST					PUMP CASE JACKET ( ) FULL ( ) PARTIAL						
POWER TRANSMISSION ( X ) DIRECT ( ) GEAR ( ) V-BELT					SEALING PRESS.				barG		
CPLG ( ) FLEX. ( ) GEAR ( ) DISK ( ) RIGD ( ) SPACER					( ) PACKING :MFR MAT'L NO.OF RINGS						
MFR MODEL					( ) MECH.SEAL :MFR MODEL MFR'S CODE						
ROTATION VIEWED FROM CPLG END ( ) CW ( ) CCW					MATERIAL :FACES VS METAL GASKET						
BASEPLATE ( X ) COMMON ( ) SOLE ( ) SEPARATE					AUXILIARY PIPING SERVICE FLUID		INLET CONDITIONS barG degC		FLOW m3/h		
SHAFT SEAL ( ) NON-SEAL ( )					PLAN NO.		MAT'L (#1)		CONNECTIONS SIZE RATING FACE		
( )											
( )											
TAPPED OPENG ( ) VENT ( ) VALVE ( ) CAP ( ) PLUG ( ) FLANGE ( )											
( ) DRAIN ( ) VALVE ( ) CAP ( ) PLUG ( ) FLANGE ( )											
AUTOMATIC ( ) START ( ) STOP											
VERT.PUMP: ( X ) SUMP LENGTH 1 m ( X ) W/SUCT.STRAINER ( ) THRUST ( UP/DOWN ) kg											
MASS:PUMP 136 kg BASE kg MOTOR 12 kg TURB. kg											
ELECT. MOTOR NO. ( 1 )											
SUPPL.BY Vendor MOUNT.BY Vendor											
MFR TYPE 2.2 kW											
RATED OUTPUT 2900 rpm POLES 2											
SPEED 3 HZ 50 VOLT 380											
HAZARD.AREA CLASS None											
REMARKS:											

**DATA SHEET  
FOR  
CENTRIFUGAL BLOWER**

1 CUSTOMER 2 LOCATION 3 UNIT <b>Gas Treatment System</b> 4 SUPPLIER 5 ITEM NO. <b>B-101</b> JOB NO. 6 SERVICE REQ'N NO. 7 NO. REQ'D (WORKING <b>1</b> STAND-BY - TOTAL <b>1</b> )	REV LINE   DATE   A/E   CHIEF   MGR.   PE.   PEM   PM 0   Mar26'99   N.A.
<b>OPERATING CONDITIONS</b>	
GAS COMPOSITION <b>Treated Gas</b>	CAPACITY <b>5590</b> Nm <sup>3</sup> /h DRY BASE m <sup>3</sup> /hr/ AT SUCTION
SOLID AT SUCTION (g/Nm <sup>3</sup> )	TEMP SUCTION <b>54.7</b> (°C)
R. H. AT SUCTION (%)	DISCHARGE <b>54</b> (°C)
MOLECULAR WEIGHT <b>28.45</b>	PRESS. DISCHARGE (STATIC) <b>0</b> mmAqG
SPEC. WEIGHT AT SUCTION <b>1.044</b> (kg/m <sup>3</sup> )	SUCTION RATED (STATIC) <b>-200</b> mmAqG
COMP. FACTOR (Z)	DIFF. (STATIC) <b>200</b> mmAqG
INSTALLATION <input type="checkbox"/> INDOOR <input checked="" type="checkbox"/> OUTDOOR	
<b>CONSTRUCTIONS</b>	
MFR. # <b>FY-15BCD-B</b>	CODE
TYPE <input checked="" type="checkbox"/> CENTRIF-BACKWARD <input type="checkbox"/> CENTRIF-RADIAL	CASE/HOUSING <b>INTERNAL</b>
<input type="checkbox"/> MULTI-BLADE <input type="checkbox"/> MIXED FLOW <input type="checkbox"/> AXIAL	IMPELLER <b>SS41</b>
CASE: MOUNT <input type="checkbox"/> BRACKET <input type="checkbox"/> FOOT <input type="checkbox"/> C-LINE <input type="checkbox"/> CAST	SHAFT <b>S35C</b>
: SPLIT <input type="checkbox"/> AXIAL <input type="checkbox"/> RADIAL	SLEEVE
: CONSTRUCTION <input checked="" type="checkbox"/> FABRICATED <input type="checkbox"/> CAST	GASKET
DIA. VALUE	LABYRINTH
NOZZLE SIZE RATING FACING POSITION	BASEPLATE <b>SSC41</b>
SUCTION # # FF END	<input type="checkbox"/> LINING
DISCH # # FF TOP	
<b>PERFORMANCE</b>	
WHEEL NO. <input type="checkbox"/> OVHG <input type="checkbox"/> BET-BRG	SPEED (rpm) EFF. (STATIC) (%)
TYPE <input type="checkbox"/> CLOSED <input type="checkbox"/> SEMI-OPEN <input type="checkbox"/> OPEN	BHP RATED AT MIN. TEMP (kW)
SUCTION <input checked="" type="checkbox"/> SINGLE <input type="checkbox"/> DOUBLE	SUCTION <input type="checkbox"/> NET <input type="checkbox"/> FILTER <input type="checkbox"/> SILENCER
HUB FIT	MFR TYPE
CONSTRUCTION <input type="checkbox"/> FABRICATED <input type="checkbox"/> CAST	PD CLEAN MAX (mmAqG)
DIA. (mm.) CLEARANCE (mm.)	<input type="checkbox"/> SUCTION DAMPER <input type="checkbox"/> DISCHARGE DAMPER
BLADE TYPE <input type="checkbox"/> HOLLOW <input type="checkbox"/> SOLID AIRFOIL	CONTROL <input type="checkbox"/> MAN <input type="checkbox"/> AUTO.
<input type="checkbox"/> SINGLE-THICK, NO. OF BLADES	SIGNAL <input type="checkbox"/> ELEC <input type="checkbox"/> PNEUM RANGE (%)
BEARING RADIAL NO.	MAX OPERATING RPRESS. (mmAqG)
TURUST NO.	CASE DES PRESS (kg/cm <sup>2</sup> G TEMP (°C)
BEARING HOUSE CONSTRUCTION	<input type="checkbox"/> CASE HYD. TEST PRESS (kg/cm <sup>2</sup> G)
LUBE <input type="checkbox"/> OIL RING <input type="checkbox"/> FLOOD <input type="checkbox"/> FLING <input type="checkbox"/> PRESS	TYPE OF SEAL
<input type="checkbox"/> GREASE <input type="checkbox"/> MIST-PURE <input type="checkbox"/> MIST-PURGE	<input type="checkbox"/> MEACH. SEAL MFR
POWER TRANS <input type="checkbox"/> DIRECT <input type="checkbox"/> GEAR <input type="checkbox"/> V-BELT <input type="checkbox"/> SPD'VAR	MODEL NO. OF SEAL
COUPLING <input type="checkbox"/> FLEX <input type="checkbox"/> RIGID <input type="checkbox"/> F-DISK <input type="checkbox"/> SPACER	TYPE API CODE
MFR MODEL	MFR'S CADE
ROTATION VIEWED FROM CPL'G END <input type="checkbox"/> CW <input type="checkbox"/> CCW	MAT'L FACE VS
BASEPLATE <input checked="" type="checkbox"/> COMMON <input type="checkbox"/> SOLE <input type="checkbox"/> SEPARATE	METAL GASKET
<input type="checkbox"/> GROUTING REQUIREMENT	OTHER SEAL MFR
NOZZLE ORIENTATION TYPE NO.	MODEL NO. OF RING
APPL. ENG. SPEC	MATERIAL
CODE/STANDARD	
<b>AUX CONNECTIONS</b>	
SERVICE FLUID	INLET CONDITION (kg/cm <sup>2</sup> G) (°C)
	SP. OR. (DG)
	FLOW (m <sup>3</sup> /h)
	MATERIAL (#1)
	SIZE
	RATING
	RANGE
TAPPED OPENING <input type="checkbox"/> DRAIN <input type="checkbox"/> VALVE <input type="checkbox"/> CAP <input type="checkbox"/> PLUG <input type="checkbox"/> FLANGE (SIZE RATE FACE)	
SPACE REQ'T (L*W*H) (m) HAZARD CLASS	
NOISE LEVEL (dBA@1m) <input type="checkbox"/> ACOUST ENCLOSURE SUPPLIED BY VENDOR	
WEIGHT (kg) BLOWER	BASE MOTOR
<b>MOTOR</b>	
SUPPLIED BY VENDOR	MOUNTED BY VENDOR
MFR. TYPE	TEFC
RATED OUTPUT <b>5.5</b> (kW) POLE	
SPEED (rpm)	
PHASE <b>3</b> CYCLE <b>50</b> VOLTS <b>380</b>	
INSULATION CLASS <b>IP</b>	
HAZARDOUS AREA CLASS <b>-</b>	
<b>TURBINE</b>	
SUPPLIED BY	MOUNTED BY
MFR.	TYPE
RATED OU kW	(kW) SPEED (rpm)
INLET STEAM	(kg/cm <sup>2</sup> G) (°C)
EXHAUST	(kg/cm <sup>2</sup> G)
BRG	LUBE
STEAM RATE (kg)	AT RATED
NOZZLE ORIENTATION VIEWED FROM CPL'G END	
<b>REMARKS</b>	

แบบแสดงข้อมูลของพัดลม (B-101).

		PACKING DATASHEET		
1	CUSTOMER	DATE		
2	LOCATION	AUTH. BY	CHKD. BY	MADE BY
3	UNIT			
4	SUPPLIER	JOB NO.	REV. DATE	LINE NO.
5	ITEM NO. CX-101A	REQ. NO.		BY
6	SERVICE PACKING			
7	NO. REQ'D 1 STAND BY - TOTAL 1			
8				
9				
10	TYPE	:	RASCHIG RING	
11	SIZE	:	1"	
12	CAPACITY	:	0.1 M <sup>3</sup>	
13	MATERIAL	:	SS 304L	
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				
26				
27				
28				
29				
30				
31				
32				
33				
34				
35				


		<b>DEMISTER</b>		
		DATASHEET		
1	<b>CUSTOMER</b>	<b>DATE</b>	APR.15,1999.	
2	<b>LOCATION</b>	<b>AUTH. BY</b>	<b>CHKD. BY</b>	<b>MADE BY</b>
3	<b>UNIT</b>			
4	<b>SUPPLIER</b>	<b>JOB NO.</b>	<b>REV. DATE</b>	<b>LINE NO.</b>
5	<b>ITEM NO.</b> CX-101B	<b>REQ. NO.</b>		<b>BY</b>
6	<b>SERVICE</b> DEMISTER			
7	<b>NO. REQ'D</b> 1 STAND BY - TOTAL 1			
8				
9	<b>APPLICATION</b>	:	DIRECT CONTACT COOLER	
10	<b>PURPOSE</b>	:	OVERHEAD QUALITY SEPERATED ENTRAINED	
11			LIQUID DROPLET FROM GAS	
12	<b>OPERATING CONDITION</b>	:	-100 mmAq	
13			150 °C	
14			1741.8 m <sup>3</sup> /h	
15	<b>SPECIFICATION</b>	:		
16	-STYLE	:	421	
17	-DIAMETER	:	420 mm	
18	-THICKNESS	:	150 mm	
19	-MATERIAL	:	304LSS	
20	-SPECIAL HOUSING	:	YES	
21				
22				
23				
24				
25				
26				
27				
28				
29				
30				
31				
32				
33				
34				
35				

แบบแสดงข้อมูลของอุปกรณ์กำจัดละออง (CX-101B).

		<b>SPRAY NOZZLE</b>		
		DATASHEET		
1	<b>CUSTOMER</b>	<b>DATE</b>		
2	<b>LOCATION</b>	<b>AUTH. BY</b>	<b>CHKD. BY</b>	<b>MADE BY</b>
3	<b>UNIT</b>			
4	<b>SUPPLIER</b>	<b>JOB NO.</b>	<b>REV. DATE</b>	<b>LINE NO.</b>
5	<b>ITEM NO.</b> CX-101C	<b>REQ. NO.</b>		<b>BY</b>
6	<b>SERVICE</b> SPRAY NOZZLE			
7	<b>NO. REQ'D</b> 1 STAND BY - TOTAL 1			
8				
9	MANUFACTURER	:		
10	MODEL	:		
11	TYPE	:	60° FULL CONE	
12	CAPACITY	:	13.5 m³/h	
13	PRESSURE INLET	:	2 BAR G.	
14	DENSITY	:	995 kg/m³	
15	VISCOSITY	:	0.8 cP	
16	MATERIAL	:	BRASS	
17	APPROXIMATE WEIGHT	:	2.7 kg	
18	ACCESSORIES	:		
19				
20				
21				
22				
23				
24				
25				
26				
27				
28				
29				
30				
31				
32				
33				
34				
35				



		<b>DC GENERATOR</b>		
		DATASHEET		
1	<b>CUSTOMER</b>	<b>DATE</b>	APR.15,1999.	
2	<b>LOCATION</b>	<b>AUTH. BY</b>	<b>CHKD. BY</b>	<b>MADE BY</b>
3	<b>UNIT</b>			
4	<b>SUPPLIER</b>	<b>JOB NO.</b>	<b>REV. DATE</b>	<b>LINE NO.</b>
5	<b>ITEM NO.</b> RX-101	<b>REQ. NO.</b>		
6	<b>SERVICE</b> DC GENERATOR			
7	<b>NO. REQ'D</b> 7 STAND BY - TOTAL 7			
8				
9	<b>TYPE</b>	: DC GENERATOR		
10	<b>INPUT DATA</b>			
11	<b>-VOLTAGE</b>	: 220 V		
12	<b>-FREQUENCY</b>	: 50 HZ		
13	<b>OUTPUT REQUIREMENT</b>			
14	<b>-VOLTAGE</b>	: 0~20 KV		
15	<b>-CURRENT</b>	: 0~ 0.4mA		
16	<b>-ADJUSTABLE VOLTAGE</b>	: YES		
17	<b>-ADJUSTABLE AMPARE</b>	: YES		
18	<b>-STABILITY SYSTEM</b>	: YES		
19				
20				
21				
22				
23				
24				
25				
26				
27				
28				
29				
30				
31				
32				
33				
34				
35				



แบบแสดงผังตำแหน่งของอุปกรณ์.

LAY-OUT DRAWING  
OF  
GAS EMISSION TREATMENT SYSTEM

Rev	Date	Made	Checke	Aprr
0	04/06/99	N.A	N.A	

ELECTRICAL CONSUMPTION LIST


Plant System

Emission Gas Treatment  
Electron Attachment System

Sheet 1 of 1

NO.	ITEM NO.	NAME	NO. REQ'D		Capacity (KW)	Phase	Voltage (V)	Frequency (Hz)	Motor Type	Start Method	Speed (rpm)	REMARKS
			W	S								
1	P-101	Water Pump	1	-	2.2	3	380	50	Vertical TEFC, Outdoor	Direct on-line	1450	
2	B-101	Blower	1	-	7.5	3	380	50	Horizontal TEFC, Outdoor	Direct on-line	2900	
3	RX-101	DC Generator	1	-	12.5	1	220	-	-	-	-	

แบบแสดงรายการใช้ไฟฟ้าของอุปกรณ์ในระบบ:



แบบแสดงผังไฟฟ้าสายเดี่ยว.

INSTRUMENT DATA SHEET ( TEMPERATURE )		System : Electron Attachment		
		Sheet No. : 1/1		
		Rev : 0		
		Rev Date : Apr.06, 1999		
		Made By : N.A		
1	STREAM No.	-	5	8
2	TAG No.	TI 101	TI 102	TI 103
3	QUANTITY	1	1	1
4	SERVICE	T-101	R-101 Inlet	B-101 Outlet
5	PHASE	Liquid	Gas	Gas
6	DESIGN TEMPERATURE, °C	60	400	400
7	DESIGN PRESSURE, BAR	FW	-200 mmAq	100 mmAq
8	OPER. PRESSURE, BAR A	ATM	-100 mmAq	25 mmAq
15	MAX. TEMP., °C	50	400	400
16	NOR. TEMP., °C	40	150	54.7
17	MIN. TEMP., °C	30	-	-
18	ALARM ACTION	-	-	-
19	ALARM SET POINT, °C	-	-	-
20	METER RANGE, °C	0~100	0~400	0~400
21	SPECIAL INSTRUMENT TY	Bi-Metal	Bi-Metal	Bi-Metal
22	SPECIAL MATERIAL	-	-	-
23	LINE SIZE, INCH	3/4	3/4	3/4
24	LINE CLASS	-	-	-
25	REMARKS	-	-	-
26	P & ID No.	1	1	1

INSTRUMENT DATA SHEET ( PRESSURE )

System : Electron

Attachment


Sheet No. : 1/1

Rev : 0

Rev Date : Apr.06, 1999

Made By : N.A

1	STREAM No.	9	8		
2	TAG No.	PI 101	PI 102		
3	QUANTITY	1	1		
4	SERVICE	P-101	Air to Stack		
5	FLUID	Water	Treated Gas		
6	PHASE	Liquid	Gas		
7	DESIGN TEMPERATURE,	60	150		
8	OPER. TEMPERATURE, °	30-40	54.7		
9	DESIGN PRESSURE, BAR	3	200 mmAq		
10	MAX. PRESSURE, BAR A	3	50 mmAq		
11	NOR. PRESSURE, BAR A	2.6	25 mmAq		
12	MIN. PRESSURE, BAR A	-	0 mmAq		
13	ALARM ACTION	-	-		
14	ALARM SET POINT, BAR A	-	-		
15	METER RANGE, BAR G	0 ~ 6	-200 ~200 mmAq		
16	SPECIAL INSTRUMENT TY	Bourdon	Barometer		
17	SPECIAL MATERIAL	-	-		
18	LINE SIZE, INCH	1/2	1/2		
19	LINE CLASS	CS	CS		
20	REMARKS	-	-		
21	P & ID No.	1	1		




แบบแสดงการจัดเรียงจำนวนท่อของถังปฏิกรณ์.

ภาคผนวก ๘ สรุปการคำนวณสมการการเผาไหม้ของก๊าซเชื้อเพลิงของระบบ After Burning



ตาราง ฏ 1 เอนทาลปีจากการเผาไหม้ก๊าซเชื้อเพลิง



of LPG (Propane)

Reference Temperature : 298 K

Heating Value of Propane : 2212939 KJ/Kmol


Fuel Supply : 0.24 Kmol/h

Combustion Enthalpy : 521524.0 KJ/h

No	Component	MW	Enthalpy Formula		Molar Generated (Kmol/h)	b/2(T <sup>2</sup> -T <sub>r</sub> <sup>2</sup> )	a(T-Tr)	a(T-T <sub>r</sub> )+b/2(T <sup>2</sup> -T <sub>r</sub> <sup>2</sup> )	Flame Temp.	
			a(T-T <sub>r</sub> )+b/2(T <sup>2</sup> -T <sub>r</sub> <sup>2</sup> )						(K)	(°C)
			a	b						
1	N <sub>2</sub>	28	29.231	0.00307	4.430502	0.0068 (T <sup>2</sup> -298 <sup>2</sup> )	129.51 (T-298)	0.014338 T <sup>2</sup> + 198.19 T -581858	2488	2215
2	H <sub>2</sub> O	18	32.477	0.00862	1.1500452	0.00496 (T <sup>2</sup> -298 <sup>2</sup> )	37.35 (T-298)			
3	CO <sub>2</sub>	44	44.319	0.00730	0.706995	0.00258 (T <sup>2</sup> -298 <sup>2</sup> )	31.33 (T-298)			
4	O <sub>2</sub>	32	30.504	0.00349	0	0 (T <sup>2</sup> -298 <sup>2</sup> )	0.00 (T-298)			
	Subtotal				6.2875422	0.01434 (T <sup>2</sup> -298 <sup>2</sup> )	198.19 (T-298)			

ตาราง ฏ 2 สมดุลพลังงานของการเผาไหม้ก๊าซเชื้อเพลิง

Theoretical Combustion :  
of LPG (Propane)  
Reference Temperature :



298 K

No	Component	MW	Enthalpy Formula $a(T-T_r)+b/2(T^2-T_r^2)$		Inlet Stream							Outlet Stream		
					Emission Gas Condition			Fuel Condition				Flue Gas Outlet		
					a	b	molar (Kmol/h)	Temp. (K)	Enthalpy (KJ/h)	Fuel Supply (Kmol/h)	Theo. molar (Kmol/h)	Temp. (K)	Enthalpy (KJ/h)	molar (Kmol/h)
1	N <sub>2</sub>	28	29.231	0.00307	36.70	673	422804	0.24	18.80	2488	325116.6	41.13	888.6	754315.5
2	H <sub>2</sub> O	18	32.477	0.00862	6.67	673	91701	0.24	4.88	2488	112039	7.82	888.6	173616
3	CO <sub>2</sub>	44	44.319	0.00730	6.20	673	111282	0.24	3.00	2488	84365	6.91	888.6	198457
4	O <sub>2</sub>	32	30.504	0.00349	2.92	673	35257	0.24	0	2488	0	2.92	888.6	56177
	Subtotal				52.49		661044		6.29		521520.3	58.78		1182565
Total Molar (Kmol/h)											58.78	Total Molar (Kmol/h)		58.78
Total Enthalpy (KJ/h)											1182565	Total Enthalpy (KJ/h)		1182565

ภาคผนวก ฏ สมดุลมวลสารขององค์ประกอบของก๊าซทิ้งหลังปฏิกิริยาการเผาไหม้ของระบบ  
After Burning

ตาราง ฏ 1 สมดุลมวลสารขององค์ประกอบของก๊าซทิ้งหลังปฏิบัติการเผาไหม้ของระบบ

After Burning

Total Emission Gas Inlet :	1512.2 Kg/h	52.43 Kmol/h
Total Flue Gas out of After Burner :	1687.9 Kg/h	58.71 Kmol/h
Av. Conc. of NOx Inlet :	8000 ppm	0.4195 Kmol/h
Av. Conc. of SOx Inlet :	580 ppm	0.0304 Kmol/h

NO.	Component	Theo. Combustion Formula	Conc in		Conc out		NOx Comb Prod (Kmol/h)	SOx Comb Prod (Kmol/h)
			(ppm)	(Kmol/h)	(ppm)	(Kmol/h)		
1	Acetic Acid	$\text{CH}_3\text{COOH} + 2\text{O}_2 \longrightarrow 2\text{CO}_2 + 2\text{H}_2\text{O}$	2400	0.12584	21.43465	0.00126	0.00000	0.00000
2	Propane	$\text{C}_3\text{H}_8 + 5\text{O}_2 \longrightarrow 3\text{CO}_2 + 4\text{H}_2\text{O}$	23000	1.20598	0.00000	0.00000	0.00000	0.00000
3	Acetaldehyde	$\text{CH}_3\text{CHO} + 5/2\text{O}_2 \longrightarrow 2\text{CO}_2 + 2\text{H}_2\text{O}$	4	0.00021	0.03572	0.00000	0.00000	0.00000
4	Stryrene	$\text{C}_6\text{H}_5\text{CH}=\text{CH}_2 + 10\text{O}_2 \longrightarrow 8\text{CO}_2 + 4\text{H}_2\text{O}$	1	0.00005	0.00893	0.00000	0.00000	0.00000
5	Hydrogen Sulfide	$\text{H}_2\text{S} + 3/2\text{O}_2 \longrightarrow \text{SO}_2 + \text{H}_2\text{O}$	1	0.00005	0.00893	0.00000	0.00000	0.00005
6	Methyl Mercaptan	$\text{CH}_3\text{SH} + 3\text{O}_2 \longrightarrow \text{SO}_2 + \text{CO}_2 + 2\text{H}_2\text{O}$	0.1	0.00001	0.00089	0.00000	0.00000	0.00001
7	Dimethyl Sulfide	$(\text{CH}_3)_2\text{S} + 9/2\text{O}_2 \longrightarrow \text{SO}_2 + 2\text{CO}_2 + 3\text{H}_2\text{O}$	0.1	0.00001	0.00089	0.00000	0.00000	0.00001
8	Ammonia	$\text{NH}_3 + 5/4\text{O}_2 \longrightarrow \text{NO} + 3/2\text{H}_2\text{O}$	37	0.00194	0.33045	0.00002	0.00192	0.00000
9	Trimethyl Amine	$(\text{CH}_3)_3\text{N} + 25/4\text{O}_2 \longrightarrow \text{NO} + 3\text{CO}_2 + 9/2\text{H}_2\text{O}$	2.3	0.00012	0.02054	0.00000	0.00012	0.00000
							0.00204	0.00006

Table 2 : Total Outlet Concentration of NOx and SOx

NO.	Component	Inlet Conc		Comb Prod (Kmol/h)	Total Outlet (Kmol/h)	Outlet Conc (ppm)
		(ppm)	(Kmol/h)			
1	NOx	8000	0.41947	0.00204	0.42151	7179.6
2	SOx	580	0.03041	0.00006	0.03047	519.1

ภาคผนวก ฐ สรุปการคำนวณออกแบบเตาเผาซ้ำของระบบ After Burning



ตาราง รุ.1 ข้อมูลเบื้องต้นในการคำนวณออกแบบเตาเผาซ้ำ

	HAP Emission Stream Characteristic		Metric Unit		English Unit	
1	Maximum Flow Rate	$Q_e$	(Nm <sup>3</sup> /h)	1176.4	(SCFM)	731.9
2	Density of Emission Gas	$D_e$	(Kg/Nm <sup>3</sup> )	1.2855	(lb/SCF)	0.0759
3	Temperature of Emission Gas	$T_e$	(°C)	400	(°F)	752
4	Heat Content of Emission Gas	$h_e$	(KJ/Kg)	436	(Btu/lb)	187.2
5	Oxygen Content	$O_2$	(%)	5.56	(%)	5.56
6	Halogenated Organics		No			
7	Required Destruction Efficiency	DE	(%)	99	(%)	99
8.1	Type of Supplementary Fuel		LPG (as Propane)			
8.2	Density of Fuel	$D_f$	(Kg/Nm <sup>3</sup> )	1.12	(lb/SCF)	0.0662
8.3	Heat Content of Fuel	$h_f$	(KJ/Kg)	50295.2	(Btu/lb)	21600.0
9	Existing Combustion Chamber Volume	$V_e$	(m <sup>3</sup> )	1	(ft <sup>3</sup> )	35.3


ตาราง รุ.2 การคำนวณออกแบบขนาดเตาเผาซ้ำ

1	Required Destruction Efficiency	DE	(%)	99	(%)	99
2	Mean Residence Time	$t_r$	(sec)	1.5	(sec)	1.5
3	Fast Path Residence Time	$t_f$	(sec)	0.75	(sec)	0.75
4	Combustion Temperature	$T_c$	(°C)	982.2	(°F)	1800
5	Max. Temperature in Chamber	$T_m$	(°C)	1482.2	(°F)	2700
6	Exit Temperature	$T_{ex}$	(°C)	982.2	(°F)	1800
7	Estimated Heat Loss	HL	(%)	3	(%)	3
8	Supplementary Fuel Requirement	$Q_f$	(Nm <sup>3</sup> /h)	5.3	(SCFM)	3.3
9	Combustion Air Requirement	$Q_{fa}$	(Nm <sup>3</sup> /h)	140.9	(SCFM)	87.7
10	Combustion Gas Flow Rate	$Q_{fc}$	(Nm <sup>3</sup> /h)	146.3	(SCFM)	91.05
11	Flue Gas Flow Rate	$Q_{fg}$	(Nm <sup>3</sup> /h)	1322.7	(SCFM)	823.0
12	Combustion Chamber Volume	$V_c$	(m <sup>3</sup> )	3.40	(ft <sup>3</sup> )	120.1

**Table 1 : Typical Temperature and Residence Time of Typical Incinerator**

Vol of Chamber :	120.1	ft <sup>3</sup>	3.4	m <sup>3</sup>
Flow Rate :	823	SCFM	1323	Nm <sup>3</sup> /h
Max. Temperature	2700	(°F)	1755	K
Exit Temperature:	1800	(°F)	1255	K

Temperature (K)	Temperature (oF)	Mean Residence Time (sec)	Fast Path Time (sec)
1700	2600	0.14	0.07
1644	2500	0.29	0.15
1589	2400	0.45	0.22
1533	2300	0.61	0.30
1477	2200	0.77	0.39
1422	2100	0.94	0.47
1366	2000	1.12	0.56
1311	1900	1.31	0.65
1255	1800	1.50	0.75



ภาคผนวก ๓ สรุปการคำนวณออกแบบไซโคลนของระบบ After Burning



ตาราง ท.1      สรุปพารามิเตอร์ในการคำนวณ

Use : Stairmand Standard Design

Parameter	Constant	Dimensions (mm)	
$Q/D^2$	16500	D	423
$a/D$	0.75	a	317
$b/D$	0.375	b	159
$D_c/D$	0.75	$D_c$	317
$S/D$	0.875	S	370
$h/D$	1.5	h	635
$H/D$	4	H	1693
$B/D$	0.375	B	159

ตาราง ท.2      การคำนวณความดันลดภายในไซโคลน

del P allowable not exceed 100 mmAq

Parameter	Value
del H	7.2
$v_i$	16.30 m/s
del P	482.8 Pa
	49.22 mmAq

ตาราง ท.3      การคำนวณประสิทธิภาพการกำจัดฝุ่นของไซโคลน

$n_{283}$	$n_{673}$	$w/d^2$	Parameter			
			$eff=1-\exp(-2(Cwd^2)^{1/(2n+2)})$			
			d av ( $\mu m$ )			
			22	53.5	84	127
0.594	0.47350	$7.356E+07$	0.912742	0.98841	0.997653	0.99967

Part. Size ( $\mu m$ )	Mean Size ( $\mu m$ )	Fraction	Efficiency	Fraction*Efficiency	Dust Outlet Conc. (mg/m <sup>3</sup> )
0-44	22	0.8	0.912742	0.73019	12.85454
44-63	53.5	0.1	0.98841	0.09884	0.21342
63-105	84	0.05	0.997653	0.04988	0.02161
105-149	127	0.05	0.99967	0.04998	0.00304
<b>Total</b>		<b>1</b>		<b>0.92890</b>	<b>13.0926</b>

ภาคผนวก ฉ สรุปการคำนวณความดันสูญเสียของระบบ After Burner เพื่อกำหนดขนาดของพัดลม

ตาราง ผ.1 สรุปการคำนวณความดันสูญเสียของระบบ After Burner

Stream	Fitting		Type of Fitting	Flow Rate (m <sup>3</sup> /h)	Duct Size Equiv. (mm)	Velocity (m/s)	Velocity Press (Pa)	Length (m)	Fitting loss coefficient C <sub>o</sub>	Duct Press drop /m (Pa)	Total Press drop (Pa)	Sectional drop (Pa)	Overall Press drop	
	No.	Source											(Pa)	(mmAq)
1,2	1	-	Duct	2954.5	304.8	11.25	31.95	10	-	2.365	23.654	95.549	1959.0	199.7
	2	6.6,6.2	Tee Tr	2954.5	-	11.25	31.95	-	0.55	-	17.574			
	3	7.4	Gate	2954.5	-	11.25	31.95	-	1.7	-	54.3206			
-	D-201			-	-	-	-	-	-	-	482.8	482.8		
3	1	-	Duct	2954.5	304.8	11.25	31.95	3.5	-	2.365	8.279	20.741		
	2	3.5	Elbow	2954.5	-	11.25	31.95	-	0.13	-	4.154			
	3	3.5	Elbow	2954.5	-	11.25	31.95	-	0.13	-	4.154			
	4	3.5	Elbow	2954.5	-	11.25	31.95	-	0.13	-	4.154			
-	Y-201			-	-	-	-	-	-	-	981	981		
6	1	-	Duct	6046.5	355.6	16.91	39.93	1.5	-	2.534	3.801	363.321		
	2	4.2	Diffuser	6046.5	-	16.91	39.93	-	0.58	-	23.161			
	3	-	Duct	56782.2	1270	12.45	87.62	5	-	1.557	7.783			
	4	7.4	Gate	56782.2	-	12.45	87.62	-	3.2	-	280.385			
	5	6.6,6.2	Tee Tr	56782.2	-	12.45	87.62	-	0.55	-	48.191			
8	1	-	Duct	63596.9	1270	13.95	1.79	10	-	1.557	15.567	15.567		

Project	Emission Gas Treatment (After Burner System)	REV.	DATE
LINE	Stream 1	0	Mar.25'99
	MADE		

**STATIC REGAIN DUCT SIZING**

DENSITY 0.505 kg/m<sup>3</sup>      ROUGHNESS 0.15 mm  
 VISC. 0.0348898 cP = 3.49E-05 N.s/m<sup>2</sup>

	PREVIOUS	THIS	
WIDTH		380	mm
HIGH		190	mm
DIAMETER	12"	304.8	mm
		0.3048	m
AREA		0.072966	m <sup>2</sup>
FLOW		2954.5	m <sup>3</sup> /hr
VELOCITY		11.24765	m/s
REYNOLDS		49621.46	

FRICTION OF THIS SECTION			
ITER.	f	LEFT	RIGHT
1	1000	0.031623	7.741867
2	0.016684	7.741867	6.560321
3	0.023235	6.560321	6.665379
4	0.022509	6.665379	6.655506
5	0.022576	6.655506	6.656429
6	0.022569	6.656429	6.656343
7	0.02257	6.656343	6.656351
8	0.02257	6.656351	6.656350
9	0.02257	6.656350	6.656350
10	0.02257	6.656350	6.656350

LENGTH 10 m  
 DROP/m@THIS SECTION 2.365361 Pa/m

TOTAL DROP 23.65361 Pa  
2.42 mmAq  
 STATIC PRESSURE REGAIN -23.95775 Pa

USE DUCT 380 x 190 mm

ตาราง ผ.3 การคำนวณความดันสูญเสียของสายการไหลที่ 3 ของระบบ After Burning

Project	Emission Gas Treatment (After Burner Sysytem)		REV.	DATE
LINE	Stream 3	MADE	0	Mar.25'99
<b>STATIC REGAIN DUCT SIZING</b>				
DENSITY	0.505	kg/m <sup>3</sup>	ROUGHNESS	0.15
VISC.	0.0348898	cP =		3.49E-05
				N.s/m <sup>2</sup>
PREVIOUS	THIS		FRICTION OF THIS SECTION	
WIDTH		380	mm	
HIGH		.190	mm	
DIAMETER	12"	304.8	mm	
		0.3048	m	
AREA		0.072966	m <sup>2</sup>	
FLOW		2954.5	m <sup>3</sup> /hr	
VELOCITY		11.24765	m/s	
REYNOLDS		49621.46		
LENGTH		3.5	m	
DROP/m@THIS SECTION		2.365361	Pa/m	
TOTAL DROP		8.278765	Pa	
STATIC PRESSURE REGAIN		0.85	mmAq	
USE DUCT	380	x	190	mm

ตาราง ผ.4 การคำนวณความดันสูญเสียของสายการไหลที่ 6 ของระบบ After Burning

Project	Emission Gas Treatment (After Burner System)	REV.	DATE
LINE	Stream 6	0	Mar.25'99
	MADE		

### STATIC REGAIN DUCT SIZING

DENSITY **0.27916** kg/m<sup>3</sup>      ROUGHNESS **0.15** mm  
 VISC. **0.019** cP = 0.000019 N.s/m<sup>2</sup>

	PREVIOUS	THIS	
WIDTH		450	mm
HIGH		225	mm
DIAMETER	14"	355.6	mm
		0.3556	m
AREA		0.099315	m <sup>2</sup>

FLOW **6046.5** m<sup>3</sup>/hr  
 VELOCITY **16.91174** m/s  
 REYNOLDS **88358.74**

LENGTH **1.5** m  
 DROP/m@THIS SECTION **2.53376** Pa/m

TOTAL DROP **3.80064** Pa  
**0.39** mmAq  
 STATIC PRESSURE REGAIN **-29.94062** Pa

USE DUCT **450** x **225** mm

FRICTION OF THIS SECTION			
ITER.	f	LEFT	RIGHT
1	1000	0.031623	7.741867
2	0.016684	7.741867	6.560321
3	0.023235	6.560321	6.665379
4	0.022509	6.665379	6.655506
5	0.022576	6.655506	6.656429
6	0.022569	6.656429	6.656343
7	0.02257	6.656343	6.656351
8	0.02257	6.656351	6.656350
9	0.02257	6.656350	6.656350
10	<b>0.02257</b>	6.656350	6.656350

Project	Emission Gas Treatment (After Burner Systeem)	REV.	DATE
LINE	Stream 7	0	Mar.25'99
	MADE		

**STATIC REGAIN DUCT SIZING**

DENSITY **1.13** kg/m<sup>3</sup>      ROUGHNESS **0.15** mm  
 VISC. **0.0183** cP = 1.83E-05 N.s/m<sup>2</sup>

	PREVIOUS	THIS	
WIDTH		1600	mm
HIGH		800	mm
DIAMETER	50"	1270	mm
		1.27	m
AREA		1.266769	m <sup>2</sup>

FLOW **56782.2** m<sup>3</sup>/hr  
 VELOCITY **12.45123** m/s  
 REYNOLDS **976435.3**

LENGTH **5** m  
 DROP/m@THIS SECTION **1.556672** Pa/m

TOTAL DROP **7.783362** Pa  
**0.79** mmAq  
 STATIC PRESSURE REGAIN **-65.69533** Pa

USE DUCT **1600** x **800** mm

FRICTION OF THIS SECTION			
ITER.	f	LEFT	RIGHT
1	1000	0.031623	7.741867
2	0.016684	7.741867	6.560321
3	0.023235	6.560321	6.665379
4	0.022509	6.665379	6.655506
5	0.022576	6.655506	6.656429
6	0.022569	6.656429	6.656343
7	0.02257	6.656343	6.656351
8	0.02257	6.656351	6.656350
9	0.02257	6.656350	6.656350
10	<b>0.02257</b>	6.656350	6.656350

Project	Emission Gas Treatment (After Burner Sysytem)	REV.	DATE
LINE	Stream 8	0	Mar.25'99
	MADE		

**STATIC REGAIN DUCT SIZING**

DENSITY 1.037 kg/m<sup>3</sup>      ROUGHNESS 0.15 mm  
 VISC. 0.0194 cP = 1.94E-05 N.s/m<sup>2</sup>

	PREVIOUS	THIS	
WIDTH		1600	mm
HIGH		800	mm
DIAMETER	50"	1270	mm
		1.27	m
AREA		1.266769	m <sup>2</sup>

FLOW 63596.9 m<sup>3</sup>/hr  
 VELOCITY 13.94557 m/s  
 REYNOLDS 946709.8

LENGTH 10 m  
 DROP/m@THIS SECTION 1.792029 Pa/m

TOTAL DROP 17.92029 Pa  
1.83 mmAq  
 STATIC PRESSURE REGAIN -75.62794 Pa

USE DUCT 1600 x 800 mm

FRICTION OF THIS SECTION			
ITER.	f	LEFT	RIGHT
1	1000	0.031623	7.741867
2	0.016684	7.741867	6.560321
3	0.023235	6.560321	6.665379
4	0.022509	6.665379	6.655506
5	0.022576	6.655506	6.656429
6	0.022569	6.656429	6.656343
7	0.02257	6.656343	6.656351
8	0.02257	6.656351	6.656350
9	0.02257	6.656350	6.656350
10	<b>0.02257</b>	6.656350	6.656350



## ภาคผนวก ณ แบบต่างๆของระบบ After Burning


### รายการของแบบในระบบได้แก่

หน้า

1) แบบแสดงท่อและอุปกรณ์วัดคุม.....	188
2) แบบแสดงรายการของอุปกรณ์ในระบบ.....	189
3) แบบแสดงข้อมูลของไซโคลน.....	190
4) แบบแสดงข้อมูลของพัดลม.....	191
5) แบบแสดงผังตำแหน่งของอุปกรณ์.....	192
6) แบบแสดงรายการใช้ไฟฟ้าของอุปกรณ์ในระบบ.....	194
7) แบบแสดงผังไฟฟ้าสายเดี่ยว.....	195
8) แบบแสดงอุปกรณ์วัดคุมความดัน.....	196
9) แบบแสดงอุปกรณ์วัดคุมอุณหภูมิ.....	197

D-201  
CYCLONE  
DIA : 432 mm x 1693 mm

Y-101  
THERMAL INCINERATOR  
WASTE GAS FLOW 2955 m<sup>3</sup>/h  
COMBUSTION TEMP. 982 °C  
EFFICIENCY 99 %



B-201  
BLOWER  
CAPACITY : 52490 Nm<sup>3</sup>/h  
DIFF. HEAD : 200 mm Aq

EQUIPMENT LIST

Plant System


Emission Gas Treatment After Burner System

Sheet 1 of 1

Rev	Date	Made	hecke	Approved
0	Feb,09,199	N.A	N.A	

ITEM NO.	NAME	NO. REQ'D		DESIGN CONDITION		OPERATING CONDITION		FLUID	TYPE	SPECIFICATIONS	MATERIAL	MOTOR kW	ELEC. kW	REMARKS	
		W	S	PRESS. barG	TEMP. °C	PRESS. barA	TEMP. °C								
		1	Y-201	Thermal Incinerator	1	-	-300 mmAq								>1000
2	D-201	Cyclone	1	-	-300 mmAq	450	-200 mmAq	400	Emission Gas	General	Press drop <100 mmAq Dia 632mm x 3669 mm	CS	-	-	
3	B-201	Blower	1	-	-300/100 mmAq	200	-200 mmAq	58	Treated Gas	Centrifugal	52490 Nm <sup>3</sup> /h , 200 mmAq 200 mmAq 38 KW , 380 V , 3 Ph , 50 HZ	CS/CS	75	-	

		PLANT : EMISSION GAS TREATMENT						
<b>DESIGN DATA</b>		ITEM NO. : D-201						
CODE <input type="checkbox"/> ASME/ANSI RTP-1 <input type="checkbox"/> JIS B 824 <input checked="" type="checkbox"/> NONE		SERVICE NAME : CYCLONE						
DESIGN PRESS. -0.05 bar / FW		<b>WEIGHT &amp; CAPACITY</b>						
DESIGN TEMP. 450 °C								
CORROSION ALLOWANCE 1.0 mm								
HYDRO. TEST PRESS. <input type="checkbox"/> AS PER CODE <input checked="" type="checkbox"/> FW kg/cm <sup>2</sup> G								
PNEUM. TEST PRESS. <input type="checkbox"/> AS PER CODE <input checked="" type="checkbox"/> NONE kg/cm <sup>2</sup> G		ERECTION WEIGHT 125				kg		
POST WELD HEAT TREATMENT <input type="checkbox"/> AS PER CODE <input type="checkbox"/> YES <input checked="" type="checkbox"/> NONE		OPERATING WEIGHT 125				kg		
RADIOGRAPHY <input type="checkbox"/> AS PER CODE <input checked="" type="checkbox"/> NO		FULL WATER WEIGHT 1000				kg		
LONG JOINT EFFICIENCY <input type="checkbox"/> AS PER CODE <input checked="" type="checkbox"/> 0.7		CAPACITY 0.7				m <sup>3</sup>		
INSULATION <input type="checkbox"/> HOT <input type="checkbox"/> COLD <input checked="" type="checkbox"/> P.P. ( MM) <input type="checkbox"/> NO		<b>NOZZLE SCHEDULE</b> <input checked="" type="checkbox"/> ANSI B16.5 <input type="checkbox"/>						
WIND PRESSURE None		MARK	NO. REQD	SIZE	RATING	TYPE	FACING	DESIGNATION
EARTHQUAKE FACTOR None		A	1	153X306	Cal		FF	GAS INLET
<b>MATERIAL SPECIFICATIONS</b>		B	1	306	Cal		FF	GAS OUTLET
		C	1	153	Cal		FF	DUST OUTLET
		SHELL & HEAD CS						
SUPPORTS CS								
INTERNALS CS								
NOZZLE NECKS CS								
FLANGES CS								
BOLTS & NUTS CS								
GASKETS CAF								




2									
1									
0									FOR PROPOSAL
REV.	DWG	CHK	GL	SC	MGR	APPR	DATE	DESCRIPTION	



DWG. NO.

**DATA SHEET  
FOR  
CENTRIFUGAL BLOWNER**

<p>1 CUSTOMER</p> <p>2 LOCATION</p> <p>3 UNIT <b>Gas Treatment System</b></p> <p>4 SUPPLIER</p> <p>5 ITEM NO. <b>B-201</b></p> <p>6 SERVICE</p> <p>7 NO REQ'D (WORKING   STAND-BY - TOTAL   )</p>	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>REV</th> <th>LINE</th> <th>DATE</th> <th>A/E</th> <th>CHIEF</th> <th>MGR.</th> <th>PE.</th> <th>PEM</th> <th>PM.</th> </tr> <tr> <td>0</td> <td></td> <td>Mar26'99</td> <td>N.A</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>1</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>3</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>5</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>	REV	LINE	DATE	A/E	CHIEF	MGR.	PE.	PEM	PM.	0		Mar26'99	N.A						1									2									3									4									5								
REV	LINE	DATE	A/E	CHIEF	MGR.	PE.	PEM	PM.																																																								
0		Mar26'99	N.A																																																													
1																																																																
2																																																																
3																																																																
4																																																																
5																																																																
<b>OPERATING CONDITIONS</b>																																																																
<p>9 GAS COMPOSITION <b>Treated Gas</b></p> <p>10</p> <p>11</p> <p>12 SOLID AT SUCTION (g/Nm<sup>3</sup>)</p> <p>13 R. H. AT SUCTION (%)</p> <p>14 MOLECULAR WEIGHT <b>28.45</b></p> <p>15 SPEC. WEIGHT AT SUCTION (kg/m<sup>3</sup>) <b>1.037</b></p> <p>16 COMP. FACTOR (Z)</p>	<p>CAPACITY <b>52490</b> Nm<sup>3</sup>/h DRY BASE</p> <p>m<sup>3</sup>/hr/ AT SUCTION</p> <p>TEMP. SUCTION (°C)</p> <p>DISCHARGE <b>58</b> (°C)</p> <p>PRESS. DISCHARGE (STATIC) <b>0</b> mmAqG</p> <p>SUCTION RATED (STATIC) <b>-200</b> mmAqG</p> <p>DIFF. (STATIC) <b>200</b> mmAqG</p> <p>INSTALLATION <input type="checkbox"/> INDOOR <input checked="" type="checkbox"/> OUTDOOR</p>																																																															
<b>CONSTRUCTIONS</b>																																																																
<p>18 MFR. #</p> <p>19 TYPE <input checked="" type="checkbox"/> CENTRIF-BACKWARD <input type="checkbox"/> CENTRIF-RADIAL</p> <p><input type="checkbox"/> MULTI-BLADE <input type="checkbox"/> MIXED FLOW <input type="checkbox"/> AXIAL</p> <p>21 CASE : MOUNT <input type="checkbox"/> BRACKET <input type="checkbox"/> FOOT <input type="checkbox"/> C-LINE <input type="checkbox"/> CAST</p> <p>22 : SPLIT <input type="checkbox"/> AXIAL <input type="checkbox"/> RADIAL</p> <p>23 : CONSTRUCTION <input checked="" type="checkbox"/> FABRICATED <input type="checkbox"/> CAST</p> <p>24 DIA. VALUE</p> <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>NOZZLE</th> <th>SIZE</th> <th>RATING</th> <th>FACING</th> <th>POSITION</th> </tr> <tr> <td>SUCTION</td> <td>#</td> <td>#</td> <td>FF</td> <td>END</td> </tr> <tr> <td>DISCH.</td> <td>#</td> <td>#</td> <td>FF</td> <td>TOP</td> </tr> </table> <p>28 WHEEL NO. <input type="checkbox"/> OVHG <input type="checkbox"/> BET-BRG</p> <p>29 TYPE <input type="checkbox"/> CLOSED <input type="checkbox"/> SEMI-OPEN <input type="checkbox"/> OPEN</p> <p>30 SUCTION <input checked="" type="checkbox"/> SINGLE <input type="checkbox"/> DOUBLE</p> <p>31 HUB FIT</p> <p>32 CONSTRUCTION <input type="checkbox"/> FABRICATED <input type="checkbox"/> CAST</p> <p>33 DIA. (mm.) CLEARANCE (mm.)</p> <p>34 BLADE TYPE <input type="checkbox"/> HOLLOW <input type="checkbox"/> SOLID AIRFOIL</p> <p><input type="checkbox"/> SINGLE-THICK, NO. OF BLADES</p> <p>36 BEARING RADIAL NO.</p> <p>37 TURUST NO.</p> <p>38 BEARING HOUSE CONSTRUCTION</p> <p>39 LUBE <input type="checkbox"/> OIL RING <input type="checkbox"/> FLOOD <input type="checkbox"/> FLING <input type="checkbox"/> PRESS</p> <p><input type="checkbox"/> GREASE <input type="checkbox"/> MIST-PURE <input type="checkbox"/> MIST-PURGE</p> <p>41 POWER TRANS <input type="checkbox"/> DIRECT <input type="checkbox"/> GEAR <input type="checkbox"/> V-BELT <input type="checkbox"/> SPD'VAR</p> <p>42 COUPLING <input type="checkbox"/> FLEX <input type="checkbox"/> RIGID <input type="checkbox"/> F-DISK <input type="checkbox"/> SPACER</p> <p>43 MFR. MODEL</p> <p>44 ROTATION VIEWED FROM CPL'G END <input type="checkbox"/> CW <input type="checkbox"/> CCW</p> <p>45 BASEPLATE <input checked="" type="checkbox"/> COMMON <input type="checkbox"/> SOLE <input type="checkbox"/> SEPARATE</p> <p><input type="checkbox"/> GROUTING REQUIREMENT</p> <p>47 NOZZLE ORIENTATION TYPE NO</p> <p>48 APPL. ENG. SPEC</p> <p>49 CODE/STANDARD</p>	NOZZLE	SIZE	RATING	FACING	POSITION	SUCTION	#	#	FF	END	DISCH.	#	#	FF	TOP	<p>CODE</p> <p>CASE HOUSING</p> <p>INTERNAL</p> <p>IMPELLER</p> <p>SS41</p> <p>SHAFT</p> <p>S35C</p> <p>SLEEVE</p> <p>GASKET</p> <p>LABYRINTH</p> <p>BASEPLATE</p> <p>SSC41</p> <p><input type="checkbox"/> LINING</p>																																																
NOZZLE	SIZE	RATING	FACING	POSITION																																																												
SUCTION	#	#	FF	END																																																												
DISCH.	#	#	FF	TOP																																																												
<b>PERFORMANCE</b>																																																																
<p>28 WHEEL NO. <input type="checkbox"/> OVHG <input type="checkbox"/> BET-BRG</p> <p>29 TYPE <input type="checkbox"/> CLOSED <input type="checkbox"/> SEMI-OPEN <input type="checkbox"/> OPEN</p> <p>30 SUCTION <input checked="" type="checkbox"/> SINGLE <input type="checkbox"/> DOUBLE</p> <p>31 HUB FIT</p> <p>32 CONSTRUCTION <input type="checkbox"/> FABRICATED <input type="checkbox"/> CAST</p> <p>33 DIA. (mm.) CLEARANCE (mm.)</p> <p>34 BLADE TYPE <input type="checkbox"/> HOLLOW <input type="checkbox"/> SOLID AIRFOIL</p> <p><input type="checkbox"/> SINGLE-THICK, NO. OF BLADES</p> <p>36 BEARING RADIAL NO.</p> <p>37 TURUST NO.</p> <p>38 BEARING HOUSE CONSTRUCTION</p> <p>39 LUBE <input type="checkbox"/> OIL RING <input type="checkbox"/> FLOOD <input type="checkbox"/> FLING <input type="checkbox"/> PRESS</p> <p><input type="checkbox"/> GREASE <input type="checkbox"/> MIST-PURE <input type="checkbox"/> MIST-PURGE</p> <p>41 POWER TRANS <input type="checkbox"/> DIRECT <input type="checkbox"/> GEAR <input type="checkbox"/> V-BELT <input type="checkbox"/> SPD'VAR</p> <p>42 COUPLING <input type="checkbox"/> FLEX <input type="checkbox"/> RIGID <input type="checkbox"/> F-DISK <input type="checkbox"/> SPACER</p> <p>43 MFR. MODEL</p> <p>44 ROTATION VIEWED FROM CPL'G END <input type="checkbox"/> CW <input type="checkbox"/> CCW</p> <p>45 BASEPLATE <input checked="" type="checkbox"/> COMMON <input type="checkbox"/> SOLE <input type="checkbox"/> SEPARATE</p> <p><input type="checkbox"/> GROUTING REQUIREMENT</p> <p>47 NOZZLE ORIENTATION TYPE NO</p> <p>48 APPL. ENG. SPEC</p> <p>49 CODE/STANDARD</p>	<p>SPEED (rpm)</p> <p>EFF. (STATIC) (%)</p> <p>BHP RATED AT MIN. TEMP. (kW)</p> <p>SUCTION <input type="checkbox"/> NET <input type="checkbox"/> FILTER <input type="checkbox"/> SILENCER</p> <p>MFR. TYPE</p> <p>PD CLEAN MAX. (mmAq)</p> <p><input type="checkbox"/> SUCTION DAMPER <input type="checkbox"/> DISCHARGE DAMPER</p> <p>CONTROL <input type="checkbox"/> MAN. <input type="checkbox"/> AUTO.</p> <p>SIGNAL <input type="checkbox"/> ELEC <input type="checkbox"/> PNEUM RANGE (%)</p> <p>MAX. OPERATING PRESS. (mmAqG)</p> <p>CASE DES. PRESS. (kg/cm<sup>2</sup> G TEMP. (°C))</p> <p><input type="checkbox"/> CASE HYD. TEST PRESS (kg/cm<sup>2</sup> G)</p> <p>TYPE OF SEAL</p> <p><input type="checkbox"/> MEACH. SEAL MFR</p> <p>MODEL NO. OF SEAL</p> <p>TYPE API CODE</p> <p>MFR'S CADE</p> <p>MAT'L FACE VS</p> <p>METAL GASKET</p> <p>OTHER SEAL MFR</p> <p>MODEL NO. OF RING</p> <p>MATERIAL</p>																																																															
<b>AUX. CONNECTIONS</b>																																																																
<p>51 SERVICE FLUID</p> <p>52 INLET CONDITION (kg/cm<sup>2</sup> G) (°C)</p> <p>53 SP. GR.</p> <p>54 FLOW (m<sup>3</sup>/h)</p> <p>55 MATERIAL (#1)</p> <p>56 CONNECTIONS</p> <p>57 SIZE</p> <p>58 RATING</p> <p>59 FACE</p>	<p>60 TAPPED OPENING <input type="checkbox"/> DRAIN <input type="checkbox"/> VALVE <input type="checkbox"/> CAP <input type="checkbox"/> PLUG <input type="checkbox"/> FLANGE (SIZE RATE FACE)</p> <p>61 SPACE REQ'T (L*W*H) (m)</p> <p>62 HAZARD CLASS</p> <p>63 NOISE LEVEL (dBA@1m)</p> <p>64 ACOUST ENCLOSURE SUPPLIED BY VENDOR</p> <p>65 WEIGHT (kg) BLOWER BASE MOTOR</p>																																																															
<b>MOTOR</b>	<b>TURBINE</b>																																																															
<p>61 SUPPLIED BY VENDOR</p> <p>62 MFR. TYPE</p> <p>63 RATED OUTPUT ### (kW) POLE</p> <p>64 SPEED (rpm)</p> <p>65 PHASE 3 CYCLE 50 VOLTS 380</p> <p>66 INSULATION CLASS IP</p> <p>67 HAZARDOUS AREA CLASS -</p>	<p>SUPPLIED BY MFR.</p> <p>MOUNTED BY TYPE</p> <p>RATED OU kW (kW) SPEED (rpm)</p> <p>INLET STEAM (kg/cm<sup>2</sup> G) (°C)</p> <p>EXHAUST (kg/cm<sup>2</sup> G)</p> <p>BRG LUBE</p> <p>STEAM RATE (kg) AT RATED</p>																																																															
NOZZLE ORIENTATION VIEWED FROM CPL'G END																																																																
<b>REMARKS</b>																																																																

แบบแสดงข้อมูลของพัดลม.





Rev	Date	Made	Checke	Aprr
0	04/06/99	N.A	N.A	

ELECTRICAL CONSUMPTION LIST

Plant System


Emission Gas Treatment After Burner System

Sheet 1 of 1

NO.	ITEM NO.	NAME	NO. REQ'D		Capacity (KW)	Phase	Voltage (V)	Frequency (Hz)	Motor Type	Start Method	Speed (rpm)	REMARKS
			W	S								
1	B-201	Blower	1	-	75	3	380	50	Vertical TEFC, Outdoor	Direct on-line	1450	
2	Y-201	After Burner	1	-	0.2	1	220	50	Horizontal TEFC, Outdoor	Direct on-line	2900	

แบบแสดงรายการใช้ไฟฟ้าของอุปกรณ์ในระบบ.





แบบแสดงผังไฟฟ้าสายเดี่ยว.


แบบแสดงอุปกรณ์วัดคุมความดัน.

INSTRUMENT DATA SHEET ( PRESSURE )					
				System : After	
				Burner	
				Sheet No. : 1/1	
				Rev : 0	
				Rev Date : Apr.06, 1999	
				Made By : N.A	
1	STREAM No.	4	-	8	4
2	TAG No.	PI 201	PI 202	PI 203	PCV 201 A-C
3	QUANTITY	1	1	1	3
4	SERVICE	LPG Line	Y-201	Air to Stack	LPG Tanks
5	FLUID	LPG	Combustion Gas	Treated Gas	LPG
6	PHASE	Gas	Gas	Gas	Gas
7	DESIGN TEMPERATURE,	60	1000	150	60
8	OPER. TEMPERATURE, °	30	981	57.8	30
9	DESIGN PRESSURE, BAR	1	50 mmAq	200 mmAq	35
10	MAX. PRESSURE, BAR A	-	0 mmAq	50 mmAq	33.5
11	NOR. PRESSURE, BAR A	1.5	-150 mmAq	25 mmAq	14.5
12	MIN. PRESSURE, BAR A	-	-	0 mmAq	
13	ALARM ACTION	-	-	-	
14	ALARM SET POINT, BAR A	-	-	-	
15	METER RANGE, BAR G	0 ~ 6	-200 ~50 mmAq	-200 ~200 mmAq	
16	SPECIAL INSTRUMENT TY	Bourdon	Compound	Barometer	Regulator
17	SPECIAL MATERIAL	-	-	-	-
18	LINE SIZE, INCH	1/2	1/2	1/2	1/2
19	LINE CLASS	CS	-	CS	CS
20	REMARKS	-	Local Panel	-	Differntial
			Mounted with		Pressure
			Package unit		
21	P & ID No.	2	2	2	2


แบบแสดงอุปกรณ์วัดอุณหภูมิ.

INSTRUMENT DATA SHEET ( TEMPERATURE )		System : After Burner	
		Sheet No. : 1/1	
		Rev : 0	
		Rev Date : Apr.06, 1999	
		Made By : N.A	
1	STREAM No.	-	8
2	TAG No.	TI 201	TI 202
3	QUANTITY	1	1
4	SERVICE	Y-201	B-201 Outlet
5	PHASE	Gas	Gas
6	DESIGN TEMPERATURE, °	1000	400
7	DESIGN PRESSURE, BAR	-200 mmAq	100 mmAq
8	OPER. PRESSURE, BAR A	-100 mmAq	25 mmAq
15	MAX. TEMP., °C	1000	400
16	NOR. TEMP., °C	982	58.7
17	MIN. TEMP., °C	-	-
18	ALARM ACTION	H	-
19	ALARM SET POINT, °C	1000	-
20	METER RANGE, °C	0~1200	0~400
21	SPECIAL INSTRUMENT TY	Thermocouple	Bi-Metal
22	SPECIAL MATERIAL	-	-
23	LINE SIZE, INCH	3/4	3/4
24	LINE CLASS	-	-
25	REMARKS	Local Panel	-
		Mounted with	
		Package unit	
26	P & ID No.	2	2


ภาคผนวก ด รูปร่างลักษณะและแบบแสดงการจัดเรียงภายในของเครื่องกำจัดฝุ่นแบบไฟฟ้า  
สถิตย์ (32)




รูป ด.1 รูปร่างลักษณะทั่วไปของเครื่องกำจัดฝุ่นแบบไฟฟ้าสถิตย์.



รูปด.2 รูปร่างลักษณะภายในของเครื่องกำจัดฝุ่นแบบไฟฟ้าสถิตย์.




รูปด.3 แสดงการจัดวางขั้วคาโชด.




รูปด.4 แสดงการจัดวางของเครื่องกำเนิดไฟฟ้าสถิตย์.






รูปด.6 แสดงการไหลของก๊าซผ่านเครื่องกำจัดฝุ่นแบบไฟฟ้าสถิตย์.



รูปด.5 แสดงการจัดวางภายในเครื่องกำเนิดไฟฟ้าสถิตย์.



รูปด.7 แสดง Support ของขั้วคาโทดภายใน.

## ประวัติผู้เขียน



นายนพดล อุนจาร์อาภา เกิดวันที่ 19 พฤศจิกายน พ.ศ. 2513 ที่จังหวัด กรุงเทพมหานคร สำเร็จการศึกษาปริญญาตรีวิศวกรรมศาสตรบัณฑิต ภาควิชาวิศวกรรมเคมี คณะวิศวกรรมศาสตร์ มหาวิทยาลัยเทคโนโลยีพระจอมเกล้าธนบุรี (สถาบันเทคโนโลยีพระจอมเกล้าธนบุรี) ในปีการศึกษา 2535 และเข้าศึกษาต่อในหลักสูตรวิศวกรรมศาสตรมหาบัณฑิต ภาควิชาวิศวกรรมเคมี คณะวิศวกรรมศาสตร์ จุฬาลงกรณ์มหาวิทยาลัย เมื่อ พ.ศ. 2537